



## LNG liquefaction plant

# HAZOP and SIL Allocation Report

**Project** 23123I  
**Revision** 00  
**Date** April 2023  
**File:** 23123I\_HAZOP&SIL\_Report\_LNG\_plant\_rev00.docx



**LNG liquefaction plant**

HAZOP and SIL Allocation Report

PROJECT 23123I	DATE April 2023	PAGE 2 di 14
-------------------	--------------------	-----------------

**INDEX**

<b>INTRODUCTION.....</b>	<b>3</b>
<b>1 PROJECT OVERVIEW.....</b>	<b>4</b>
1.1 HAZOP and SIL allocation scope of work.....	4
<b>2 DEFINITIONS AND ACRONYMS .....</b>	<b>5</b>
2.1 Definitions .....	5
2.2 Acronyms.....	7
<b>3 REFERENCES.....</b>	<b>7</b>
3.1 Standards and guidelines.....	8
3.2 Project documentations .....	8
<b>4 HAZOP AND SIL METHODOLOGY .....</b>	<b>9</b>
<b>5 HAZOP NODES .....</b>	<b>10</b>
<b>6 HAZOP AND SIL TEAM AND VENUES .....</b>	<b>11</b>
<b>7 HAZOP RESULTS.....</b>	<b>12</b>
7.1 HAZOP Worksheet.....	12
7.2 HAZOP Recommendations .....	12
<b>8 SIL ALLOCATION RESULTS.....</b>	<b>13</b>
8.1 SIL Worksheet.....	13
8.2 SIL Allocation Recommendations.....	14

**ATTACHMENT**

<b>Attachment 1</b>	Attendance List
<b>Attachment 2</b>	Master Copy P&IDs
<b>Attachment 3</b>	HAZOP Worksheet
<b>Attachment 4</b>	HAZOP Action List
<b>Attachment 5</b>	SIL Worksheet
<b>Attachment 6</b>	SIFs List
<b>Attachment 7</b>	Reference HAZOP/SIL Procedures

## LNG liquefaction plant

HAZOP and SIL Allocation Report

PROJECT	DATE	PAGE
23123I	April 2023	3 di 14

### INTRODUCTION

SIAD Macchine Impianti S.p.A. (the CLIENT) has been awarded by OGE (the COMPANY) for engineering services and provision of new LNG liquefaction plant to be located in Renzenhof (Germany). Within this framework, the CLIENT requested ICARO to provide support to carry out:

- HAZOP (Hazard and Operability) study;
- SIL Allocation.

HAZOP study and SIL Allocation were led by ICARO's senior consultant company, with the participation of SIAD and OGE technicians, also involving a TÜV representative, according to German regulations.

HAZOP and SIL allocation workshops ("sessions") have been held as reported here below:

- From **27<sup>th</sup> to 31<sup>st</sup> March 2023** in SIAD premises in Bergamo (Italy),
- From **3<sup>rd</sup> to 6<sup>th</sup> April 2023** in OGE premises in Essen (Germany),
- On **17<sup>th</sup> April 2023** via teleconference.

Present document shows the results of the HAZOP study and SIL Allocation.

HAZOP study allowed to analyse a total number of **26 nodes** and suggest a total number of **67 actions**.

SIL study allowed to analyse a total number of **46 SIFs** and suggest a total number of **10 actions**.

According to the final global results of this study, have been identified:

- A number of **17 SIFs not SIL rated**;
- A number of **25 SIFs rated SIL1**;
- A number of **4 SIFs rated SIL2**.

## LNG liquefaction plant

HAZOP and SIL Allocation Report

PROJECT	DATE	PAGE
23123I	April 2023	4 di 14

### 1 PROJECT OVERVIEW

The project consists into design and provision of new LNG liquefaction plant to be located in Renzenhof (Germany).

Plant is composed of following units:

- natural gas fiscal metering station;
- mercury removal unit;
- CO2 absorption unit;
- amine stripping unit;
- MDEA solvent addition and removal unit;
- natural gas precooling and drying unit;
- liquefaction unit;
- LNG storage;
- LNG truck loading bay.

#### 1.1 HAZOP and SIL allocation scope of work

HAZOP Review will involve equipment and systems under CLIENT's scope of work (main process).

The following systems have not been included in the scope of work of the present HAZOP analysis.

- Packages provide by third-party vendors: steam generation section, cooling water circuit, chillers, demi water package, thermal oxidizer, instrument air package, LIN storage tanks, hot flare.
- Auxiliaries associated to compressors and other machines.

The above listed items have been analyzed from a HAZOP perspective relatively to the interconnection points (interface approach) with main process units and the mutual interactions between the systems were reviewed.

For what concern SIL allocation, only SIFs addressed to prevent scenario with potential impact on personnel safety and/or environment (according to HAZOP outcomes) have been reviewed.

**LNG liquefaction plant**

HAZOP and SIL Allocation Report

 PROJECT  
23123I

 DATE  
April 2023

 PAGE  
5 di 14

## 2 DEFINITIONS AND ACRONYMS

### 2.1 Definitions

<b>Basic Process Control System</b>	The system that responds to input signals from the process and generates output signals to maintain operation of the process in a desired state. The system does not perform functions assessed as SIL 1 or higher.
<b>Beta Factor</b>	The number of Common Mode Failures (of robust Initiators or Final Elements), expressed as a fraction of all possible Failures.
<b>Cause</b>	Reason the occurrence of deviation. Once a deviation can be shown to have a conceivable or realistic cause, then it becomes meaningful. Only single jeopardy together with all relevant effects shall be considered during HAZOP. Deviation is meaningful only if it is physically possible.
<b>Common Mode Failure</b>	A Failure having the potential to affect all duplicated components in a robust configuration by virtue of common or shared characteristics.
<b>Consequences</b>	Results of the deviations.
<b>Dangerous Failure</b>	A Failure that has the potential to place the SIL/IPF in a state in which it will fail to perform its function. Dangerous Failures are usually only safe when the system has to perform a certain action or through testing. Also known as unrevealed failure.
<b>Dangerous Failure Rate</b>	The number of Dangerous Failures per unit time.
<b>Dangerous Failure Robustness</b>	A configuration in which plant integrity is not jeopardised by the Dangerous Failure of a single SIL/IPF component. Also known as unrevealed failure robustness.
<b>Demand</b>	A process or equipment condition or event which requires an IPF / SIF to take action to prevent a Hazardous Situation.
<b>Demand Rate</b>	The frequency at which a Demand occurs, i.e., the number of Demands per unit time.
<b>Design intent</b>	Describes the designer's desired or specific range of behaviour for elements and characteristics (operating conditions); also identified as "INTENTION".
<b>Deviation</b>	Departure from design intent. The variations from the intention are systematically identified by applying the "guidewords"
<b>Diagnostic Coverage Factor</b>	The number of Dangerous Failures that diagnostic features are capable of detecting, expressed as a fraction of all possible dangerous failures.  (NOTE: Diagnostic features may only be recognised as such if they can trip the process to a safe state or maintain safety by different means.)
<b>Failure</b>	An abnormal condition that may cause a reduction or loss of capability of the IPF to perform its intended function.
<b>Final Element</b>	A device, or combination of devices, that manipulate a process variable or attract the attention of the operator to achieve risk reduction. The Final Element includes output cards or output relays, solenoid valves and cabling. Examples are valves, switchgear (rotating equipment stop circuits) and alarms.
<b>Guidewords</b>	Simple words which are used to qualify each intention in order to guide and stimulate the creative thinking process and discover deviations.
<b>Hazard or Hazardous Situation</b>	A situation with the potential to cause harm, including ill health and injury, damage to property, products or the environment, production losses or increased liabilities.
<b>Hazard Rate</b>	The frequency at which Hazardous Situations occur per unit time.  Hazard Rate = Demand rate x Probability of Failure on Demand.
<b>Initiator</b>	A device, or combination of devices, that indicates whether a process or equipment item is operating outside the operating envelope. The Initiator includes input cards and input relays. Examples are manual switches, position switches and measurement systems (including process connections, sensors, transmitters, cabling, trip amplifiers or input cards etc.).  In IEC 61508/61511 an Initiator is referred to as a Sensor.

**LNG liquefaction plant**

HAZOP and SIL Allocation Report

 PROJECT  
23123I

 DATE  
April 2023

 PAGE  
6 di 14

<b>Independent Protection Layer</b>	<p>IPL. Device, system, or action that is capable of preventing a postulated accident sequence from proceeding to a defined, undesirable endpoint. An IPL is (1) independent of the event that initiated the accident sequence and (2) independent of any other IPLs. IPLs are normally identified during layer of protection analyses.</p>
<b>Inspection Time</b>	<p>Time interval between proof tests</p>
<b>Instrumented Protective Function</b>	<p>A function comprising one or more Initiators, a Logic Solver and one or more Final Elements whose purpose is to prevent or mitigate hazardous situations.</p> <p>An IPF is intended to achieve or maintain a safe state for the process, in respect of a specific hazardous event.</p> <p>In IEC 61508/61511 an IPF is referred to as a SIF.</p>
<b>Instrumented Protective System / Safety Instrumented System</b>	<p>The electromechanical, electronic and/or programmable electronic Logic Solver component of the Instrumented Protective Function, complete with input and output equipment. In IEC 61508/61511 an IPS or SIS are referred to as a 'Logic Solver'.</p>
<b>Safeguards</b>	<p>Protection, detection and indication mechanisms for the deviation and relevant consequences, which may be included within the selected part or form a portion of the design intentions of other parts</p>
<b>Logic Solver</b>	<p>The portion of an IPF / SIF that performs the application logic function. The Logic Solver excludes trip amplifiers, input cards and output cards. Examples are electromechanical relays, solid-state/magnetic-core logic and the CPU section of programmable electronic systems.</p>
<b>Mean Time To Restoration</b>	<p>Time interval to repair the failing component. Includes repair time, shipping and managing time</p>
<b>Mitigation</b>	<p>The action of making a consequence less severe or relieving consequences.</p>
<b>Parameters</b>	<p>The team generates possible deviations applying guidewords to various process parameters such as 'Flow', 'Level' and 'Pressure'. The selection of parameters is an important task for each team to devise for each individual system.</p>
<b>Partial Valve Stroke Test</b>	<p>Technique to test a percentage of the possible failure modes of a valve without the need to physically fully close the valve itself.</p>
<b>Probability of Failure on Demand</b>	<p>The probability (dimensionless) of the IPF or SIS failing to respond to a Demand.</p>
<b>Programmable electronics</b>	<p>Electronic component or device forming part of a PES and based on computer technology. The term encompasses both hardware and software and input and output units.</p> <p>(NOTE: This term covers micro-electronic devices based on one or more CPUs together with associated memories, etc. Examples of process sector programmable electronics include: smart sensors; final elements; and programmable electronic logic solvers, such as, programmable controllers, PLCs, DCS, loop controllers.)</p>
<b>Programmable Electronic System</b>	<p>System for control, protection or monitoring based on one or more programmable electronic devices, including all elements of the system such as power supplies, sensors and other input devices, data highways and other communication paths, actuators and other output devices. As an example, an IPS or SIS could be a PES.</p>
<b>Proof Test</b>	<p>A test carried out on IPF components against an approved procedure to confirm that all requirements of the IPF are met.</p>
<b>Proof Test Coverage Factor</b>	<p>The number of Dangerous Failures detected by the Proof Test expressed as a fraction of all possible dangerous failures.</p>
<b>Recommendation</b>	<p>Additional safety measure identified by process team, intended to reduce the risk connected to a specific deviation (also identified as "ACTION").</p>
<b>Risk</b>	<p>The frequency at which a Hazardous Situation occurs multiplied by the consequence of the Hazardous Situation.</p>
<b>Risk Reduction Factor</b>	<p>Is the contribute on an IPL to reduce risk allocated.</p>
<b>Safe Failure</b>	<p>A Failure whose occurrence does not have the potential to place an IPF in a dangerous state. Also known as revealed failure.</p>
<b>Safe Failure Rate</b>	<p>The number of Safe Failures per unit time.</p>

## LNG liquefaction plant

HAZOP and SIL Allocation Report

PROJECT	DATE	PAGE
23123I	April 2023	7 di 14

<b>Safe Failure Fraction</b>	The safe failure fraction (SFF) is the fraction of the overall failure rate of a device that results in either a safe fault or a diagnosed unsafe fault.
<b>Safety Integrity Level</b>	Dangerous failure class 1, 2, 3 or 4 derived from the consequences of failure on demand and the frequency of demand. The definition in IEC 61511: discrete level (one out of four) for specifying the safety integrity requirements of the IPF / SIF to be allocated to the SIS (trip systems). Safety integrity level 4 has the highest level of safety integrity; safety integrity level 1 has the lowest.
<b>Trip</b>	An Instrumented Protective Function action to bring the Final Element to a safe state.
<b>Undetected Failure</b>	A failure that is not detected by internal diagnostics
<b>Validation</b>	Confirmation that the system under consideration fully meets the integrity requirements set forth in the associated IPF Requirements Specification.
<b>Verification</b>	Demonstration for a particular life-cycle phase that all deliverables (documents, software, hardware) meet the objectives set for that phase.

## 2.2 Acronyms

<b>BOG</b>	Boil-Off Gas
<b>BPCS</b>	Basic Process Control System
<b>C&amp;E</b>	Cause and Effects Diagram
<b>DCS</b>	Distributed Control System
<b>ESD</b>	Emergency Shut Down
<b>ESDV</b>	Emergency Shut Down Valve
<b>F&amp;G</b>	Fire and Gas
<b>HAZOP</b>	Hazard and Operability study
<b>HC(s)</b>	Hydrocarbon(s)
<b>HFT</b>	Hardware Fault Tolerance
<b>IE</b>	Initiating Event
<b>IEC</b>	International Electrotechnical Commission
<b>IGV</b>	Inlet guide vane
<b>IPL</b>	Independent Protection Layer
<b>IPF</b>	Instrumented Protective Function
<b>IPS</b>	Instrumented Protective System
<b>LIN</b>	Liquefied Nitrogen
<b>LNG</b>	Liquefied Natural Gas
<b>MDEA</b>	Methyl diethanolamine
<b>MTTR</b>	Mean Time To Restoration
<b>NG</b>	Natural Gas
<b>P&amp;ID</b>	Piping and Instrumentation Diagram
<b>PLC</b>	Programmable Logic Controller
<b>PFD</b>	Process Flow Diagram
<b>PFDavg</b>	Probability of Failure on Demand (average)
<b>PSV</b>	Pressure Safety Valve
<b>SDV</b>	Shut Down Valve
<b>SIF</b>	Safety Instrumented Function
<b>SIL</b>	Safety integrity Level
<b>SIS</b>	Safety Instrumented System

## 3 REFERENCES

## LNG liquefaction plant

HAZOP and SIL Allocation Report

PROJECT 23123I	DATE April 2023	PAGE 8 di 14
-------------------	--------------------	-----------------

### 3.1 Standards and guidelines

- IEC-61882 "Hazard and operability studies (HAZOP studies) – Application guide, 2016.
- "HAZOP and multistage hazard study", Institution of Chemical Engineers, 1999.
- "Guidelines for Hazard Evaluation Procedures", 2nd Edition, CCPS and AIChE, 1992.
- "A Guide to Hazard and Operability Studies", Chemical Industries Association, 1990.
- IEC 61508:2010 Part 1÷7 "Functional Safety of Electrical / Electronic / Programmable Electronic Safety-Related Systems";
- IEC 61511:2016 Part 1÷3 "Functional safety – Safety Instrumented Systems for the Process Industry Sector.

### 3.2 Project documentations

- C&E Matrix: 140REZH690010001PFS00101-0C;
- PFD: I20784 Sh 3 – 21;
- P&IDs:
  - 2220698-0C-10-001 sh 2 - 5
  - I20784 Sh 10 - Natural gas inlet
  - I20784 Sh 11 - NG reduction station for steam boiler
  - I20784 Sh 15 - Natural gas treatment and dryer
  - I20784 Sh 16 - Steam condensation and condensate subcooling
  - I20784 Sh 20 - Liquefier cold box LNG
  - I20784 Sh 22 - Liquefier cold box LNG
  - I20784 Sh 23 – Liquefier cold box LNG
  - I20784 Sh 25 – Nitrogen recycle compressor
  - I20784 Sh 26 – Nitrogen booster
  - I20784 Sh 27 - Nitrogen turbine
  - I20784 Sh 30 – LNG storage
  - I20784 Sh 31 – LNG storage
  - I20784 Sh 32 – LNG truck loading pump
  - I20784 Sh 33 – LNG truck loading pump
  - I20784 Sh 34 - Truck loading bay
  - I20784 Sh 35 - Truck loading bay
  - I20784 Sh 36 - NG regeneration cooler
  - I20784 Sh 37 - NG regeneration heater
  - I20784 Sh 37A - NG regeneration compressor
  - I20784 Sh 37B - NG regeneration compressor
  - I20784 Sh 38 – HC heater
  - I20784 Sh 38A – BOG compressor



**LNG liquefaction plant**

HAZOP and SIL Allocation Report

PROJECT 23123I	DATE April 2023	PAGE 9 di 14
-------------------	--------------------	-----------------

- I20784 Sh 38B - BOG compressor
- I20784 Sh 39A - Cold flare
- I20784 Sh 39B – Hot flare
- I20784 Sh 40 - Liquid nitrogen storage
- I20784 Sh 41 - Liquid nitrogen storage
- I20784 Sh 42 - Nitrogen distribution system
- I20784 Sh 43 - Instrument air distribution system
- I20784 Sh 50 - Steam boiler
- I20784 Sh 51 - Chiller
- I20784 Sh 60 - Instrument air package
- I20784 Sh 65 - Cooling water system
- I20784 Sh 66 - Cooling water system
- I20784 Sh 67 - Cooling water system
- I20784 Sh 68 - Demi water package
- I20784 Sh 70 - Thermal oxidizer
- I20784 Sh 74 - Analysis pumps
- I20784 Sh 75 - Analysis room
- I20784 Sh 80 - Motors control typical
- I20784 Sh 81 - Heaters control typical
- I20784 Sh 82 - ESD valves typical

#### 4 HAZOP AND SIL METHODOLOGY

The procedures that define modalities and methodologies to be followed in developing the Hazard and Operability - HAZOP – study and SIL allocation are included in **Attachment 7**.

**LNG liquefaction plant**

HAZOP and SIL Allocation Report

 PROJECT  
23123I

 DATE  
April 2023

 PAGE  
10 di 14

## 5 HAZOP NODES

An overall number of **26 nodes** has been identified for HAZOP purposes.

List of reference nodes is reported in the following table:

N	Nodes	Drawings
00	General issues	-
01A	Fiscal metering station	I20784 Sh 10
01B	Natural gas supply, preheating, HG removal and absorption	2220698-OC-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15
02	Natural gas supply to steam generator	I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70
03	Flash vessel	2220698-OC-10-001 Sh 2; I20784 Sh 15; I20784 Sh 36
04	NG stream to dryers and condensate separator	2220698-OC-10-001 Sh 2; 2220698-OC-10-001 Sh 5
05	MDEA Storage tank and dosing	2220698-OC-10-001 Sh 3; 2220698-OC-10-001 Sh 4
06	MDEA stripping column	2220698-OC-10-001 Sh 2; 2220698-OC-10-001 Sh 3; I20784 Sh 15
07	MDEA blowdown tank	2220698-OC-10-001 Sh 3; 2220698-OC-10-001 Sh 4
08	Antifoam dosing package	2220698-OC-10-001 Sh 3
09	Natural gas precooling, drying and liquefaction	2220698-OC-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20
10	Natural gas dryers regeneration loop	2220698-OC-10-001 Sh 3; 2220698-OC-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B
11	LNG separator	I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70
12	LNG storage tank including BOG loop	I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B
13	LNG tank and truck loading system	I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38
14	Heavy HCs KO drum	I20784 Sh 70
15	LNG drain KO drum and cold flare	I20784 Sh 39A
20	Cooling water circuit	I20784 Sh 50; I20784 Sh 51; I20784 Sh 65; I20784 Sh 66; I20784 Sh 67; I20784 Sh 68
21	Steam generation	I20784 Sh 10; I20784 Sh 15; I20784 Sh 37; I20784 Sh 38; I20784 Sh 50
22	Condensate collection	I20784 Sh 10; I20784 Sh 16; I20784 Sh 37; I20784 Sh 38; I20784 Sh 50
23	Chilled water circuit	I20784 Sh 15; I20784 Sh 25; I20784 Sh 36; I20784 Sh 51
24	Demi water package	I20784 Sh 68

**LNG liquefaction plant**

HAZOP and SIL Allocation Report

 PROJECT  
23123I

 DATE  
April 2023

 PAGE  
11 di 14

N	Nodes	Drawings
25	Instrument air production	I20784 Sh 42; I20784 Sh 43; I20784 Sh 60
30	Liquid Nitrogen supply to cold box and nitrogen recycle compressor	I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31
31	LNG subcooler	I20784 Sh 23
32	Liquid nitrogen vaporizers, nitrogen heater and distribution	I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Additional information regarding each node, listed above, (e.g. node intention - operating and design conditions, relevant P&IDs, equipment, specific notes, etc.) are reported in HAZOP worksheets (ref. to **Attachment 3**).

The complete set of marked-up P&IDs with the above stated nodes is reported in **Attachment 2**.

## 6 HAZOP AND SIL TEAM AND VENUES

HAZOP and SIL study working team was composed by technicians of SIAD Macchine Impianti S.p.A. (the CLIENT) and OGE (the COMPANY) and was led by Fabrizio Bucci, a 3<sup>rd</sup> party qualified specialist not involved in the project development, acted as HAZOP Chairperson/ SIL Facilitator.

HAZOP workshop sessions have been held:

- from **27<sup>th</sup> to 31<sup>st</sup> March 2023** in SIAD premises in Bergamo (Italy),
- from **3<sup>rd</sup> to 6<sup>th</sup> April 2023** in OGE premises in Essen (Germany),

SIL allocation workshop session has been held:

- on **17<sup>th</sup> April 2023** via teleconference.

Attendance lists are reported in **Attachment 1**.

## LNG liquefaction plant

HAZOP and SIL Allocation Report

PROJECT	DATE	PAGE
23123I	April 2023	12 di 14

## 7 HAZOP RESULTS

### 7.1 HAZOP Worksheet

The HAZOP worksheets were shown during the recording with sharing the screen to immediately allow the team to read, comment and, at the end, to agree on the recorded minute.

The HAZOP study was recorded with the software PHA Works. The worksheets registered during the session are enclosed in **Attachment 3**.

These worksheets include:

- Node number, identification, and intention.
- List of the drawings containing the node.
- Parameter / guideword / deviations / consequences / available safeguards.
- Risk ranking.
- Recommendations/actions (when required);
- Recommendation Owner.

### 7.2 HAZOP Recommendations

During HAZOP an overall number of **67 recommendations** has been suggested and agreed by the team.

HAZOP Recommendation list is reported on **Attachment 4**.

Close-out of the HAZOP recommendation is part of a separate activity and therefore is not included in the present report.

## LNG liquefaction plant

HAZOP and SIL Allocation Report

PROJECT	DATE	PAGE
23123I	April 2023	13 di 14

## 8 SIL ALLOCATION RESULTS

### 8.1 SIL Worksheet

Starting from HAZOP results, the SIL analysis allowed the team to define the Safety Criteria and Mitigation of hazards which can lead to a significant safety or environmental consequences.

Scenario with economic consequences have not been included in this SIL Allocation study.

A total number of **46 SIFs** have been identified and analyzed, with following results:

- A number of **17 SIFs not SIL rated**;
- A number of **25 SIFs rated SIL1**;
- A number of **4 SIFs rated SIL2**.

The SIF List and corresponding SIL rating are listed in **Attachment 6**.

The analysis has been recorder in dedicated worksheet specifically defined for the application of SIL Allocation Procedure according to ICARO standards. SIL Worksheets are reported in **Attachment 5**.

In the worksheet for each SIF are indicated:

- SIF identification (initiator, logic solver, final elements);
- Identification of initiating events;
- Scenario description;
- Operators occupancy;
- Probability of avoiding the hazardous situation
- Available IPL;
- Scenario requiring SIF demand rate;
- SIL requirement;
- SIL selected;
- Recommendations if required.

**LNG liquefaction plant**

HAZOP and SIL Allocation Report

 PROJECT  
23123I

 DATE  
April 2023

 PAGE  
14 di 14

## 8.2 SIL Allocation Recommendations

During the SIL analysis an overall number of **10 recommendations** has been suggested and agreed by the team; those recommendation are listed in the following table:

SIF N	SIF	Recommendation Ref.	Recommendation
10	PAHH (interlock to shut down HV-138 in case of back flow due to both P2005A/B not running)	1	Effectiveness of PSV-271 in case of back flow from TW1002 to TW2008 shall be verified considering presence of 2 check valves dissimilar type (reduced required discharge capacity according to reference standard API 521, chapter 4.4.9.3.3). If PSV is adequate, required SIL ca be derated by 1 level ensuring periodical testing on check valves. For this purpose it is suggested to install second dissimilar check valve on dedicated discharge line of each P2005A/B
15	TAHH-466	2	Provide an additional independent temperature transmitter at H4006 outlet with high temperature alarm
18	TAHH-535	3	Provide an additional independent temperature transmitter on NG line upstream EW5000 including high temperature alarm
27	PAHH-1960A	4	Provide an independent function (additional pressure transmitter) to trip P19000 and to close HV-1902A in case of high pressure (set point lower than PAHH-1960A)
28	PALL-1960A	5	Intervention of PALL-1961A shall also close HV-1957A and HV-1958A
29	TALL-914	6	Provide an additional independent temperature transmitter at EW9000 outlet (road tanker BOG line) with low temperature alarm
33	TALL-913	7	Provide an additional independent temperature transmitter at EW9000 outlet (storage tank BOG line) with low temperature alarm
34	TALL-915	8	Provide an additional independent temperature transmitter at EW9000 outlet (NG line) with low temperature alarm
43	PAHH-1640	9	Ensure adequate set point for PAHH-1640 to prevent overpressurization on upstream S2011 (DP=2 barg)
45	TAHH (overheating of WB41/WB42 downstream piping)	10	Investigate availability of other IPL to prevent piping overheating downstream WB41/WB42

Close-out of the SIL recommendation is part of a separate activity and therefore is not included in the present report.

**LNG liquefaction plant**

HAZOP and SIL Allocation Report




PROJECT  
23123I

DATE  
April 2023

PAGE  
1 di 7













**ATTACHMENT 1**

Attendance List




ICARO	HAZOP & SIL STUDY ATTENDANCE LIST		  
	Company:	SIAD / BIOPLUS LNG GmbH	
	Plant Site:	Renzenhof (Germany)	
	Project:	LNG Liquefaction Plant	
ICARO Job:	23123I		

DATE: 27/03/2023

SESSION No. #1













Name:	Company:	Expertise:	Signature:
FABRIZIO BUCU	ICARO	Chairperson	
DEBORA D'OSTILO	ICARO	SCRIBE	
GENARO FORTUSO	SIAD	PH	
Mariano Cumeffi	SIAD MI	INSTRUMENT	
PAOLO ANTONELLI	SIAD MI	PROJECT ENGINEERING	
FEDERICO SOLU	SIAD TI	INSTRUMENT	
CHRISTIAN SCHMITT	OGE	PROCESS	
CHRISTIAN TIEZE	OGE	ENGINEERING	
Christian Ludwiczak	OGE	Project Manager	
Sebastian Henle	TÜV SÜD	Plant Safety	
PIERLUIGI GRITTI	SIAD MI	SENIOR TECH. MGR	
DANIELE SANTUS	TPI	PROCESS ENG.	






ICARO	HAZOP & SIL STUDY ATTENDANCE LIST		  
	Company:	SIAD / BIOPLUS LNG GmbH	
	Plant Site:	Renzenhof (Germany)	
	Project:	LNG Liquefaction Plant	
ICARO Job:	23123I		

DATE: 28/03/2023

SESSION No. #2














Name:	Company:	Expertise:	Signature:
FABRIZIO BUCCI	ICARO	CHAIRPERSON	
DEBORA D'ORTICO	ICARO	SOLUBE	
DANIELE SANTUS	TPI	PROCESS	
PIERLUIGI GRILLI	SIAD MI	TECHN. SENIOR ADV.	
FEDERICO SORU	SIAD MI	INSTRUMENTATION	
MARIANO CUMELLI	SIAD MI	SAFETY ENGINEER	
Christian Ludwiczak	OGE	Project Manager	
Sebastian Höhle	TÜV SÜD	Plant Safety	
Christian Tietze	OGE	Engineering Manager	
CHRISTIAN SCHMITT	OGE	PROCESS	
PAOLO ANTONELLI	SIAD MI	PROJECT ENGIN.	
Klaus Thomas	OGE	Process Control	




ICARO	<b>HAZOP &amp; SIL STUDY ATTENDANCE LIST</b>		  
	Company:	SIAD / BIOPLUS LNG GmbH	
	Plant Site:	Renzenhof (Germany)	
	Project:	LNG Liquefaction Plant	
	ICARO Job:	23123I	

DATE: 29/03/2023

SESSION No.














# 3




Name:	Company:	Expertise:	Signature:
FABRIZIO BUCCI	ICARO	CHAIR PERSON	
NEBORA D'OSTIHO	ICARO	SCRIBE	
CHRISTIAN SCHMITT	OGE	PROCESS	
Christian Tietze	OGE	Eng. Manag-t	
Christian Ludwigzki	OGE	Project Management	
Sebastian Klänke	TÜV SÜD	Plant Safety	
MARIAMO CUMELLI	SIAD MI	Safety Engineer	
GENNARO FORUSANO	SIAD MI	PI	
Klaus Thomas	OGE	Process Control	
PAOLO BUDONELLI	SIAD MI	P.E.	
FEDERICO SOWW	SIAD MI	INSTRUMENTATION	
DANIELE SANTUS	TPI	PROCESS	
PIERLUIGI GRITTI	SIAD MI	TECHN. SENIOR ADVIS.	

ICARO	HAZOP & SIL STUDY ATTENDANCE LIST		  
	Company:	SIAD / BIOPLUS LNG GmbH	
	Plant Site:	Renzenhof (Germany)	
	Project:	LNG Liquefaction Plant	
	ICARO Job:	23123I	

DATE: 30/03/2023

SESSION No. # 9














Name:	Company:	Expertise:	Signature:
FABRIZIO BUCCI	ICARO	Chairperson	
DEROARD OSTICO	ICARO	SCRIBE	
CHRISTIAN SCHMITT	OGE	PROCESS	
Christian Tiller	OGE	Eq. Mgt.	
Christian Ludwiczak	OGE	Project Manager	
Sebastian Künle	TÜV SÜD	Plant Safety	
Mariano Currelli	SIAD MI	Safety Engineer	
GENARO FORUSINO	SIAD MI	PI	
Klaus Thomas	OGE	Process Control	
PAOLO ANTONELLI	SIAD MI	PE	
FEDERICO SOM	SIAD MI	INSTRUMENTATION	
DANIELE SANTUS	TPI	PROCESS	
PIERLUIGI GRITTI	SIAD MI	SENIOR TECH. ADVISOR	




ICARO	HAZOP & SIL STUDY ATTENDANCE LIST		  
	Company:	SIAD / BIOPLUS LNG GmbH	
	Plant Site:	Renzenhof (Germany)	
	Project:	LNG Liquefaction Plant	
	ICARO Job:	23123I	

DATE: 31/03/2023

SESSION No.

# 5












Name:	Company:	Expertise:	Signature:
FABRIZIO BUCCI	ICARO	Chairperson	
DEBORA D'OSTI UO	ICARO	SCRIBE	
CHRISTIAN SENNITT	OGE	PROCESS	
CHRISTIAN TIEBE	OGE	Eng. Mpl.	
Christian Ludwiczak	OGE	Project Manager	
Sebastian Klönke	TÜV SÜD	Plant Safety	
Mariano Cumetti	SIAD MI	Safety Engineer	
GENARO FORZISANO	SIAD FL	PI	
Klaus Thomas	OGE	Process Control	
DAMIRE ARMONDI	SIAD MI	SAFETY ENGINEER AUT. COORDINATOR	
PAOLO ANTONELLI	SIAD MI	PE	
FEDERICO SORU	SIAD FL	INSTAUMENTATION	
PIERLUIGI GRITTI	SIAD MI	SENIOR TECHN. ADVISOR	




ICARO	HAZOP & SIL STUDY ATTENDANCE LIST		  
	Company:	SIAD / BIOPLUS LNG GmbH	
	Plant Site:	Renzenhof (Germany)	
	Project:	LNG Liquefaction Plant	
	ICARO Job:	23123I	

DATE: 31/07/2023

SESSION No.














# 6




Name:	Company:	Expertise:	Signature:
FABRIZIO BUCCI	ICARO	Chairperson	
<del>DEBORA DIOSTI</del> Christian Ludwiczak	ICARO OGE	SCRIBE Project Manager	
Sebastian Henle	TEU SUD	Plant Safety	
Klaus Thomas	OGE	Process Control	
CHRISTIAN SCHMITT	OGE	PROCESS	
GENNARO FERRISANO	SIAD TU	PC	
DAMIELE ARIMONDI	SIAD MI	FUNC. SAFETY ENGINEER AUT. COORDINATOR	
PAOLO ANTONELLI	SIAD MI	PE	
Mariano Cume A.	SIAD MI	FS / Instrument Engineer	
FEDERICO SOEN	SIAD TU	INSTRUMENTATION	
Christian Tietze	OGE	Eng. M.A.	

ICARO	<b>HAZOP &amp; SIL STUDY ATTENDANCE LIST</b>		  
	Company:	SIAD / BIOPLUS LNG GmbH	
	Plant Site:	Renzenhof (Germany)	
	Project:	LNG Liquefaction Plant	
	ICARO Job:	23123I	

DATE: 4/04/2023














SESSION No. # 7





Name:	Company:	Expertise:	Signature:
FABRIZIO BUCG	ICARO	Chairperson	
Christian Ludwig	OGE	Project Manager	
Christian Tietze	OGE	Eng. Day	
Christian Hopp	OGE	From Conica Operations Area	
Klaus Thomas	OGE	Process Control	
CHRISTIAN SCHWITT	OGE	PROCESS	
Sebastian Klauke	TÜV SÜD	Plant Safety	
GENNARO FORMISANO	SIAD MI	FS ENGINEER (TUV)	
ARMONDI DANIELE	SIAD MI	AUTOMATION COORD.	
PAOLO ANTONELLI	SIAD MI	PE	
FEDERICO SONN	INSTRUMENTATION	SIAD MI	
Mariano Come Mi	SIAD MI	FS Engineer Instrument	
DEBORA DI OSTI O	ICARO	SCRIBE	

ICARO	HAZOP & SIL STUDY ATTENDANCE LIST		  
	Company:	SIAD / BIOPLUS LNG GmbH	
	Plant Site:	Renzenhof (Germany)	
	Project:	LNG Liquefaction Plant	
	ICARO Job:	23123I	

DATE: 5/04/2023

SESSION No. #8

Name:	Company:	Expertise:	Signature:
FABRIZIO BUCCI	ICARO	CHAIRPERSON	
DEBORA DOSTILIO	ICARO	SCRIBE	
Christian Tietze	OGE	Eng. Mgt.	
Christoph Hopp	OGE	Process Area	
Klaus Thomas	OGE	Process Control	
CHRISTIAN SCHMITT	OGE	PROCESS	
Sebastian Klöck	TÜV SÜD	Plant Safety	
GENARO FORNARO	SIAD MI	PE	
DANIÈLE ARMONDI	SIAD MI	PS ENGINEER AUT. COORDINATOR	
PAOLO ANTONELLI	SIAD MI	PE	
FEDERICO SOMI	SIAD MI	INSTRUMENT	
Mariano Cumeff	SIAD MI	FS Engineer Instrument	
Christian Ludovicz	OGE	Project Manager	

	<b>HAZOP &amp; SIL STUDY ATTENDANCE LIST</b>		  
	<b>Company:</b>	SIAD / BIOPLUS LNG GmbH	
	<b>Plant Site:</b>	Renzenhof (Germany)	
	<b>Project:</b>	LNG Liquefaction Plant	
	<b>ICARO Job:</b>	23123I	

**DATE:** 17/04/2023

**SESSION No.** #9

Name:	Company:	Expertise:	Signature:
<b>FABRIZIO BUCCI</b>	ICARO	Chairperson	Via teleconference
<b>DEBORA D'OSTILIO</b>	ICARO	Scribe	Via teleconference
<b>GENNARO FORMISANO</b>	SIAD MI	PM	Via teleconference
<b>PAOLO ANTONELLI</b>	SIAD MI	PE	Via teleconference
<b>FEDERICO SORU</b>	SIAD MI	Instrument	Via teleconference
<b>MARIANO CUMETTI</b>	SIAD MI	FS engineer instrument	Via teleconference
<b>DANIELE ARIMONDI</b>	SIAD MI	FS engineer aut. coordinator	Via teleconference
<b>DANIELE SANTUS</b>	TPI	Process	Via teleconference
<b>KLAUS THOMAS</b>	OGE	Process Control	Via teleconference
<b>CHRISTIAN LUDWICZAK</b>	OGE	PM	Via teleconference
<b>CHRISTIAN SCHMITT</b>	OGE	Process	Via teleconference
<b>CHRISTIAN TIETZE</b>	OGE	Eng Manager	Via teleconference
<b>SEBASTIAN HOENLE</b>	TÜV SÜD	Plant safety	Via teleconference



**LNG liquefaction plant**


HAZOP and SIL Allocation Report

PROJECT  
23123I

DATE  
April 2023

PAGE  
2 di 7

**ATTACHMENT 2**  
Master Copy P&IDs



**Liefergrenzen:**  
 1 - vorhanden  
 8 - Rohrleitungstechnik (inkl. Schnittstelle Anbohrung)  
 12 - Leittechnik


DP-23042		Neubau Bio LNG Renzenhof	
Projektname OGE		Maßnahmenbezeichnung OGE	
02	23.03.2023	Allgemeine Überarbeitung	AS200
03	19.12.2022	Allgemeine Überarbeitung	MM119
04	29.09.2022	Überarbeitung zur Erstellung Leseblatt	MM119
05	15.02.2022	Projekt-Neulage	MM119
06	28.10.2019	PA 1007 Rückbau V0 Renzenhof	15105
07	11.12.2011	PA 1011 Umbau Renzenhof AS200	MM119
08	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119
09	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119
10	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119
11	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119
12	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119
13	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119
14	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119
15	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119
16	08.07.2011	PA 1011 Umbau Renzenhof AS200	MM119


Projekt Nr.		Renzenhof	
Datum	Name	Zeichnung	
02.02.2023	MM119	R+1 Schema Stationspiping	
02.02.2023	MM119	R+1 Schema Stationspiping	

Blatt	Blatt	Blatt	Blatt	Blatt	Blatt	Blatt	Blatt
520	REZH	700	001	000	SRI	001	01-01-00



The gas pressure regulator has a set pressure of 43 bar. The setting pressure is adjusted via the pressure connection HOB B40622. If there is a pressure increase in the area behind the gas pressure regulator (e.g. gas pressure regulator leaking), the SBV is triggered at approx. 45.4 bar. Furthermore, two SSVs are installed per control line to limit a pressure increase in the GDRM system in the event of a fault.



**Node #01A**

DP 85  
DT 80  
MOPu 67.5; MOPd 43  
MOT 60  
Metering an Regulating: DT -10°C - +60°C

LEGEND:  
 FT = FLOW TRANSMITTER  
 HOB = BALL VALVE  
 HON = NEEDLE VALVE  
 MCV = ELECTRICAL CONTROL VALVE  
 PI = PRESSURE INDICATOR MECHANICAL  
 PDI = DIFFERENTIAL PRESSURE TRANSMITTER  
 PDI-T = PRESSURE TRANSMITTER MECHANICAL  
 SSV = SAFETY SHUT-OFF VALVE  
 SRV = SAFETY CHECK VALVE  
 U = GAS METER  
 W = HEAT EXCHANGER

- 1 vorhanden
- 2 Lieferant Filter
- 3 Lieferant Vorwärmer
- 4 GDRM-Technik Messanlage
- 5 Lieferant Maschinen-/Verdichtereinheit
- 6 Lieferant Kühler
- 7 Lieferant Ausbläser
- 8 Rohrlauftechnik
- 9 Lieferant Druckluftanlage
- 10 Lieferant Fackelanlage
- 11 Lieferant Kondensatbehälter
- 12 Leittechnik
- 13 Energietechnik (TPEE)
- 14 Qualitätsmessung
- 15 TGA
- 16 Anlagenbau
- 17 GDRM-Technik Eigensgasversorgungsanlage
- 18 GDRM-Technik Kompaktanlage
- 19 Fernleitungsbau
- 20 Demontage
- 21 Lieferant HSS-Anlage (> 110 KV)
- 22 Lieferant Löschwassertank
- 23 Lieferant HS-Anlage (<= 36KV)
- 24 Lieferant Kesselanlage
- 25 Lieferant Frischwasserversorgung
- 26 Lieferant Löschwassertank
- 27 Lieferant Löschwassererfing
- 28 Lieferant Kesselanlage
- 29 Lieferant Nachrichtentechnik
- 30 Lieferant Sicherheitstechnik
- 98 Betriebliche Maßnahme
- 99 Demontage

IE	19.01.2023	Anpassung an aktuellen Planungsstand	K02341	---	---	---	---
UD	09.10.2022	Allgemeine Überarbeitung	M08110	AB0888	---	---	---
IC	25.11.2022	Isoliertechnik ergänzt	M08110	AB0888	---	---	---
IB	29.08.2022	Überarbeitung zur Erstellung Lieferant	M08110	000063	---	---	---
IA	15.03.2022	Erstellung	M08110	000063	---	---	---
Rev	Datum	Bezeichnung	erstellt	geprüft	freigegeben	Datum	freigegeben
Rev							


Projekt: 16		Standort	
Datum	Name	Zeichnungsnummer	
23.01.2023	K02341	Rohrleitungs- und Instrumentenfließschema Bio LNG-Anlage - GDRM-Anlage	
Scale	Proj.		
Schub	Verf.	Matr.	
802	10716		
Modifiziert			
F. Fach		Standort	
520	REZH	433	004 000 SRI 001 01-0E
Etw.:			

**VALVE LEGEND:**

- BALL VALVE
  - NEEDLE VALVE
  - CHECK VALVE
  - GLOBE VALVE
  - BUTTERFLY VALVE
  - SPECTACLE BLIND
  - Y STRAINER
  - PNEUMATIC BALL VALVE (SE)
  - PNEUMATIC BALL VALVE (ESD)
  - PNEUMATIC BALL VALVE (DE)
  - SAFETY VALVE
  - SOLENOID VALVE
  - PRESSURE REGULATOR
  - PNEUMATIC GLOBE VALVE
  - PNEUMATIC GLOBE VALVE WITH SOLENOID BLOCK VALVE
  - STEAM TRAP
  - SIGHT GLASS
  - PLUG
- FC = FAIL CLOSED  
FO = FAIL OPEN  
FL = FAIL LOCK  
LC= LOCKED CLOSE  
LO= LOCKED OPEN

**INSTRUMENT LEGEND:**

- PRESSURE GAUGE
- THERMOMETER
- FLOWMETER
- FLOW TRANSMITTER ANALOGIC 4-20 mA
- MOTOR
- VARIABLE FREQUENCY DRIVER
- PRESSURE TRANSMITTER ANALOGIC 4-20 mA (PIC= CONTROLLER)
- TEMPERATURE TRANSMITTER ANALOGIC 4-20 mA (TIC= CONTROLLER)
- LEVEL TRANSMITTER ANALOGIC 4-20 mA (LIC= CONTROLLER)
- FLOW TRANSMITTER ANALOGIC 4-20 mA (FIC= CONTROLLER)
- DIFFERENTIAL PRESSURE TRANSMITTER ANALOGIC 4-20 mA
- PRESSURE SWITCH (HIGH)
- FLOW SWITCH (LOW)
- LEVEL SWITCH (LOW/HIGH)
- LEVEL SWITCH (LOW LOW/HIGH HIGH)
- LIMIT SWITCH
- OPERATOR ACCESSIBLE WITH SAFETY FUNCTION
- OPERATOR ACCESSIBLE WITH CONTROL FUNCTION



- FLUID LIST:**  
 NG= NATURAL GAS  
 N= NITROGEN  
 Rg= RICH AMINE  
 Lo= LEAN AMINE  
 K= CO2  
 CW= COOLING WATER  
 BW= DEMI WATER  
 LS= STEAM  
 LC= CONDENSATE STEAM  
 HC= LIQUID HYDROCARBONS  
 A= INSTRUMENT AIR  
 CD= CONDENSATE  
 AF= ANTIFOAM
- INSULATION:**  
 F= COLD INSULATION  
 I= HOT INSULATION  
 PERSONNEL PROTECTION  
 HEAT TRACING  
 N= NOT PAINTED/ NOT INSULATED  
 V= PAINTED


- CONCENTRIC REDUCER
- ECCENTRIC REDUCER
- PIPING SLOPE
- ELECTRICAL HEAT TRACING
- HEAT CONSERVATION / PERSONNEL PROTECTION
- COLD CONSERVATION

06									
05									
04									
03									
02									
01									
Rv. Nr.	Datum	Beschreibung	erstellt	geprüft	freigegeben	Datum	freigegeben		
Projekt - Nr.			Standort / Projektname						
DG-001115			LNG LIQUEFACTION PLANT						
Datum			Zeichnungsbenennung						
13/03/2023			NG TREATMENT UNIT - PIPING AND INSTRUMENTATION DIAGRAM						
Name			NG BEHANDLUNGSEINHEIT - ROHRLÄUFTUNGEN UND INSTRUMENTIERUNGS DIAGRAMM						
FR									
CA									
DS									
OS									
Schutzzeichen			F-Tech						
ISO 16016 beachten			Standardkurzname						
A1			A-Art						
OGE			A-Teil						
			D-Art						
			Lfd.-Nr.						
			Blatt						
			And						
Urspr.: 2220698-0C-10-001 / EST105704			Ers.f.:						
			Ers.d.:						

---	---
---	---
Projektnummer OGE	Maßnahmenbezeichnung OGE

# CO2 ABSORPTION UNIT AU1000

- PUÒÒÀÈÙ
- PUÒÒÀÈÈ
- PUÒÒÀÈ
- PUÒÒÀÈ




- NOTE 1: CONNECTED TO COLD FLARE HEADER  
 NOTE 2: GENERAL P&ID, DOCUMENT SIAD M.I. N° 120784  
 NOTE 3: PSV CONNECTED TO BLOWDOWN MDEA HEADER  
 NOTE 4: ON/OFF VALVE WITH ADJUSTABLE OPENING  
 NOTE 5: FLASH VESSEL S1003 ELECTRICALLY TRACED  
 NOTE 6: ABSORPTION TOWER TW1002 ELECTRICALLY TRACED TO LIQUID LEVEL AT PLANT STOP  
 NOTE 7: P&ID N° 120784  
 NOTE 8: MINIMUM DISTANCE FROM HV164 TO R0169 MUST BE 600mm

1.1	RAW NATURAL GAS INLET	4" 600#
1.3	NATURAL GAS TO DRYER	4" 600#
1.4	LEAN AMINE INLET	2" 600#
1.6	AMINE FLASH	1/2" 150#
1.7	TO AMINE BLOWDOWN VESSEL	1" 150#
1.10	RICH AMINE FROM FLASH VESSEL	2" 150#
1.11	AMINE DISCHARGE	1" 600#
1.12	CONDENSATE FROM PRECOOLER	1/2" 150#
1.13	LIQUID HYDROCARBON DISCHARGE	3/4" 150#
1.14	AMINE DISCHARGE	1" 150#
1.17	INSTRUMENT AIR	3/4" 150#
1.18	NITROGEN INLET	1-1/2" 150#
1.19	TO COLD FLARE	3" 150#
1.20	TO HOT FLARE	1/2" 150#

CLIENTE	BIOPLUS LNG	OC	REVISIONE - Revision	13/03/2023	FR	CA	DS
STABILIMENTO	RENZENHOF (GERMANY)	DB	REVISIONE - Revision	22/02/2023	FR	CA	DS
OGGETTO	NATURAL GAS TREATMENT CO2 REMOVAL AND DRYING CO2 ABSORPTION UNIT	OA	PRIMA EMISSIONE - First Issue	18/01/2023	FR	CA	DS
COMMESSA	G22C20698	REV. rev.	DESCRIZIONE description	DATA date	ESEC. prep'd	CONTR. chk'd	APPR. app'r'd
DATE date	18/01/2023	SCALE scale	FR	MASSA (Kg)	FO. sh. 2	FORMAT size	
ESEC. prep'd	FR	DISIGNO N°		2220698-0C-10-001			

SIAD M.I. T.P.I.  
LIMIT OF SUPPLY

# AMINE STRIPPING UNIT – SU2000




- ΡΥΘΩΜΕΙ
- ΡΥΘΩΜΕΙ
- ΡΥΘΩΜΕΙ
- ΡΥΘΩΜΕΙ

NOTE 2: GENERAL P&ID, DOCUMENT SIAD M.I. N° 120784  
 NOTE 4: PSV CONNECTED TO MDEA BLOWDOWN TANK  
 NOTE 5: CARBON GUARD BED ELECTRICALLY TRACED  
 NOTE 6: STRIPPING TOWER TW2008 ELECTRICALLY TRACED TO LIQUID LEVEL AT PLANT STOP  
 NOTE 7: CONDENSATE SEPARATOR S2011 ELECTRICALLY TRACED  
 NOTE 8: WEEP HOLE AT LOWEST POINT DOWNSTREAM OF PSV271  
 NOTE 9: BELT DRUM HEATER

2.1	LEAN AMINE	2" 600#	2.6	INSTRUMENT AIR	1/2" 150#	2.12	COOLING WATER OUTLET	4" 150#
2.2	TO COMBUSTOR	2" 150#	2.7	LP STEAM	3" 150#	2.13	COOLING WATER INLET	4" 150#
2.3	RICH AMINE FROM FLASH	2" 150#	2.8	LP STEAM CONDENSATE	2" 150#	2.14	NITROGEN INLET	1/2" 150#
2.4	CONDENSATE FROM C5500	1/2" 150#	2.10	DEMI WATER INLET	1/2" 150#	2.15	CONDENSATE FROM ST9000	1/2" 150#
2.5	MDEA LOADING	1" 150#	2.11	TO MDEA BLOWDOWN TANK	1" 150#	2.16	TO MDEA BLOWDOWN TANK	1" 150#


CLIENTE	BIOPLUS LNG	DC	REVISIONE - Revision	13/03/2023	FR	CA	DS
STABILIMENTO	RENZENHOF (GERMANY)	DB	REVISIONE - Revision	22/02/2023	FR	CA	DS
OGGETTO	NATURAL GAS TREATMENT CO2 REMOVAL AND DRYING AMINE STRIPPING UNIT	OA	PRIMA EMISSIONE - First Issue	18/01/2023	FR	CA	DS
COMMESSA	G22C20698	REV. rev.	DESCRIZIONE description	DATA date	ESGC. prep. d	CONTR. ckn	APPR. appr. d
DATE date	18/01/2023	SCALE scale	FR	MASSA (Kg)	Di	di	di
FORMAT	A1	FOG. sh.	3	REVISIONE	OC		
TECNO PROJECT INDUSTRIALE			2220698-OC-10-001				

— PUÖÖÄÄ  
 - - - - - PUÖÖÄÄ



3.2	MDEA PLANT LOADING	1" 150#
3.3	AMINE DISCHARGE	1" 150#
3.4	AMINE TO TRUCK	1" 150#
3.5	FROM MDEA PSV HEADER	1-1/2" 150#

NOTE 1: GENERAL P&ID, DOCUMENT SIAD M.I. N° I20784  
 NOTE 4: MDEA BLOWDOWN TANK V3004 ELECTRICALLY TRACED




CLIENTE	BIOPLUS LNG	DC	REVISIONE - Revision	13/03/2023	FR	CA	DS
STABILIMENTO	RENZENHOF (GERMANY)	DB	REVISIONE - Revision	22/02/2023	FR	CA	DS
OGGETTO	NATURAL GAS TREATMENT CO2 REMOVAL AND DRYING SOLVENT ADDITION AND REMOVAL UNIT	REV. rev.	PRIMA EMISSIONE - First Issue	18/01/2023	FR	CA	DS
COMMESSA	G22C20698	DATE	18/01/2023	SCALA	FR	MASSA (Kg)	Di 5
TECNO PROJECT INDUSTRIALE	PLANTS AND TECHNOLOGY FOR THE INDUSTRIAL GASES	CURNO - BERGAMO - ITALY					
A TERMINI DI LEGGE SI PRESERVA LA PROPRIETA' DEL PRESENTE DISEGNO METANOLOGIA LA RIPRODUZIONE E LA COMUNICAZIONE A TERZI				2220698-0C-10-001			

- 4.1 WET NATURAL GAS INLET 4" 600#
- 4.2 CHILLED WATER OUTLET 3" 150#
- 4.3 CHILLED WATER INLET 3" 150#
- 4.4 CONDENSATE OUTLET 1/2" 150#
- 4.5 REGENERATION GAS 3" 600#
- 4.6 DEPRESSURIZATION GAS 1" 600#
- 4.7 NITROGEN INLET 1/2" 150#
- 4.8 TO COLD FLARE 3" 150#
- 4.9 NATURAL GAS TO LIQUEFACTION 4" 600#
- 4.10 DRAIN 1/2" 150#
- 4.11 INSTRUMENT AIR 1" 150#
- 4.12 TO HOT FLARE 1/2" 150#

### NATURAL GAS PRECOOLING AND DRYING UNIT DU4000

- PUÖÖÄE
- PUÖÖÄE
- PUÖÖÄE



- NOTE 1: PSV CONNECTED TO COLD FLARE HEADER
- NOTE 2: GENERAL P&ID, DOCUMENT SIAD M.I. N° 120784
- NOTE 3: SLOW-CLOSING VALVES KV401, KV424, KV446, KV447, KV430, KV448, KV432, KV431, KV498, KV497, KV496, KV495, KV494, KV493
- NOTE 4: VALVES HV455, HV464 CONNECTED TO COLD FLARE HEADER
- NOTE 5: VALVES V458, V467 CONNECTED TO HOT FLARE HEADER
- NOTE 6: PRESSURE GAUGE PI489 INSTALLED CLOSE TO V467
- NOTE 7: PRESSURE GAUGE PI493 INSTALLED CLOSE TO V458

CLIENTE	BIOPLUS LNG	DC	REVISIONE - Revision	13/03/2023	FR	CA	DS
STABILIMENTO	RENZINHOF (GERMANY)	DB	REVISIONE - Revision	22/02/2023	FR	CA	DS
OGGETTO	NATURAL GAS TREATMENT CO2 REMOVAL AND DRYING NATURAL GAS PRECOOLING AND DRYING UNIT	OA	PRIMA EMISSIONE - First Issue	18/01/2023	FR	CA	DS
COMMESSA	G22C20698	REV. rev.	DESCRIZIONE	DATA date	ESEC.	prep. di	CONTR. chkd
DATE date	18/01/2023	SCALE	scale	FR	MASSA (Kg)	Di	5
DESCRIZIONE	TECNO PROJECT INDUSTRIALE PLANTS AND TECHNOLOGY FOR THE INDUSTRIAL GASES CURNO - BERGAMO - ITALY	ESEC.	prep. di	FR	MASSA (Kg)	Di	5
DESCRIZIONE	TECNO PROJECT INDUSTRIALE PLANTS AND TECHNOLOGY FOR THE INDUSTRIAL GASES CURNO - BERGAMO - ITALY	REV.	REV.	FR	MASSA (Kg)	Di	5
A TERMINI DI LEGGE SI PREZIOVA LA PROPRIETA' DEL PRESENTE DISEGNO VETTORIALE IN REVISIONE E LA COMUNICAZIONE A TITOLO DI PROVA. IL PRESENTE DISEGNO E' LA PROPRIETA' DI TECNO PROJECT - ING. COPPINI ANDRE' COMMUNICATO IN TUTTI I PANNELLI. E' PROIBITO PER LA							
2220698-0C-10-001							

SIAD M.I. T.P.I.

LIMIT OF SUPPLY



# PIPING AND INSTRUMENTATION DIAGRAM

**PROJECT N° : L43374**  
**N° COMMESSA :**

**PLANT TYPE : LNG LIQUEFACTION PLANT**  
**TIPO IMPIANTO : IMPIANTO LIQUEFAZIONE LNG**




**LOCATION : RENZENHOF (Germany)**  
**LOCALITA' : RENZENHOF (Germania)**

**CUSTOMER : BIOPLUS LNG GmbH**  
**CLIENTE :**

SHEET	DESCRIPTION
1A	Cover sheet
2A	Instrument and valve legend
3A	Symbols sheet
4A	Revisions
10	Natural gas inlet
11	NG reduction station for steam boiler
15	Natural gas treatment and dryer
16	Steam condensation and condensate subcooling
20	Liquefier cold box LNG
22	Liquefier cold box LNG
23	Liquefier cold box LNG
25	Nitrogen recycle compressor
26	Nitrogen booster
27	Nitrogen turbine
30	LNG storage
31	LNG storage
32	LNG truck loading pump
33	LNG truck loading pump
34	Truck loading bay
35	Truck loading bay
36	NG regeneration cooler
37	NG regeneration heater
37A	NG regeneration compressor
37B	NG regeneration compressor
38	HC heater
38A	BOG compressor
38B	BOG compressor

SHEET	DESCRIPTION
39A	Cold flare
39B	Hot flare
40	Liquid nitrogen storage
41	Liquid nitrogen storage
42	Nitrogen distribution system
43	Instrument air distribution system
50	Steam boiler
51	Chiller
60	Instrument air package
65	Cooling water system
66	Cooling water system
67	Cooling water system
68	Demi water package
70	Thermal oxidizer
74	Analysis pumps
75	Analysis room
80	Motors control typical
81	Heaters control typical
82	ESD valves typical

This document is property of SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 A termine di legge ogni diritto è riservato.

Projekt - Nr. <b>DG-001115</b>		Standort / Projektname <b>LNG LIQUEFACTION PLANT</b>																																	
																																			
<table border="1" style="font-size: small;"> <tr><th>Datum</th><th>Name</th></tr> <tr><td>13.03.2023</td><td>CAGLIONI</td></tr> <tr><td>13.03.2023</td><td>SORU</td></tr> <tr><td>13.03.2023</td><td>ANTONELLI</td></tr> </table>		Datum	Name	13.03.2023	CAGLIONI	13.03.2023	SORU	13.03.2023	ANTONELLI	<table border="1" style="font-size: small;"> <tr><th colspan="8">Zeichnungsbenennung</th></tr> <tr><td colspan="8"><b>PIPING AND INSTRUMENTATION DIAGRAM</b></td></tr> <tr><td colspan="8"><b>ROHRLEITUNGEN UND INSTRUMENTIERUNGSDIAGRAMM</b></td></tr> </table>		Zeichnungsbenennung								<b>PIPING AND INSTRUMENTATION DIAGRAM</b>								<b>ROHRLEITUNGEN UND INSTRUMENTIERUNGSDIAGRAMM</b>							
Datum	Name																																		
13.03.2023	CAGLIONI																																		
13.03.2023	SORU																																		
13.03.2023	ANTONELLI																																		
Zeichnungsbenennung																																			
<b>PIPING AND INSTRUMENTATION DIAGRAM</b>																																			
<b>ROHRLEITUNGEN UND INSTRUMENTIERUNGSDIAGRAMM</b>																																			
Schutz- vermerk ISO 16016 beachten	Blattgr. -	Maßst. 1/ -																																	
Urspr.: I20784 Rev.0C		Ers.f.: Ers.d.:																																	
520	REZH	700	001 000 SRI 002 01+ 0C																																

### VALVE LEGEND CODE

FIRST LETTER / FUNCTION		TAG NUMBER	LAST LETTERS / FLUID
MANUAL VALVE	AUTOMATIC VALVE	MANUAL OR AUTOMATIC VALVE	MANUAL VALVE
A B BYPASS C CONTROL	SEE INSTRUMENT LEGEND CODE IDENTIFICATIONS LETTERS	SEE INSTRUMENT LEGEND CODE AREA IDENTIFICATION NUMBERS	SEE FLUID LEGEND CODE
D DRAINS			
E			
F			
G			
H HIGH PRESSURE DIFFERENTIAL TAP			
I			
J SIGHT GLASS			
K FILTER			
L LOW PRESSURE DIFFERENTIAL TAP			
M			
N			
O			
P PRESSURE TAP			
Q			
R			
S SAMPLE			
T THAW			
U			
V VENT			
W			
X SHUTOFF			
Y CHECK VALVE			
Z			

### INSTRUMENT LEGEND CODE

IDENTIFICATIONS LETTERS				
FIRST LETTER / FUNCTION		SUCCEEDING LETTERS		
MEASURED VARIABLE	MODIFIER	PASSIVE FUNCTION	OUTPUT FUNCTION	MODIFIER
A ANALYSIS		ALARM		
B FLAME DETECTOR				
C CONDUCTIVITY			CONTROL	
D DENSITY	DIFFERENTIAL			
E VOLTAGE (E.F.M.)		PRIMARY ELEMENT		
F FLOW RATE	RATIO			
G GAUGING		GLASS		
H HAND CONTROL				HIGH
I CURRENT (ELECTR.)		INDICATE		
J POWER	SCAN			
K TIME			CONTROL STATION	
L LEVEL		LIGHT		LOW
M MOISTURE				MIDDLE OR INTERM.
N PNEUMATIC		PNEUMATIC	PNEUMATIC	PNEUMATIC
O		ORIFICE		
P PRESSURE OR VACUUM		POINT		
Q QUANTITY OR EVENT	INTEGR. OR TOTALIZE			
R RADIOACTIVITY		RECORD		
S SPEED OR FREQUENCY	SAFETY		SWITCH	
T TEMPERATURE			TRANSMITTER	
U MULTIVARIABLE		MULTIFUNCTION	MULTIFUNCTION	MULTIFUNCTION
V VIBRATION			VALVE	
W WEIGHT OR FORCE		WELL		
X UNCLASSIFIED	AXIS X	UNCLASSIFIED	UNCLASSIFIED	UNCLASSIFIED
Y UNCLASSIFIED	AXIS Y		RELAY OR COMPUTE	
Z POSITION	AXIS Z		UNCLASSIFIED FINAL CONTROL ELEMENT	

### FLUID LEGEND CODE

ITEM	FLUID	ITEM	FLUID	ITEM	FLUID	ITEM	FLUID
GO	GAS OIL	HW	HOT WATER	CO	CARBON OXIDE	RL	LIQUID ARGON
DO	DIATERMIC OIL	SW	SALT WATER	K	CARBON DIOXIDE	HPN	HIGH PRESSURE NITROGEN
LO	LUBE OIL	TW	TREATED WATER	NO	NITROGEN OXIDE	HPO	HIGH PRESSURE OXYGEN
	<b>AIR AND GAS GENERAL USE</b>	UW	UTILITIES WATER	FF	FIRE FOAM	HPR	HIGH PRESSURE ARGON
G	GAS (GENERAL)	BW	BOILER FEED WATER / DEMI	FL	FOAMING LIQUID	LA	LIQUID AIR
IG	INSTRUMENT GAS	IW	SERVICE WATER	CH	CHEMICAL	KL	KETTLE
NG	NATURAL GAS / METHANE / BIOMETHANE		<b>CONDENSATE AND STEAM</b>	GY	GLYCOL	E	HELIUM
PG	PURGE GAS	S	STEAM (GENERAL)	BO	BLOW DOWN	X	OXYGEN
FG	FUEL GAS	KS	HIGH PRESSURE STEAM	SG	SLUDGES	LOX	LIQUID OXYGEN
GF	FLUORURATE GAS	WS	MEAN PRESSURE STEAM	DR	DRAINS	GOX	GAS OXYGEN
TG	THAW GAS	LS	LOW PRESSURE STEAM	V	ATMOSPHERE DISCHARGED	KG	ENRICHED GAS
RG	REGENERATION GAS	KC	HIGH PR. STEAM COND.	P	PROPANE/PROPYLENE	CL	CRYOGENIC LIQUID
GR	REFRIGERATING GAS	WC	MEAN PR. STEAM COND.	GV	GASES MIXTURE	LNG	NATURAL GAS / METHANE / BIOMETHANE LIQUID
LR	REFRIGERATING LIQUID	LC	LOW PR. STEAM COND.	HC	HYDROCARBONS	NGL	NGL NATURAL GAS LIQUID
A	AIR (GENERAL)	CD	CONDENSATE DISCHARGE	Ra	AMINE RICH		<b>BIOGAS</b>
CA	COMPRESSED AIR		<b>PROCESS GAS AND LIQUID</b>	La	AMINE POOR	BGLP	BIOGAS LOW PRESSURE < 0.5 bar
UA	UTILITIES AIR			LN	LIQUID NITROGEN	BGHP	BIOGAS HIGH PRESSURE
	<b>WATER</b>	D	ACETYLENE	WLIN	LIQUID NITROGEN IMPURE		
W	WATER (GENERAL)	NH3	AMMONIA	N	NITROGEN		
CW	COOLING WATER	Q	ETHYLENE	WN	WASTE NITROGEN		
DW	DRINKING WATER	H	HYDROGEN	R	ARGON		
FW	FIRE FIGHTING WATER			RR	WASTE ARGON		
				RP	PURE ARGON		

### AREA IDENTIFICATION NUMBERS

	NUMBER	AREA
<b>FISCAL METER</b>	-	FISCAL METER
<b>433</b>		
<b>GAS TREATMENT</b>	100 - 199	AVAILABLE FOR GAS TREATMENT
	200 - 299	AVAILABLE FOR GAS TREATMENT
	300 - 399	AVAILABLE FOR GAS TREATMENT
	400 - 499	AVAILABLE FOR GAS TREATMENT
	500 - 599	NG REGENERATION HEATER + REGENERATION COMPRESSOR
<b>LIQUEFACTION</b>	600 - 699	NATURAL GAS INLET
	700 - 739	COLD BOX LNG
	740 - 749	RECYCLE COMPRESSOR
	750 - 759	WARM TURBINE
	760 - 769	COLD TURBINE
<b>UTILITIES</b>	770 - 799	AIR DISTRIBUTION SYSTEM
	800 - 899	WATER AND DEMI WATER CIRCUIT
	900 - 999	HC HEATER + BOG COMPRESSOR
	1000 - 1099	ANALYZERS
	1100 - 1299	CHILLED WATER CIRCUIT
	1300 - 1499	AVAILABLE
	1500 - 1599	STEAM SYSTEM
<b>VENT</b>	1600 - 1699	COLD FLARE AND THERMAL OXIDIZER
	1700 - 1799	LIQUID NITROGEN STORAGE, NITROGEN DISTRIBUTION SYSTEM
	1800 - 1899	AVAILABLE
<b>STORAGE</b>	1900 - 1999	LNG STORAGE AND TRUCK <u>LOADING</u>
	2000 - 2299	AVAILABLE

All rights are reserved according to law.   
 Tutti i diritti sono riservati secondo la legge.   
 This document is property of SIAD MACCHINE IMPIANTI.   
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0B
CUSTOMER : BIOPLUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale A3	Format A3
Drawing number I20784		Sheet 2A	



### PROCESS LINES

- MAJOR PROCESS LINES
- SECONDARY PROCESS LINES
- AUXILIARY LINES
- EXISTING LINE
- INSULATED PIPING
- VIP - VACUUM INSULATED PIPING
- TRACED AND INSULATED PIPING
- PROCESS FLOW DIRECTION
- PROCESS LINE REDUCER
- TRANSITION JOINT
- EXPANSION JOINT
- PROCESS LINE FLANGE
- LINE CHANGE INDICATION

### PRIMARY ELEMENTS

- FE
- ORIFICE PLATE
- FE
- FLOW TUBE
- FE
- CORIOLIS
- FE
- VORTEX
- TE
- THERMOCOUPLE
- TE
- RESISTANCE BULB
- THERMOWELL
- INSTRUMENT TAP

### BODY SYMBOLS

- UNDEFINED
- GATE
- CHECK
- GLOBE
- BELLOWS SEALED
- SEGMENT BALL
- BUTTERFLY
- BALL / PLUG
- ANGLE
- THREE-WAY
- NEEDLE VALVE
- 2 VALVES MANIFOLD
- 3 VALVES MANIFOLD
- 5 VALVES MANIFOLD

### AUTOMATIC VALVE ACTUATORS

- DIAPHRAGM
- DIAPHRAGM WITH POSITIONER
- DOUBLE ACTING PISTON
- ACTING PISTON SPRING RETURN

### AUTOMATIC VALVE ACTIONS

- FO : FAIL OPEN
- FC : FAIL CLOSED

### AUTOMATIC VALVE SUPPLY

- S1 → UNREGULATED
- S2 → REGULATED

### BURSTING DISC

- PRESSURE
- EMPTY

### MISCELLANEOUS SYMBOLS

- DRAIN
- THAW GAS
- CONDENSATE TRAP
- THAW MANIFOLD
- DM
- LIQUID DRAIN MANIFOLD
- FG
- SIGHT FLOW INDICATION
- TRUCK FILL HOSE
- BOUNDARY / LOCATION LINE
- MECHANICAL LINK
- QUICK DISCONNECT
- R
- REGULATOR
- F
- FILTER
- FR
- FILTER REGULATOR
- S
- SNUBBER
- Y FILTER
- Y FILTER
- SPECTACLE FLANGE
- CWR
- COOLING WATER RETURN
- CWS
- COOLING WATER SOURCE

### INSTRUMENT TYPE & LOCATION

- LOCALLY MOUNTED
- FRONT PANEL MOUNTED
- REAR PANEL MOUNTED
- SECONDARY FUNCTION
- OPERATOR INTERFACE WITH CONTROL FUNCTION
- OPERATOR INTERFACE WITH SAFETY FUNCTION
- INTERNAL LOGIC FUNCTION
- OPERATOR INTERFACE DCS

### FIELD EQUIPMENT SPEC. DRAWINGS

CUSTOMER: SIAD M.I.

LIMIT OF SUPPLY

SUBORDINATE SUPPLIER: SIAD M.I.

LIMIT OF SUPPLY

### EQUIPMENT

- VENT SILENCER
- EXPANDER WITH NOZZLES
- DB PLATE
- BOOSTER
- SCREEN PROCESS LINE
- INTERCOOLER / HEATER EXCHANGER
- PROCESS LINE STRAINER
- MOTOR
- FLOW RESTRICTOR
- VARIABLE AREA FLOW INDICATOR
- CENTRIFUGAL PUMP
- BREATHING DEVICE
- LNG SUBMERSIBLE PUMP
- BLOWER

### SAFETY VALVES

- PRESSURE ACTUATED
- VACUUM ACTUATED
- PILOT OPERATED
- VACUUM / PRESSURE ACTUATED

### SOLENOID VALVES

- ELECTRIC TWO-WAYS
- ELECTRIC THREE-WAYS (D=DE-ENERGIZED)
- PNEUMATIC TWO-WAYS
- PNEUMATIC THREE WAYS (D=DE-ENERGIZED)

### INSTRUMENT CONNECTION

- CONNECTION TO PROCESS OR INSTRUMENT SUPPLY
- THERMAL CAPILLARY
- ELECTRICAL WIRING
- SOFTWARE LINK

### REGULATORS

- INTERNAL PILOT
- EXTERNAL PILOT
- TEMPERATURE CONTROLLED

### PIPING IDENTIFICATION (SIAD MI)

X - XX - X - XXX - X

- FLUID
- INSULATION TYPE
- PIPE SIZE
- PROGRESSIVE NUMBER
- LINE SPECIFICATION

V = EXTERNAL PAINTING ONLY  
 N = NOT PAINTED / NOT INSULATED  
 F = INSULATION FOR LOW TEMPERATURE  
 I = HOT INSULATION  
 W = VACUUM INSULATION

A = RATING 150 ANSI  
 AB = RATING PN 10 DIN  
 B = RATING 300 ANSI

### PROCESS DATA

F	X
Q	Nm3/h
P	BAR (g)
T	°C
Ø	INCHES

### CROSS REFERENCE

ORIGIN OR DESTINATION SHEET

1/1N.5C

SHEET COORDINATES

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0C
	Scale	Format A3
Drawing number 120784		Sheet 3A

This document is property of SIAD MACCHINE IMPIANTI. Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI. All rights are reserved according to law. A termine di legge ogni diritto è riservato.

This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.


REVISION	SHEET	ALTERATIONS	DATE	DRAWN	CHECKED
0A	ALL	Issue for approval	03/02/2023	M. Caglioni	F. Soru
0B	1A	Issue for approval	23/02/2023	M. Caglioni	F. Soru
	2A				
	3A				
	4A				
	11				
	15				
	20				
	22				
	23				
	25				
	27				
	30				
	31				
	32				
	33				
	34				
	35				
	36				
	37				
	37A				
	37B				
	38				
	38A				
	38B				
	39A				
	39B				
	40				
	41				
	42				
	50				
	51				
	65				

REVISION	SHEET	ALTERATIONS	DATE	DRAWN	CHECKED
0C	1A	Issue for approval	13/03/2023	M. Caglioni	F. Soru
	3A				
	4A				
	10				
	11				
	15				
	16				
	20				
	23				
	25				
	26				
	27				
	30				
	31				
	32				
	33				
	34				
	35				
	36				
	37				
	37A				
	37B				
	38				
	38A				
	38B				
	39A				
	39B				
	42				
	43				
	50				
	68				
	70				

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0C
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale	Format A3
Drawing number I20784		Sheet 4A	



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.




- PU00AFC
- PU00AF0
- PU00AEG
- PU00AFE
- PU00AFG
- PU00AGF
- PU00AGG

**+MDL6000  
FEED GAS MODULE**

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0C
	Scale	Format A3
	Drawing number I20784	


This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.



Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIOPUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		11	




This document is property of SIAD MACCHINE IMPIANTI. Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law. A termine di legge ogni diritto è riservato.



- PUÖÖÄEFÖ
- PUÖÖÄEH
- PUÖÖÄEI
- PUÖÖÄEJ
- PUÖÖÄFE
- PUÖÖÄGF
- PUÖÖÄGH

Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIOPUS LNG GmbH				A3	
LOCATION : RENZHOFF (Germany)		Drawing number		Sheet	
		I20784		15	






This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.

Title <b>PIPING AND INSTRUMENTATION DIAGRAM</b> PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0C
	Scale	Format A3
	Drawing number 120784	






This document is property of SIAD MACCHINE IMPIANTI. Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI. All rights are reserved according to law. A termine di legge ogni diritto è riservato.



Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIOPUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		20	


PUÖÖÄEJ  
 PUÖÖÄFF

All rights are reserved according to law.  
 Tutti i diritti sono riservati secondo la legge.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.



Title <b>PIPING AND INSTRUMENTATION DIAGRAM</b> PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIPLUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job	Revision
	L43374	0B
	Scale	Format
	A3	
Drawing number	Sheet	
120784	22	






This document is property of SIAD MACCHINE IMPIANTI. Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law. A termine di legge ogni diritto è riservato.

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Job L43374	Revision 0C
Drawing number I20784		Scale Format A3	Sheet 23

All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.




Title <b>PIPING AND INSTRUMENTATION DIAGRAM</b> PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0C
	Scale A3	Format A3
	Drawing number I20784	Sheet 25




PUÖÖÄHE

OXYGEN IN BUILDING ATMOSPHERE  
 AT 1014B  
 AAL 1014B



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.

Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIOPUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		26	




All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0C
CUSTOMER : BIPLUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale A3	Format A3
Drawing number I20784		Sheet 27	



All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.




- PUÖÖÄFF
- PUÖÖÄFG
- PUÖÖÄHE

■ PUÖÖÄFH

Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIOPUS LNG GmbH		A3		Sheet	
LOCATION : RENZENHOF (Germany)		Drawing number		120784	
SIAD MACCHINE IMPIANTI		Sheet		30	

This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.




- PUÖÖÄFF
- PUÖÖÄFG
- PUÖÖÄHE

Title		Job	Revision
PIPING AND INSTRUMENTATION DIAGRAM		L43374	0C
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale	Format
CUSTOMER : BIOPUS LNG GmbH			A3
LOCATION : RENZENHOF (Germany)		Drawing number	Sheet
		I20784	31



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.



PUÖÖÄFH


**+P19000  
LNG TRUCK LOADING PUMP**

NOTE 1 - TEMPORARY FILTER

Title PIPING AND INSTRUMENTATION DIAGRAM		Job L43374	Revision 0C
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale	Format A3
CUSTOMER : BIPLUS LNG GmbH		Drawing number	Sheet
LOCATION : RENZENHOF (Germany)		120784	32



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.




**+P19001**  
**LNG TRUCK LOADING PUMP**

NOTE 1

NOTE 1 - TEMPORARY FILTER

Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIOPUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		33	







NOTE:  
VALVES HV1954A, HV1955A,  
X1965N/A, X1966N/A MUST BE  
INSTALLED NEAR LNG AND BOG  
LINES

NOTE 1: - DETACHMENT TAKEN  
AT THE BOTTOM OF  
THE PIPE

NOTE 2: - TE1953A INSTALLED IN  
THE BOTTOM OF THE  
MANIFOLD


**PUÖÖÄHG**



Title <b>PIPING AND INSTRUMENTATION DIAGRAM</b>		Job L43374	Revision 0C
Plant Type LNG LIQUEFACTION PLANT		Scale	Format A3
Customer BIOPLUS LNG GmbH		Location RENZENHOF (Germany)	Sheet 34
Drawing number I20784		SIAD MACCHINE IMPIANTI	

All rights are reserved according to law.  
 Tutti i diritti sono riservati secondo la legge.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.



All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.



NOTE:  
 VALVES HV1954B, HV1955B,  
 X1965N/B, X1966N/B MUST BE  
 INSTALLED NEAR LNG AND BOG  
 LINES


NOTE 1: - DETACHMENT TAKEN  
 AT THE BOTTOM OF  
 THE PIPE

NOTE 2: - TE1953B INSTALLED IN  
 THE BOTTOM OF THE  
 MANIFOLD



Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0C
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale A3	Format A3
Drawing number I20784		Sheet 35	





**+MDL5000  
NG REGENERATION MODULE**

**PUÖÖÄFE**

**PUÖÖÄFE**

**PUÖÖÄGH**


**+HW5000  
NG REGENERATION  
COOLER**

**+ST5000  
NG CONDENSATE  
SEPARATOR**

Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIPLUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		36	

All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.

This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.



**+MDL5000**  
NG REGENERATION MODULE


- PUÖÖÄFE
- PUÖÖÄGF
- PUÖÖÄGG

Title PIPING AND INSTRUMENTATION DIAGRAM		Job L43374	Revision 0C
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale	Format A3
CUSTOMER : BIPLUS LNG GmbH		Drawing number 120784	
LOCATION : RENZENHOF (Germany)		Sheet 37	



**+C5500  
NG REGENERATION  
COMPRESSOR**

ALL EQUIPMENT WITHIN THIS LINE  
SUPPLIED WITH COMPRESSOR  
(SIAD M.I.)  
FOR DETAILS SEE  
MANUFACTURER DWG No XXXX




All rights are reserved according to law.  
 Tutti i diritti sono riservati secondo la legge.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.

■ PUÖÖÄFE  
■ PUÖÖÄHG

Title <b>PIPING AND INSTRUMENTATION DIAGRAM</b> PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0C
	Scale	Format A3
	Drawing number 120784	



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A tutti i diritti sono riservati.




Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIPLUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		37B	





This document is property of SIAD MACCHINE IMPIANTI. Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI. All rights are reserved according to law. A termine di legge ogni diritto è riservato.











- █ PU00AF
- █ PU00FG
- █ PU00FH
- █ PU00AG
- █ PU00GG

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0C
CUSTOMER : BIPLUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale Format A3	Sheet 38
Drawing number 120784			



**+C9100  
BOG COMPRESSOR**

ALL EQUIPMENT WITHIN THIS LINE  
SUPPLIED WITH COMPRESSOR  
(SIAD M.I.)  
FOR DETAILS SEE  
MANUFACTURER DWG No XXXX




PUÖÖÄFG

PUÖÖÄHG

All rights are reserved according to law.  
 Tutti i diritti sono riservati secondo la legge.  
 All rights are reserved according to law.  
 Tutti i diritti sono riservati secondo la legge.  
 All rights are reserved according to law.  
 Tutti i diritti sono riservati secondo la legge.


Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIPLUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0C
	Scale	Format A3
	Drawing number 120784	Sheet 38A

This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A tutti i diritti sono riservati.





**+C910  
BOG COMPRESSOR**

ALL EQUIPMENT WITHIN THIS LINE SUPPLIED WITH COMPRESSOR  
 SIAD M.I.  
 FOR DETAILS SEE MANUFACTURER DWG No XXXX




PUÖÖÄFG  
 PUÖÖÄHG



Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0C
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale	Format A3
Drawing number 120784			Sheet 38B



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.




**PUÖÖÄFI**

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0C
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale A3	Format A3
Drawing number I20784		Sheet 39A	



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.

**PUÖÖÄFE**



**+FL16002  
HOT FLARE**

SEE P&I  
XXXXX  
(xxxxxx)

IGNITION SYSTEM

NG FROM CLIENT  
 MIN. PRESSURE 2 BARG  
 MAX PRESSURE 8 BARG

Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIOPUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		39B	




**TYPICAL**

**+VT17000  
LIN STORAGE TANK**

**+E17000  
LIN BUILD-UP  
VAPORIZER**

**CUSTOMER  
SUPPLY**

**PUOÒANG**



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.

Title PIPING AND INSTRUMENTATION DIAGRAM		Job L43374	Revision 0B
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale	Format A3
CUSTOMER : BIOPUS LNG GmbH		Drawing number 120784	
LOCATION : RENZENHOF (Germany)		Sheet 40	
<b>SIAD MACCHINE IMPIANTI</b>			

**TYPICAL**

**+VT17001  
LIN STORAGE TANK**


**+E17001  
LIN BUILD-UP  
VAPORIZER**

**PUÖÖÄHG**


**CUSTOMER  
SUPPLY**

This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A tutte le leggi sono riservati i diritti.

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0B
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale A3	Format A3
Drawing number I20784		Sheet 41	



PUÖÖÄHE




All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.

Title	Job	Revision
PIPING AND INSTRUMENTATION DIAGRAM	L43374	0C
PLANT TYPE : LNG LIQUEFACTION PLANT	Scale	Format
CUSTOMER : BIPLUS LNG GmbH		A3
LOCATION : RENZEHOF (Germany)	Drawing number	Sheet
	I20784	42








All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0C
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale A3	Format A3
Drawing number I20784		Sheet 43	



This document is property of SIAD MACCHINE IMPIANTI.  
Tutti i diritti sono riservati.  
All rights are reserved according to law.  
Tutti i diritti sono riservati secondo la legge.




Title	Job	Revision
PIPING AND INSTRUMENTATION DIAGRAM	L43374	0C
PLANT TYPE : LNG LIQUEFACTION PLANT	Scale	Format
CUSTOMER : BIOPUS LNG GmbH		A3
LOCATION : RENZENHOF (Germany)	Drawing number	Sheet
	I20784	50



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.


■ PUÖÖÄGE  
■ PUÖÖÄGH



Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0B	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIOPUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		51	

This document is property of SIAD MACCHINE IMPIANTI.  
Tutti i diritti sono riservati.  
All rights are reserved according to law.  
Tous droits réservés.


PUÖÖÄG



Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0A
	Scale	Format A3
Drawing number I20784		Sheet 60



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A tutti i diritti sono riservati.




NOTE 1: SUFFIX FROM "A" TO "R" FOR 16 FANS

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0B
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale Format A3	Sheet 65
Drawing number I20784			




This document is property of SIAD MACCHINE IMPIANTI.  
 Tutti i diritti sono riservati.  
 This document is reserved according to law.  
 All rights are reserved according to law.  
 All rights are reserved according to law.  
 All rights are reserved according to law.



Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0A
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale A3	Format A3
Drawing number I20784		Sheet 66	



This document is property of SIAD MACCHINE IMPIANTI.  
 It is present disegno e' di proprieta' della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto e' riservato.




■ PIPING

Title		Job		Revision	
PIPING AND INSTRUMENTATION DIAGRAM		L43374		0A	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format	
CUSTOMER : BIPLUS LNG GmbH				A3	
LOCATION : RENZENHOF (Germany)		Drawing number		Sheet	
		I20784		67	



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A tutti i diritti sono riservati.

**+DW8000  
 DEMI WATER PACKAGE**



■ PUÖÖÄGE
 ■ PUÖÖÄG


Title PIPING AND INSTRUMENTATION DIAGRAM		Job L43374		Revision 0C	
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale		Format A3	
CUSTOMER : BIOPUS LNG GmbH		Drawing number		Sheet	
LOCATION : RENZENHOF (Germany)		120784		68	





PUÖÖÄFF  
PUÖÖÄFI

PUÖÖÄEG







All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.

Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT		Job L43374	Revision 0C
CUSTOMER : BIOPUS LNG GmbH LOCATION : RENZENHOF (Germany)		Scale	Format A3
Drawing number I20784		Sheet 70	




This document is property of SIAD MACCHINE IMPIANTI.  
 I presenti disegni e di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.




Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIPLUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0A
	Scale	Format A3
Drawing number I20784		Sheet 74



This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 A termine di legge ogni diritto è riservato.




**ANALYSIS SYSTEM**




Title PIPING AND INSTRUMENTATION DIAGRAM		Job L43374	Revision 0A
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale	Format A3
CUSTOMER : BIOPUS LNG GmbH		LOCATION : RENZENHOF (Germany)	
Drawing number I20784		Sheet 75	




TYPE 1 - LV MOTOR  
TYPICAL



TYPE 2 - MV MOTOR  
TYPICAL



TYPE 8 - LV MOTOR UNDER VFD




All rights are reserved according to law.  
 Tutti i diritti sono riservati.  
 This document is property of SIAD MACCHINE IMPIANTI.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.


Title PIPING AND INSTRUMENTATION DIAGRAM		Job L43374	Revision 0A
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale	Format A3
CUSTOMER : BIOPUS LNG GmbH		Drawing number	
LOCATION : RENZENHOF (Germany)		120784	Sheet 80



TYPE 3 – HEATERS ON/OFF  
TYPICAL



TYPE 4 – HEATERS WITH THYRISTOR  
TYPICAL




This document is property of SIAD MACCHINE IMPIANTI.  
 All rights are reserved according to law.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI.


Title PIPING AND INSTRUMENTATION DIAGRAM PLANT TYPE : LNG LIQUEFACTION PLANT CUSTOMER : BIOPLUS LNG GmbH LOCATION : RENZENHOF (Germany)	Job L43374	Revision 0A
	Scale	Format A3
Drawing number I20784		Sheet 81



TYPE 5 – ON/OFF VALVE (ESD)  
TYPICAL



TYPE 5A – ON/OFF VALVE (ESD)  
TYPICAL



This document is property of SIAD MACCHINE IMPIANTI. All rights are reserved according to law.  
 Il presente disegno è di proprietà della SIAD MACCHINE IMPIANTI. Tutti i diritti sono riservati.

Title PIPING AND INSTRUMENTATION DIAGRAM		Job L43374	Revision 0A
PLANT TYPE : LNG LIQUEFACTION PLANT		Scale	Format A3
CUSTOMER : BIOPUS LNG GmbH		Drawing number 120784	
LOCATION : RENZENHOF (Germany)		Sheet 82	



**LNG liquefaction plant**

HAZOP and SIL Allocation Report

PROJECT  
23123I

DATE  
April 2023

PAGE  
3 di 7

**ATTACHMENT 3**

HAZOP Worksheet

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH

Location: Renzenhof, Germany

Facility: LNG liquefaction plant

PHA Method: HAZOP

PHA Type: Initial

Process:

File Description:

Date:

Process Description:

Chemicals:

Purpose:

Scope:

Objectives:

Project Notes:



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023  
 Node: (00) General issues  
 Notes:  
 Drawings:  
 Parameter: Flow

Intention:

Equipment:

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect	1. Misdirect Flow	1.1. Inadvertent opening of vent valve on NG circuit to hot flare	1.1.1. Potential overpressurization of hot flare header  1.1.2. Possible unexpected routing of gas to hot flare when not in operation with possible environmental concern/ complains from authorities		1. Mode of operation of hot flare and potential overpressurization scenario due to inadvertent opening of manual vent valves to be investigated once design of hot flare will be finalized (e. g. increasing DP of hot flare header, etc...)  2. Appropriate isolation philosophy to be investigated for drains and vents on LNG/NG high pressure vents and drains to hot flare used for maintenance purposes only	SIAD MI / OGE  SIAD MI / OGE	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
 OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Flow

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	2. No/less Flow	<p>2.1. Loss of natural gas from BL (any causes)</p> <p>2.2. Plugging of filter F-B41</p> <p>2.3. Unexpected closure of SSV-B41520/41530 or PCV-B41540 or any other valve in the line</p>	<p>2.1.1. No impact on this node</p> <p>2.1.2. Loss of natural gas to downstream section (See Node #01B and #02)</p> <p>2.1.3. Loss of natural gas to ground flare pilot and consequent delay in maintenance operation (ground flare is used for maintenance only)</p> <p>2.1.4. Loss of natural gas to building heating system</p> <p>2.2.1. According to composition of natural gas, significant plugging of the filter is not expected. In case of plugging, expected consequence is slight increase of differential pressure over time with potential minor operational upset</p> <p>2.3.1. No impact on mechanical integrity of new piping according to design criteria (85 barg vs 67.5 barg)</p> <p>2.3.2. Loss of natural gas to downstream section (See Node #01B and #02)</p> <p>2.3.3. No impact on existing natural gas distribution network</p>	<p>2.1.2.1. PAL/PALL-B40622 and operator response</p> <p>2.2.1.1. PDAH/AHH-B41211</p> <p>2.3.2.1. PAL/PALL-B40622 and operator response</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
 OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Flow

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	3. More Flow	3.1. Higher demand rate from downstream unit	3.1.1. Possible lower temperature of natural gas at W-B41 outlet and potential operational upset with no safety concern	3.1.1.1. TAL/TALL-B40621 and operator response			
Reverse	4. Reverse Flow	4.1. No credible causes identified					
Misdirect	5. Misdirect Flow	5.1. Stand-by PCV passing/open	5.1.1. No impact on metering since stand-by metering system is normally isolated by manual block valves  5.1.2. See pressure more for wide opening of PCV-B41540/B42540				

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
 OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Temperature

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	6. Lower Temperature	6.1. Refer to More Flow in this node  6.2. Failure of heater W-B41 or failure of relevant temperature control system (TT-B40621)	6.2.1. Lower temperature of natural gas at the outlet of fiscal metering station (estimated -2 °C instead of 10°C) with no impact on mechanical integrity of piping and potential operational upset on downstream sections.		3. Ensure that signal from TT-B41320 and TT-B42320 are reported to DCS including high and low temperature alarm	OGE (TPG)	

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
 OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Temperature

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	6. Lower Temperature (cont.)	6.2. Failure of heater W-B41 or failure of relevant temperature control system (TT-B40621) (cont.)  6.3. Low ambient temperature	6.2.2. Condensation is not expected in this case according to natural gas dew point (approximately -8°C)  6.3.1. No impact during normal operation if heater W-B41 is working properly. Lower temperature of natural gas. Significant condensation is not expected in this case.	6.3.1.1. TAL/TALL-B40621 and operator response (Stand-by heater available)  6.3.1.2. Metering station located inside container			
More	7. Higher Temperature	7.1. No causes identified for natural gas supply from distribution network  7.2. Higher heat input from heater W-B41 due to failure of relevant temperature control system (TT-B40621)	7.2.1. Increase of natural gas temperature and potential overheating of downstream piping (DT=80°C) with potential mechanical damage and loss of containment (possible fire/explosion)  7.2.2. Possible damage to heater elements due to overheating (economical losses)	7.2.1.1. Internal independent high high temperature interlock provided for heater W-B41 (Minimum requirement included on data sheet for vendor)  7.2.2.1. Internal independent high high temperature interlock provided for heater W-B41 (Minimum requirement included on data sheet for vendor)	4. Ensure provision for internal independent high high temperature interlock provided for heater W-B41 to protect heater itself and downstream piping from overheating scenario  :See_4	OGE (TPG)	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
 OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Pressure

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	8. Lower Pressure	8.1. Refer to No/Less flow in this node					
More	9. Higher Pressure	9.1. No cause identified from distribution network  9.2. Refer to No/Less flow in this : node					SBV-B40303 is addressed to relief gas protecting piping and prevent leading to intervention of shut-off valve SSVs in case of leakage from PCV-B41540
		9.3. PCV-B41540 malfunction (fully open), including PT-B40622 malfunction	9.3.1. Pressure build-up downstream valve PCV-B41540 up to 65 barg and potential overpressurization (DP=52 barg) with mechanical damage, loss of containment and potential for fire/explosion	9.3.1.1. SSV-B41520/B41530 (mechanical/pneumactical devices to cut off natural gas supply)	5. Ensure adequate set point for SSV-B41520/B41530 intervention to prevent opening of PSVs located on downstream piping (set at 52 barg)	OGE (TPG)	
		9.4. PCV-610 malfunction (fully open)	9.4.1. Higher pressure of natural gas routed to analyser (44 barg instead of 1 barg) with potential overpressurization of analysers (AI-1001, 1010, 1011, 1016) and associated items (DP= 0.5 barg) with mechanical damage and potential injuries to personnel		6. Ensure provision for pressure release devices to protect analysers AI-1001, 1010, 1011, 1016 and associated items in case of wide opening of pressure let down valve PCV-610/602	SIAD MI	Tubing and first valve downstream PCV-610 are rated to withstand 65 barg
		9.5. External fire	:		7. Investigate requirement for pressure relief devices for external fire case in compliance with criteria...	OGE (TPG)	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
 OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Pressure

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	9. Higher Pressure (cont.)	9.5. External fire (cont.)	: (cont.)		...adopted for production plant		

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
 OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Level

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	10. No/less Level	10.1. Not applicable					
More	11. Higher Level	11.1. Not applicable					

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
 OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Composition

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	12. Different Composition	12.1. Increased content of contaminants (CO <sub>2</sub> , H <sub>2</sub> S, H <sub>2</sub> , O <sub>2</sub> , N <sub>2</sub> )	12.1.1. No impact on this node  12.1.2. Possible impact on liquefaction section (see relevant nodes)	12.1.2.1. Online analysers AI-1001, 1010, 1011, 1016 including high concentration alarms			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01A) Fiscal metering station

Intention: OP upstream = 55 barg (normal operating), 65 barg (maximum operating), OP downstream = 43 barg, DP = 67.5 barg  
OT upstream W-B41 = 10°C

Notes:

Drawings: I20784 Sh 10

Parameter: Services / Utilities

Equipment: F-B41/2, W-B41/2

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	13. No Services / Utilities	13.1. No additional causes identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Flow

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	14. No/less Flow (NG feed to TW1002)	14.1. Unexpected closure of HV-600 or HV-105	14.1.1. Blocked outlet for upstream section (See No/Less flow in Node #01A)  14.1.2. Pressure build-up overtime downstream valve PCV-B41540 up to 65 barg and potential overpressurization (DP=52 barg) with mechanical damage, loss of containment and potential for fire/explosion	14.1.2.1. Discrepancy alarm provide for HVs  14.1.2.2. PAH/PAHH-B40622 and operator response  14.1.2.3. SSV-B41520/B41530 (mechanical/pneumactical devices to cut off natural gas supply)			
		14.2. Significant plugging of mercury trap is not expected according to gas composition  14.3. Possible plugging of dust filter	14.1.3. No impact on equipment in this node  14.1.4. Loss of natural gas to downstream sections (see relevant nodes)	14.3.1.1. PDAH-101			
	15. No/less Flow (TW1002 overhead line)	15.1. Unexpected closure of HV-133	15.1.1. Pressure build-up overtime downstream valve PCV-B41540 up to 65 barg and potential overpressurization...	15.1.1.1. Discrepancy alarm provide for HVs  15.1.1.2. PAH/PAHH-...			



# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Flow

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	15. No/less Flow (TW1002 overhead line) (cont.)	15.1. Unexpected closure of HV-133 (cont.)	...(DP=52 barg) with mechanical damage, loss of containment and potential for fire/explosion	...B40622 and operator response  15.1.1.3. SSV- B41520/B41530 (mechanical/pneumactical devices to cut off natural gas supply)			
	16. No/less Flow (TW1002 bottom side)	16.1. Unexpected closure of LV- 146 or malfunction of LIC-152 closing LV-152	15.1.2. Loss of natural gas to downstream sections (see relevant nodes)  16.1.1. Level build up in TW1002 bottom section, according to limited inventory of amine complete overfilling is not expected.  16.1.2. Loss of reach amine supply to flash vessel/stripping column resulting in loss of lean amine supply to TW1002 overtime and consequent CO2 carry over to downstream section with potential impact on cold box (see relevant nodes)	16.1.2.1. LAHH-126 to activate closure of HV-105, HV-106 (same actions are also initiated by LAHH-127 on S1001)  16.1.2.2. PDI-125 to give alarm for high DP and to activate closure of HV-105, HV-106 in case of high high DP  16.1.2.3. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Flow

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	17. No/less Flow (nitrogen supply to cold flare header)	17.1. Inadvertent closure of manual valve	17.1.1. Negligible impact since multiple sources of flushing nitrogen to cold flare are in place				
More	18. More Flow (NG feed to TW1002)	18.1. Higher demand rate of natural gas (JT valve PV-703 malfunction)	18.1.1. Higher flowrate of gas TW-1002 and potential for inadequate CO2 removal and consequent CO2 carry over to downstream section with potential impact on cold box (see relevant nodes)	18.1.1.1. FIC-713 to limit natural gas flowrate  18.1.1.2. PDAH-125 and operator response  18.1.1.3. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD			
Reverse	19. Reverse Flow	19.1. No causes identified on natural gas side  19.2. No caused identified for natural gas backflow into nitrogen circuit since double block and bleed valve (FC) are provided (initiated by shut-down and depressurizing sequence)					
Misdirect	20. Misdirect Flow	20.1. HV-602 or HV-106 left opened after start-up  20.2. Inadvertent opening of mercury trap F1005 by-pass line	20.1.1. No impact  20.2.1. Possible mercury carry-over to downstream section resulting in potential damage of equipment overtime (long term scenario) and reduction of relevant lifetime		20.2.1.1. Routine inspection and procedure		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Flow

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	20. Misdirect Flow (cont.)	20.3. Unexpected opening of HV-164	20.3.1. Significant portion of natural gas sent to cold flare resulting in possible environmental concern	20.3.1.1. Discrepancy alarm on HVs  20.3.1.2. PDI-105 to give alarm for high DP and to activate closure of HV-105, HV-106 in case of high high DP  20.3.1.3. Restriction orifice RO-169 to limit flowrate			

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Temperature

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	21. Lower Temperature	21.1. Loss of heating medium to HW6000 including TIC-600 malfunction closing relevant TV  21.2. Refer to Low temperature in Node #01A	21.1.1. Lower temperature of natural gas routed to TW1002 (10 °C instead of 30°C) resulting in inadequate CO2 removal and consequent carry over to downstream sections (see relevant nodes)  21.2.1. Lower temperature of natural gas routed to TW1002 (10 °C instead of 30°C) resulting in inadequate CO2 removal and consequent carry over to...	21.1.1.1. TAL/TALL-119 activate closure of HV-600, HV-602  21.1.1.2. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD  21.2.1.1. TAL/TALL-119 activate closure of HV-600, HV-602  21.2.1.2. AI-1012 to...			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 30 °C

TW1002: OT ~ 54 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Temperature

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	21. Lower Temperature (cont.)	21.2. Refer to Low temperature in Node #01A (cont.)	...downstream sections (see relevant nodes)	...provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD	8. Investigate appropriate monitoring system to check functionality/effectiveness of electrical tracing systems	SIAD MI	
		21.3. Low ambient temperature	21.3.1. Possible freezing of stagnant piping on rich amine side	21.3.1.1. Electrical tracing and insulation provided on rich amine piping (electrical tracing also supplied by EDG)			
More	22. Higher Temperature	22.1. Refer to Higher temperature in Node #01A					
		22.2. Malfunction of TIC-600 providing higher duty to exchanger HW6000 by opening relevant TV	22.2.1. Higher temperature of natural gas routed to TW1002 resulting in inadequate CO2 removal and consequent carry over to downstream sections (see relevant nodes)	22.2.1.1. TAH/TAHH-119 activate closure of HV-600, HV-602  22.2.1.2. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Pressure

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	23. Lower Pressure	23.1. Loss of feed from BL (Refer to No/Less flow in Node #01A)	23.1.1. Inadequate CO2 removal and consequent carry over to downstream sections (see relevant nodes)	23.1.1.1. PAL/PALL-604 activate closure of HV-600, HV-602  23.1.1.2. PAL/PALL-122 activate closure of HV-105, HV-106  23.1.1.3. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD			
		23.2. Inadequate pressurization at start-up (HV-106 does not open on demand)	23.2.1. Possible impact to F1005 internals due to high DP when HV-105 is open with loss of efficiency and possible reduced lifetime	23.2.1.1. Permissive to not open HV-105 below minimum set point initiated by PT-122			
More	24. Higher Pressure	24.1. Refer to No/Less flow in this node					
		24.2. Refer to More Pressure in node #01A					
		24.3. External fire	:			:See_7	
		24.4. Trapped gas between HV-600 and HV-105	24.4.1. Possible thermal expansion of trapped gas with no impact since estimated pressure build-up is lower than 52 barg (DP)				
		24.5. PCV-602 malfunction (fully open)	24.5.1. Higher pressure of natural gas routed to analyser (44 barg...			:See_6	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Pressure

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	24. Higher Pressure (cont.)	24.5. PCV-602 malfunction (fully open) (cont.)	...instead of 1 barg) with potential overpressurization of analysers (AI-1001, 1010, 1011, 1016) and associated items (DP= 0.5 barg) with mechanical damage and potential injuries to personnel		:See_6 (cont.)		

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Level

Equipment: HW6000, F1005, F1006, TW1002, S1001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	25. No/less Level	25.1. Malfunction of LIC-152 fully opening LV-152 on TW-1002 bottom side	25.1.1. Loss of level on TW-1002 and consequent gas breakthrough (44 barg) to flash vessel S1003 (DP=10 barg) leading to potential overpressurization with mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to mechanical damage	25.1.1.1. LALL-144 activate closure of LV-146 (same function is also initiated by PAHH-172)  25.1.1.2. PSV-167 on S1003 sized including gas breakthrough scenario			Capacity of S1003 is adequate to handle incoming liquid from TW1002 in case of wide opening of LV-152 in order to exclude potential overfilling scenario
More	26. Higher Level	26.1. Refer to No/Less flow in this node  26.2. No causes identified for S1001					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Equipment: HW6000, F1005, F1006, TW1002, S1001

Parameter: Composition

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	27. Different Composition	27.1. See previous deviation  27.2. See node #06 for off-spec lean amine					

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Intention: HW6000 shell side: OTin = 10 °C, OTout = 30 °C

TW1002: OT ~ 54°C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Equipment: HW6000, F1005, F1006, TW1002, S1001

Parameter: Services / Utilities

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	28. No Services / Utilities	28.1. Loss of utilities	28.1.1. No additional scenario identified (see previous deviation)				





## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Flow

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	29. No/less Flow (cont.)	29.2. Unexpected isolation within feed gas module MDL6000 (cont.)  29.3. Unexpected closure of PCV-1581  29.4. Unexpected closure of PCV-1650	...provided by manufacturer)  29.2.3. Loss of natural gas feed to thermal-oxidizer pilots and main burners resulting in operational upset including possible plant shut-down  29.2.4. Loss of natural gas feed to thermal-oxidizer pilots and main burners (see dedicated HAZARD analysis/any other technical documentation provided by manufacturer)  29.2.5. Negligible impact on upstream sections  29.3.1. Loss of natural gas feed to steam generator burners leading to loss of LP steam production leading to plant shut-down  29.3.2. Loss of natural gas feed to steam generator burners (see dedicated HAZARD analysis/any other technical documentation provided by manufacturer)  29.4.1. Loss of natural gas feed to thermal-oxidizer pilots and main burners resulting in operational upset including possible plant shut-down  29.4.2. Loss of natural gas feed...				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 18 of 161

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Flow

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	29. No/less Flow (cont.)	29.4. Unexpected closure of PCV-1650 (cont.)	...to thermal-oxidizer pilots and main burners (see dedicated HAZARD analysis/any other technical documentation provided by manufacturer)				
More	30. More Flow	30.1. No significant cause identified					
Reverse	31. Reverse Flow	31.1. No causes identified					
Misdirect	32. Misdirect Flow	32.1. No causes identified					

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Temperature

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	33. Lower Temperature	33.1. Lower temperature of natural gas from upstream section (see node #01B)	33.1.1. Natural gas routed to feed gas module at 10 °C instead of 30 °C and consequent lower temperature to users (estimated - 17 °C) leading to possible operational upset. No impact on mechanical integrity on piping (MDMT = -29°C)  33.1.2. Lower temperature of natural gas sent to users (see relevant HAZARD analysis/technical documentation)	33.1.1.1. TAL-601 / TALL-601 to close HV-600  33.1.2.1. TAL-601 / TALL-601 to close HV-600			
More	34. Higher Temperature	34.1. Higher temperature of natural gas from upstream...	34.1.1. No significant impact				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Temperature

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	34. Higher Temperature (cont.)	...section (see node #01B)	34.1.1. No significant impact (cont.)				

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Pressure

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	35. Lower Pressure	35.1. See no/less flow					
More	36. Higher Pressure	36.1. Malfunction of pressure controller on feed gas module	36.1.1. Higher pressure of natural gas at feed gas module outlet resulting in potential overpressurization, mechanical damage, natural gas leak and fire / explosion hazard	36.1.1.1. Shut-off valves provided within MDL6000 as per national regulation  36.1.1.2. PAHH-601 to activate closure of HV-600  36.1.1.3. PSV-605 sized including this scenario			
		36.2. Malfunction of PCV-1581 (fully open)	36.2.1. Higher pressure of natural gas routed to steam boiler burners (44 barg instead of 2 barg) (see dedicated HAZARD analysis/any other technical documentation provided by manufacturer)				
		36.3. Malfunction of PCV-1615 (fully open)	36.3.1. Higher pressure of natural gas routed to thermal oxidizer burners and main pilots (44 barg instead of 2 barg) (see dedicated HAZARD analysis/any other technical documentation...				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Pressure

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	36. Higher Pressure (cont.)	36.3. Malfunction of PCV-1615 (fully open) (cont.)	...provided by manufacturer)				

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Level

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	37. No/less Level	37.1. Not applicable					
More	38. Higher Level	38.1. Not applicable					

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Composition

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	39. Different Composition	39.1. No causes identified					

Session: (1) 27/03/2023

Node: (02) Natural gas supply to steam generator

Intention: RS6000: m= 70 kg/h; OPin = 43,9 barg, OPout = 2 barg; OTin = 30 °C, OTout = 6 °C

Notes:

Drawings: I20784 Sh 10; I20784 Sh 11; I20784 Sh 50; I20784 Sh 70

Parameter: Services / Utilities

Equipment: RS6000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	40. No Services / Utilities	40.1. Not applicable					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023  
 Node: (03) Flash vessel  
 Intention: S1003: OT ~ 54°C  
 HW2007: OTin = 54°C; OTout = 99°C  
 OP = 5 barg

**Notes:**

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 15; I20784 Sh 36  
 Parameter: Flow

Equipment: S1003, HW2007

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	41. No/less Flow (Overhead line)	41.1. Malfunction of PIC-171 closing PV-171 or PV spurious closure	41.1.1. Pressure build up in S1003 leading to potential overpressurization with mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to mechanical damage  41.1.2. Loss of amine flash gas to NG regeneration cooler with negligible impact (9 Nm3/h vs overall stream 260 Nm3/h)	41.1.1.1. PAHH-172 to activate closure of LV-146  41.1.1.2. PSV-167 sized including this scenario			
	42. No/less Flow (Hydrocarbon line)	42.1. Malfunction of LIC-158 closing LV-158 or not opening on demand or spurious closure of LV-143	42.1.1. Hydrocarbon accumulation overtime on S1003 leading to potential HC carry over to TW2008 and TW1002 resulting in foaming and consequent operational upset	42.1.1.1. Periodical sampling and operator response (antifoam injection available)			
	43. No/less Flow (Rich amine)	43.1. Malfunction of LIC-163 closing LV-163 or not opening on demand or spurious closure of LV-151	43.1.1. Increase of level in S1003, overfilling is not expected taking into account void space available in S1003 compared to hold up in TW2008 and TW1002  43.1.2. Increase of level in S1003 leading to rich amine overflow inside HC bucket and consequent possible amine carry-over to thermal oxidizer KO drum with operational upset and no safety concern	43.1.2.1. LAHH-154 to activate closure LV-146			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023  
 Node: (03) Flash vessel  
 Intention: S1003: OT ~ 54°C  
 HW2007: OTin = 54°C; OTout = 99°C  
 OP = 5 barg

**Notes:**

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 15; I20784 Sh 36  
 Parameter: Flow

Equipment: S1003, HW2007

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	43. No/less Flow (Rich amine) (cont.)	43.1. Malfunction of LIC-163 closing LV-163 or not opening on demand or spurious closure of LV-151 (cont.)	43.1.3. Loss of reach amine supply to stripping column resulting in loss of lean amine supply to TW1002 overtime and consequent CO2 carry over to downstream section with potential impact on cold box (see relevant nodes)  43.1.4. Loss of reach amine supply to stripping column resulting in loss of level and potential damage to P-2005A/B due to dry-running with potential localized NG leakage due to backflow from TW1002 resulting in possible fire and injuries to personnel	43.1.3.1. LAL-202 and operator response  43.1.3.2. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD  43.1.4.1. LAL-202 and operator response  43.1.4.2. LALL-209 activate trip of pump P-2005A/B and to close HV-138			
More	44. More Flow	44.1. No causes identified					
Reverse	45. Reverse Flow (NG side)	45.1. No causes identified for backflow from gas regeneration cooler according to operating condition downstream cooler itself (OP approximately 1.5 barg)					
	46. Reverse Flow (HC side)	46.1. No causes identified for backflow from oxidizer suction KO drum through HC discharge line (OP approximately 0.1 barg)					
	47. Reverse Flow (rich amine)	47.1. No causes identified for backflow from TW2008...					

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023  
 Node: (03) Flash vessel  
 Intention: S1003: OT ~ 54°C  
 HW2007: OTin = 54°C; OTout = 99°C  
 OP = 5 barg

**Notes:**

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 15; I20784 Sh 36  
 Parameter: Flow

Equipment: S1003, HW2007

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Reverse (cont.)	47. Reverse Flow (rich amine) (cont.)	...according to operating condition (OP approximately 0.9 barg)					
Misdirect	48. Misdirect Flow	48.1. No causes identified					

Session: (2) 28/03/2023  
 Node: (03) Flash vessel  
 Intention: S1003: OT ~ 54°C  
 HW2007: OTin = 54°C; OTout = 99°C  
 OP = 5 barg

**Notes:**

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 15; I20784 Sh 36  
 Parameter: Temperature

Equipment: S1003, HW2007

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	49. Lower Temperature	49.1. No significant process causes identified  49.2. Low ambient temperature	49.2.1. Possible freezing of stagnant piping on rich amine side	49.2.1.1. Electrical tracing and insulation provided on rich amine piping (electrical tracing also supplied by EDG)	:See 8		
More	50. Higher Temperature	50.1. No causes identified					

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023  
 Node: (03) Flash vessel  
 Intention: S1003: OT ~ 54°C  
 HW2007: OTin = 54°C; OTout = 99°C  
 OP = 5 barg

**Notes:**

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 15; I20784 Sh 36  
 Parameter: Pressure

Equipment: S1003, HW2007

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	51. Lower Pressure	51.1. Malfunction of PIC-171 fully opening PV-171	51.1.1. Pressure decrease in S1003 resulting in inadequate driving force to push rich amine to stripping unit (Refer to No/Less Flow consequences)  51.1.2. No impact on downstream system				
More	52. Higher Pressure	52.1. Gas breakthrough scenario from TW1002 (see node #01B)  52.2. Blocked outlet (see no/less flow in this node)  52.3. Gas breakthrough scenario from HW4001 (see Node #04)  52.4. External fire	52.4.1. Overpressurization of involved equipment/piping with possible mechanical damage	52.4.1.1. PSV-167 sized including external fire			



# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023  
 Node: (03) Flash vessel  
 Intention: S1003: OT ~ 54°C  
 HW2007: OTin = 54°C; OTout = 99°C  
 OP = 5 barg

**Notes:**

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 15; I20784 Sh 36  
 Parameter: Level

Equipment: S1003, HW2007

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	53. No/less Level (Hydrocarbon side)	53.1. Malfunction of LIC-158 fully opening LV-158	53.1.1. Loss of HC level on HC bucket and consequent gas breakthrough (5 barg) to thermal oxidizer KO drum V16200 (DP > 5 barg). No impact on mechanical integrity  53.1.2. Minor economical losses due to routing of NG to thermal oxidizer	53.1.2.1. LSSL-104 activate closure of LV-143			V16200 DP to be finalized (at least same of DP of flash vessel S1003, 10 barg)
	54. No/less Level (rich amine)	54.1. Malfunction of LIC-163 fully opening LV-163	54.1.1. Loss of amine level on S1003 and consequent gas breakthrough (5 barg) to stripping column TW2008 (DP= 2 barg) with potential mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to mechanical damage	54.1.1.1. LALL-164 activate closure of LV-151  54.1.1.2. PSV-271 sized including gas breakthrough scenario			
More	55. Higher Level	55.1. Refer to No/Less flow in this node					

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
Facility: LNG liquefaction plant

Session: (2) 28/03/2023  
Node: (03) Flash vessel  
Intention: S1003: OT ~ 54°C  
HW2007: OTin = 54°C; OTout = 99°C  
OP = 5 barg

Notes:

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 15; I20784 Sh 36

Parameter: Composition

Equipment: S1003, HW2007

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	56. Different Composition	56.1. No additional causes identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (04) NG stream to dryers and condensate separator

Intention: HW4001: OTin = 50 °C, OTout = 20 °C, OPchilled water = 3 barg  
 OP = 44 barg

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 5

Parameter: Flow

Equipment: HW4001, ST4001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	57. No/less Flow (gas)	57.1. No/Less Flow from upstream section	57.1.1. No impact on this node				
	58. No/less Flow (condensate)	58.1. Malfunction of LIC-419 closing LV-419 or not opening on demand or spurious closure of LV-413	58.1.1. No impact on flash vessel S1003  58.1.2. Level build up on pre-cooler condensate separator ST4001 resulting in possible overfilling and liquid carry over to dryers with potential for damage of adsorbent material, economical losses and no safety concern	58.1.2.1. LAHH-411 activate closure HV105, HV106  58.1.2.2. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD			
More	59. More Flow	59.1. No causes identified					
Reverse	60. Reverse Flow	60.1. No causes identified					
Misdirect	61. Misdirect Flow	61.1. Tube rupture in HW4001  61.2. HV-130 left opened after start-up	61.1.1. NG (44 barg) enters into HW4001 shell side (DP= 8 barg) and potential overpressurization on chilled water circuit resulting in mechanical damage and loss of containment of natural gas, potential fire/explosion and injuries to personnel due to mechanical damage  61.2.1. No impact	61.1.1.1. PSV-478 sized for this scenario (routed to cold flare)			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (04) NG stream to dryers and condensate separator

Intention: HW4001: OTin = 50 °C, OTout = 20 °C, OPchilled water = 3 barg  
 OP = 44 barg

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 5

Parameter: Temperature

Equipment: HW4001, ST4001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	62. Lower Temperature	62.1. Malfunction of TIC-486 fully opening TV-486 on chilled water circuit	62.1.1. Lower temperature on natural gas resulting in potential hydrates formation and possible plugging overtime leading to operational upset	62.1.1.1. TALL-421 activate closure of HV-105 and HV-106	:See 8  9. Provide winterization on low points where condensation may happen on naturale gas line from TW1002 to HW4001	SIAD MI	
		62.2. Low ambient temperature	62.2.1. Possible freezing of stagnant piping on condensate side	62.2.1.1. Electrical tracing and insulation provided on condensate piping (electrical tracing also supplied by EDG)			
More	63. Higher Temperature	63.1. Loss of chilled water including malfunction of TIC-486 closing TV-486	63.1.1. Loss of water condensation on natural gas stream leading to reduced efficiency of dryer section and potential for umidy slippage to cold box (see relevant node)	63.1.1.1. TAHH-421 activate closure of HV-105 and HV-106  63.1.1.2. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (04) NG stream to dryers and condensate separator

Intention: HW4001: OTin = 50 °C, OTout = 20 °C, OPchilled water = 3 barg  
 OP = 44 barg

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 5

Parameter: Pressure

Equipment: HW4001, ST4001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	64. Lower Pressure	64.1. Inadequate pressurization at start-up (HV-130 does not open on demand)	64.1.1. Possible impact to downstream equipment (online dryers) due to high DP when HV-133 is open with possible damage to internals and economical losses	64.1.1.1. Permissive to not open HV-133 below minimum set point initiated by PT-122/439/440/441			
More	65. Higher Pressure	65.1. Refer to misdirect flow (tube tupture in HW4001)  65.2. External fire  65.3. Trapped liquid on HW4001 shell side	:  65.3.1. Thermal expansion of trapped chilled water resulting in mechanical damage and economical losses	65.3.1.1. PSV-478 sized for this scenario	:See 7		

Session: (2) 28/03/2023

Node: (04) NG stream to dryers and condensate separator

Intention: HW4001: OTin = 50 °C, OTout = 20 °C, OPchilled water = 3 barg  
 OP = 44 barg

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 5

Parameter: Level

Equipment: HW4001, ST4001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	66. Lower Level	66.1. Malfunction of LIC-419 fully opening LV-419	66.1.1. Loss of level on ST-4001 and consequent gas breakthrough (44 barg) to flash vessel S1003 (DP=10 barg) leading to potential overpressurization with mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to...	66.1.1.1. LALL-472 activate closure of LV-413  66.1.1.2. PSV-167 on S1003 sized including gas breakthrough scenario	10. Closure of LV-413 shall be also initiated by PAHH-172	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (04) NG stream to dryers and condensate separator

Intention: HW4001: OTin = 50 °C, OTout = 20 °C, OPchilled water = 3 barg  
 OP = 44 barg

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 5

Parameter: Level

Equipment: HW4001, ST4001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	66. Lower Level (cont.)	66.1. Malfunction of LIC-419 fully opening LV-419 (cont.)	...mechanical damage	66.1.1.2. PSV-167 on S1003 sized including gas breakthrough scenario (cont.)	10. Closure of LV-413 shall be also initiated by PAHH-172 (cont.)		
More	67. Higher Level	67.1. Refer to No/Less flow					

Session: (2) 28/03/2023

Node: (04) NG stream to dryers and condensate separator

Intention: HW4001: OTin = 50 °C, OTout = 20 °C, OPchilled water = 3 barg  
 OP = 44 barg

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 5

Parameter: Composition

Equipment: HW4001, ST4001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	68. Different Composition	68.1. No additional causes identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (05) MDEA Storage tank and dosing

Intention: System used for periodical pure amine make up after weekly sampling (if make up is required)

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Flow

Equipment: Amine IBC, P3001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	69. No/less Flow	69.1. Pump P3001 failure when required in operation	69.1.1. Interruption of pure amine make-up and consequent delay in operation (according to operating manual, additional sampling is required after make-up)	69.1.1.1. Totalizer FIQ-304  69.1.1.2. Discrepancy alarm/electrical fault signal for pump status reported to PLC			
More	70. More Flow	70.1. Improper make-up operation (excessive amount )	70.1.1. Higher amount of pure amine with no significant consequences on process side. Minor economical losses				
Reverse	71. Reverse Flow	71.1. Pump P3001 failure when required in operation	71.1.1. Possible backflow from lean amine circuit with potential contamination of fresh amine and economical losses/potential overflowing of IBC and potential for soil contamination	71.1.1.1. Discrepancy alarm/electrical fault signal for pump status reported to PLC  71.1.1.2. Presence of two check valves in series  71.1.1.3. IBC located inside curbed area with adequate impermeable material			
Misdirect	72. Misdirect Flow	72.1. Wrong line up of connection between P3001 discharge and V3004	72.1.1. Make-up amine batch routed to V3004 instead of to lean amine circuit resulting in minor economical losses/operational upset due to delay in operation. No impact on V3004 according to limited amount involved				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (05) MDEA Storage tank and dosing

Intention: System used for periodical pure amine make up after weekly sampling (if make up is required)

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Temperature

Equipment: Amine IBC, P3001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	73. Lower Temperature	73.1. Low ambient temperature	73.1.1. No impact on pure amine circuit according to its freezing point (-48°C)  73.1.2. Potential freezing on portions of piping where lean amine can be possibly present and consequent mechanical damage	73.1.2.1. Winterization provided between first check valve on pump P3001 discharge and injection point	:See.8		
More	74. Higher Temperature	74.1. No causes identified					

Session: (2) 28/03/2023

Node: (05) MDEA Storage tank and dosing

Intention: System used for periodical pure amine make up after weekly sampling (if make up is required)

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Pressure

Equipment: Amine IBC, P3001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	75. Lower Pressure	75.1. Refer to No/Less flow (pump failure)					
More	76. Higher Pressure	76.1. Inadvertent closure of valve on pump discharge line	76.1.1. Pressure build up in blocked outlet piping up to P3001 shut off pressure (estimated < 5 barg ). No impact on piping mechanical integrity (ANSI150)				



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (05) MDEA Storage tank and dosing

Intention: System used for periodical pure amine make up after weekly sampling (if make up is required)

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Level

Equipment: Amine IBC, P3001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	77. No/less Level	77.1. Unappropriate monitoring of level in IBC	77.1.1. Emptying of IBC during fresh amine transfer and potential damage to P3001 due to dry running, economical losses		11. Provide additional gauging system to monitor level inside amine IBC (e.g. pressure gauge on bottom outlet line to P3001 pump suction, etc.)	SIAD MI	
More	78. Higher Level	78.1. No causes identified					

Session: (2) 28/03/2023

Node: (05) MDEA Storage tank and dosing

Intention: System used for periodical pure amine make up after weekly sampling (if make up is required)

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Composition

Equipment: Amine IBC, P3001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	79. Different Composition	79.1. No additional causes identified					

Session: (2) 28/03/2023

Node: (05) MDEA Storage tank and dosing

Intention: System used for periodical pure amine make up after weekly sampling (if make up is required)

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Services / Utilities

Equipment: Amine IBC, P3001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	80. No Services / Utilities	80.1. No additional causes identified					



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Flow

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	81. No/less Flow (lean amine to TW1002) (cont.)	81.3. Unexpected closure of HV-138 on TW1002 inlet line	<p>81.3.1. Level build up in TW2008, overfilling is not expected since capacity of this equipment can accomodate overall amine inventory</p> <p>81.3.2. Level build up in TW2008 resulting in temperature build up on bottom section (&lt;150°C) with negligible impact on amine (degradation temperature around 180°C)</p> <p>81.3.3. Loss of lean amine supply to TW1002 and consequent inadequate CO2 removal and consequent CO2 slippage to cold box (see relevant node)</p> <p>81.3.4. Pressure build up on blocked in piping up to P-2005A/B shut-off pressure (approximately 52 barg). No impact on mechanical integrity of piping and equipment according to design criteria</p> <p>81.3.5. Potential damage to P-2005A/B overtime due to prolonged operation in blocked...</p>	<p>81.3.3.1. Discrepancy alarm on HVs</p> <p>81.3.3.2. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD</p> <p>81.3.5.1. PAH-201A/B</p> <p>81.3.5.2. Unit is located...</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 36 of 161

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Flow

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	81. No/less Flow (lean amine to TW1002) (cont.)	81.3. Unexpected closure of HV-138 on TW1002 inlet line (cont.)	...outlet condition resulting in economical losses/possible amine spillage and soil contamination	...inside curbed area with adequate impermeable material			
	82. No/less Flow (lean amine recirculation)	82.1. PCV-229 malfunction (close position)	82.1.1. Loss of lean amine filtration resulting in possible increasing foaming tendency in TW2008 and process upset	82.1.1.1. FAL-230 and operator response  82.1.1.2. Periodical sampling and availability of antifoaming agent			
		82.2. Plugging of cartridge filter F2002/F2003	82.2.1. Increased DP accross cartridge filter F2002/F2003 leading to cartridge damage overtime (minor economical losses)	82.2.1.1. PDAH-243			It's not credible plugging of carbon filter F2001
83. No/less Flow (Overhead circuit)	83.1. Malfunction of PIC-275 closing PV-275 on CO2 vent to thermal oxidizer	83.1.1. Pressure build up on TW2008 and S2011 (DP=2barg) leading to potential overpressurization overtime, mechanical damage and injuries to personnel  83.1.2. No impact on thermal oxidizer due to loss of CO2 vent...	83.1.1.1. PAHH-282 activate closure of FV-204  83.1.1.2. PSV-271 sized including this scenario	13. Add closure of LV-151 among actions initiated by PAHH-282  14. Investigate appropriate routing of PSV-271 (currently routed to atm at safe location) taking into account either potential presence of amine and requirements from national regulation	SIAD MI  SIAD MI / OGE		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 37 of 161

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Flow

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	83. No/less Flow (Overhead circuit) (cont.)	83.1. Malfunction of PIC-275 closing PV-275 on CO2 vent to thermal oxidizer (cont.)	...stream				
	84. No/less Flow (Bottom circuit)	84.1. Failure of pump P2012A/B	84.1.1. Level build up in S2011 leading to possible overfilling resulting in HW2010 flooding, loss of condensation and pressure build up on TW2008 and S2011 (DP=2barg) leading to potential ovepressurization overtime, damage and injuries to personnel	84.1.1.1. Discrepancy signal from on-duty P2012A/B starting stand-by pump  84.1.1.2. LAHH-279 activate closure of FV-204 (same action is initiated by PAHH-282)  84.1.1.3. PSV-271 sized including this scenario	15. Add closure of LV-151 among actions initiated by LAHH-279	SIAD MI	
		84.2. Malfunction of LIC-278 closing LV-278	84.1.2. Level build up in S2011 leading liquid carry over to thermal oxidizer KO drum with operational upset	84.1.2.1. Discrepancy signal from on-duty P2012A/B starting stand-by pump  84.1.2.2. LAHH-279 activate closure of FV-204	:See 15		
More	85. More Flow	85.1. Malfunction of FIC-227 to increase rpm of pump P2005A/B through relevant VFD	85.1.1. Increased recirculation flowrate for amine resulting in loss of efficiency in amine...	85.1.1.1. PAH-201A/B  85.1.1.2. AI-1012 to...			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Flow

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	85. More Flow (cont.)	85.1. Malfunction of FIC-227 to increase rpm of pump P2005A/B through relevant VFD (cont.)	...regeneration ultimately resulting in CO2 slippage to cold box (see relevant node)	...provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD			
Reverse	86. Reverse Flow	86.1. Failure of pump P2005A/B	86.1.1. Possible natural gas reverse flow from TW1002 (44barg) to TW2008 (DP=2barg) leading to pressure build up in stripping column, mechanical damage and potential for injuries to personnel including fire/explosion hazard	86.1.1.1. Discrepancy signal from on duty P2005A/B starting stand-by pump	16. Add dedicated interlock to shut down HV-138 in case of back flow due to both P2005A/B not running (e.g. high high pressure detected on common pump suction line)	SIAD MI	
		86.2. No causes identified for backflow on CO2 vent line to thermal oxidizer			17. Add additional check valve dissimilar type at lean amine injection line in TW1002	SIAD MI	
Misdirect	87. Misdirect Flow	87.1. Tube rupture in HW2009	87.1.1. LP steam enters the column TW2008 with pressure build up on TW2008 and S2011 (DP=2barg) leading to potential overpressurization overtime, mechanical damage and injuries to personnel	87.1.1.1. PAHH-282 activate closure of FV-204  87.1.1.2. PSV-271 sized including this scenario			
		87.2. Malfunction of LIC-202...	87.2.1. Level build up in S2011...	87.2.1.1. LAHH-279...			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 39 of 161

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Flow

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	87. Misdirect Flow (cont.)	...leading to unexpected opening of LV-291 on demi water supply to S2011	...leading to possible overfilling resulting in HW2010 flooding, loss of condensation and pressure build up on TW2008 and S2011 (DP=2barg) leading to potential overpressurization overtime, damage and injuries to personnel  87.2.2. Level build up in S2011 leading liquid carry over to thermal oxidizer KO drum with operational upset	...activate closure of LV-291 (same action is initiated by PAHH-282)  87.2.1.2. PSV-271 sized including this scenario  87.2.2.1. LAHH-279 activate closure of LV-291			

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Temperature

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	88. Lower Temperature	88.1. Malfunction of TIC-226 fully opening TV-226	88.1.1. Lower temperature of lean amine (minimum estimated 40°C instead of 50°C) to absorber TW-1002 resulting in slight loss of efficiency and CO2 minor slippage to cold box (less critical than other case)	88.1.1.1. Event detectable by TI-222  88.1.1.2. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2...			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 40 of 161

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Temperature

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	88. Lower Temperature (cont.)	<p>88.1. Malfunction of TIC-226 fully opening TV-226 (cont.)</p> <p>88.2. Malfunction of TIC-204 (or TIC-263)/FIC-204 closing FV-204 or any other cause for loss of LP steam to reboiler HW2009</p> <p>88.3. Malfunction of TIC-272 fully opening TV-272</p> <p>88.4. Malfunction of TI-203 to switch off H2001 or loss of electrical power to H2001</p> <p>88.5. Low ambient temperature</p>	<p>88.1.1. Lower temperature of lean amine (minimum estimated 40°C instead of 50°C) to absorber TW-1002 resulting in slight loss of efficiency and CO2 minor slippage to cold box (less critical than other case) (cont.)</p> <p>88.2.1. Inadequate stripping resulting in off spec lean amine to absorber TW-1002 resulting in loss of efficiency and CO2 slippage to cold box (See relevant node)</p> <p>88.3.1. Level build up in S2011 resulting in operational upset leading to slight reduction of amine with negligible impact</p> <p>88.4.1. Possible water condensation on CO2 vent stream to thermal oxidizer KO drum leading to minor operational upset</p> <p>88.5.1. Possible freezing of stagnant piping on condensate side</p>	<p>...concentration through ESD</p> <p>88.2.1.1. TAL-214 and operator response</p> <p>88.2.1.2. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD</p> <p>88.4.1.1. Discrepancy status of electrical heater reported to PLC</p> <p>88.5.1.1. Electrical tracing and insulation provided on condensate piping (electrical tracing also supplied by EDG)</p>	:See.8		



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Temperature

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	89. Higher Temperature	<p>89.1. Malfunction of TIC-226 closing TV-226</p> <p>89.2. Malfunction of TIC-204 (or TIC-263)/FIC-204 fully opening FV-204</p> <p>89.3. Higher temperature of LP steam from BL</p> <p>89.4. Malfunction of TIC-272 closing TV-272</p> <p>89.5. Malfunction of TI-203 to switch on H2001 when not required</p> <p>89.6. Blocked outlet condition...</p>	<p>89.1.1. Lean amine at 80 °C instead of 50°C routed to absorber TW-1002 leading to loss of efficiency and CO2 slippage to cold box (See relevant node)</p> <p>89.2.1. Increased vaporization in TW2008 leading to higher consumption of demi water with operational upset</p> <p>89.3.1. Higher temperature on HW2009 tubes resulting in potential increased amine degradation rate with operational upset overtime</p> <p>89.4.1. Loss of cooling water to condenser resulting in increased losses of water to thermal oxidizer KO drum leading to minor operational upset</p> <p>89.5.1. No impact during normal operation (maximum reachable temperature on CO2 vent stream is approximately 15 °C)</p> <p>89.6.1. Possible overheating of...</p>	<p>89.1.1.1. TAHH-222 activate closure of HV-105, HV-106</p> <p>89.1.1.2. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD</p> <p>89.3.1.1. TAHH-267 activate closure of FV-204</p> <p>89.4.1.1. Event detectable by FIQ-208</p> <p>89.6.1.1. TAHH-211...</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 42 of 161

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OT<sub>in</sub> = 121,1 °C; OT<sub>out</sub> = 79,83°C; HW2004 OT<sub>out</sub> = 50°C

P2005A/B: OP<sub>suction</sub> = 1,69 barg, OP<sub>discharge</sub> = 47,25 barg

HW2010: OT<sub>in</sub> = 112 °C; OT<sub>out</sub> = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Temperature

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	89. Higher Temperature (cont.)	...for CO2 vent gas stream (PV-275 closure)	...H2001 and piping (DT = 90°C) with potential mechanical damage and loss of containment of hot product with personnel injuries  89.6.2. Possible damage to thermal element of H2001 with consequent economical losses	...activate trip of heater H2001  89.6.2.1. TAHH-212 activate trip of first heater H2001 electrical bundle  89.6.2.2. TAHH-213 activate trip of second heater H2001 electrical bundle			

Session: (3) 29/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OT<sub>in</sub> = 121,1 °C; OT<sub>out</sub> = 79,83°C; HW2004 OT<sub>out</sub> = 50°C

P2005A/B: OP<sub>suction</sub> = 1,69 barg, OP<sub>discharge</sub> = 47,25 barg

HW2010: OT<sub>in</sub> = 112 °C; OT<sub>out</sub> = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Pressure

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	90. Lower Pressure	90.1. Refer to No/Less flow in this node  90.2. Malfunction of PIC-275 fully opening PV-275 on CO2 vent to thermal oxidizer	90.2.1. Pressure decrease in TW2008 from 0,9 barg to approximately atmospheric pressure leading to temperature...	90.2.1.1. TAL-214 and operator response  90.2.1.2. AI-1012 to...			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Pressure

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	90. Lower Pressure (cont.)	90.2. Malfunction of PIC-275 fully opening PV-275 on CO2 vent to thermal oxidizer (cont.)	...decrease and consequent inadequate stripping resulting in off spec lean amine to absorber TW-1002 resulting in loss of efficiency and CO2 slippage to cold box (See relevant node)	...provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD			
			90.2.2. Negligible impact on downstream equipment (thermal oxidizer)				
		90.3. Unit shut down and consequent equipment isolation	90.3.1. Possible vacuum condition in HW2009 steam side (shell side) with no impact in mechanical integrity according to design criteria (FV requirement)				
			90.3.2. According to presence of inert gas, no vacuum conditions are expected for stripper and condensate separator however all stripping sections are designed for FV				
More	91. Higher Pressure	91.1. Refer to gas breakthrough scenario in node #03					
		91.2. Refer to No/Less flow in this node					
		91.3. Refer to Reverse flow in this node					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Pressure

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	91. Higher Pressure (cont.)	<p>91.4. Malfunction of PCV-229 (fully open)</p> <p>91.5. Unexpected start up of stand-by P-2005A/B</p> <p>91.6. Unexpected start up of stand-by P-2012A/B</p> <p>91.7. External fire</p> <p>91.8. Trapped liquid on heat exchangers</p>	<p>91.4.1. Lean amine at 44 barg sent to F2001, F2002 and F2003 (DP = 8 barg) resulting in possible overpressurization, mechanical damage and injuries to personnel</p> <p>91.5.1. Transient pressure build up on P-2005A/B discharge below shut-off condition. Negligible impact</p> <p>91.6.1. Pressure build up on P-2012A/B discharge below shut-off condition (approximately 4 barg). No impact on mechanical integrity of piping according to design condition of piping (ANSI150). Possible transient operational upset</p> <p>:</p> <p>91.8.1. Thermal expansion leading to mechanical damage and consequent economical losses and potential minor injuries</p>	<p>91.4.1.1. PAH/PAHH-289 activate trip of P-2005A/B</p> <p>91.4.1.2. PSV-203 sized for this scenario</p> <p>:See 7</p> <p>91.8.1.1. PSV-294 to protect HW2004 cold side</p> <p>91.8.1.2. PSV-295 to protect HW2010 cold side</p> <p>91.8.1.3. PSV-193 to protect HW2007 cold side</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (06) MDEA stripping column

Intention: TW2008: OT ~ 111 °C

HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C

P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg

HW2010: OTin = 112 °C; OTout = 45 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Level

Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	92. No/less Level	<p>92.1. Loss of rich amine feed from flash vessel (Refer to No/Less flow in node #03)</p> <p>92.2. Malfunction of LIC-202/TIC-272 leading to reduced condensation rate in HW2010/inadequate demi water make-up through TV-291</p> <p>92.3. Malfunction of LIC-278 closing LV-278</p>	<p>92.2.1. Level decrease in TW2008 with loss of reach amine supply to stripping column resulting in loss of level and potential damage to P-2005A/B due to dry-running with potential localized NG leakage due to backflow from TW1002 resulting in possible fire and injuries to personnel</p> <p>92.3.1. Level decrease in S2011 and potential damage to P-2012A/B due to dry-running with consequent economical losses</p>	<p>92.2.1.1. LALL-209 activate trip of pump P-2005A/B and to close HV-138</p> <p>92.3.1.1. LALL-280 activate trip of pump P-2012A/B</p>	:See 16, 17		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023  
 Node: (06) MDEA stripping column  
 Intention: TW2008: OT ~ 111 °C  
 HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C  
 P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg  
 HW2010: OTin = 112 °C; OTout = 45 °C

**Notes:**

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15  
 Parameter: Composition  
 Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	93. Different Composition	93.1. No additional causes identified					

Session: (3) 29/03/2023  
 Node: (06) MDEA stripping column  
 Intention: TW2008: OT ~ 111 °C  
 HW2007: OTin = 121,1 °C; OTout = 79,83°C; HW2004 OTout = 50°C  
 P2005A/B: OPsuction = 1,69 barg, OPdischarge = 47,25 barg  
 HW2010: OTin = 112 °C; OTout = 45 °C

**Notes:**

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15  
 Parameter: Services / Utilities  
 Equipment: TW2008, HW2009, HW2010, S2011, P2012A/B, HW2007, P2005A/B, F2001, F2002, F2003

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	94. No Services / Utilities	94.1. Loss of power supply	94.1.1. Possible natural gas reverse flow from TW1002 (44barg) to TW2008 (DP=2barg) leading to pressure build up in stripping column, mechanical damage and potential for injuries to personnel including fire/explosion hazard		:See_16,_17		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Intention: OP = atm, OT = Ambient.

Notes: V3004 can collect the maximum capacity of one section (max inventory of amine in flash vessel). The vessel is used only for maintenance operation, during plant stop.

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Flow

Equipment: V3004, P3002

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	95. No/less Flow	95.1. Failure of pump P3002 when required in operation	95.1.1. Delay in maintenance operation with minor upset	95.1.1.1. Possibility to replace P3002 with P3001			
More	96. More Flow	96.1. Operator mistake starting simultaneous drainage of different equipment	96.1.1. Possible level increase in V3004 leading to possible overflowing and amine release from vent line with possible injuries to personnel/soil contamination	96.1.1.1. Specific maintenance procedures which foresees single drainage at once  96.1.1.2. LAH/LAHH-305 activate trip of pump P3002 (used for equipment drainage)  96.1.1.3. MDEA blowdown tank located inside curbed area with adequate impermeable material	18. Provide overflow line for V3004 discharging to ground (located below inlet nozzle of PSV header)	SIAD MI	
Reverse	97. Reverse Flow	97.1. Failure of pump P3002 during trasfer to truck	97.1.1. Possible reverse flow from truck to MDEA blow down tank with negligible impact (delay in operation). Overflowing is not expected according to tank elevation.		19. Add check valve on P3002 discharge line to truck loading (downstream recirculation line)	SIAD MI	
Misdirect	98. Misdirect Flow	98.1. Operator error to open recirculation line during truck loading operation  98.2. Inadvertent opening of valve X318 or valve passing	98.1.1. Slight delay in operation with negligible impact  98.2.1. Possible contamination of fresh amine and consequent operational upset		20. Specify NC valve X307 on IBC bottom	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 48 of 161

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Intention: OP = atm, OT = Ambient.

Notes: V3004 can collect the maximum capacity of one section (max inventory of amine in flash vessel). The vessel is used only for maintenance operation, during plant stop.

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Temperature

Equipment: V3004, P3002

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	99. Lower Temperature	99.1. Low ambient temperature	99.1.1. Potential for freezing of stagnant line leading to mechanical damage	99.1.1.1. Electrical tracing and insulation provided on amine piping and blowdown tank (electrical tracing also supplied by EDG)  99.1.1.2. Free draining requirement for MDEA PSV header	:See 8		
More	100. Higher Temperature	100.1. Operator mistake draining hot amine from TW2008 bottom (120 °C)	100.1.1. Possible overheating of V3004 (DT=60°C) resulting in mechanical damage and possible leakages (injuries to personnel/economical losses)	100.1.1.1. Specific drainage procedure which foresees adequate amine cooling before transfer to V3004  100.1.1.2. TAL-214 to give permission to pump P3002 to start only if temperature is adequate for transfer to blowdown tank	21. Relocate TAL to give permission to pump P3002 to start from TT-214 to TT-127  22. Review V3004 design temperature up to 100 °C	SIAD MI  SIAD MI	

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Intention: OP = atm, OT = Ambient.

Notes: V3004 can collect the maximum capacity of one section (max inventory of amine in flash vessel). The vessel is used only for maintenance operation, during plant stop.

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Pressure

Equipment: V3004, P3002

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	101. Lower Pressure	101.1. No causes identified for V3004 since open vented to atmosphere by 2" vent					
More	102. Higher Pressure	102.1. No causes identified for V3004 since open vented to atmosphere by 2" vent  102.2. Pump P3002 blocked outlet condition	102.2.1. Pressure built up on blocked in piping (including ...		23. Ensure that flexible hoses used for amine...	OGE (TBF)	



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 49 of 161

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Intention: OP = atm, OT = Ambient.

Notes: V3004 can collect the maximum capacity of one section (max inventory of amine in flash vessel). The vessel is used only for maintenance operation, during plant stop.

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Pressure

Equipment: V3004, P3002

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	102. Higher Pressure (cont.)	102.2. Pump P3002 blocked outlet condition (cont.)	...flexible hoses) up to pump shut-off pressure (approximately 4 barg). No impact on mechanical integrity of piping according to design criteria. Possible overpressurization of flexible hose resulting in amine solution leak and possible injuries to personnel/soil contamination		...transfer to truck have adequate design pressure to cope with shut-off pressure of P3002		

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Intention: OP = atm, OT = Ambient.

Notes: V3004 can collect the maximum capacity of one section (max inventory of amine in flash vessel). The vessel is used only for maintenance operation, during plant stop.

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Level

Equipment: V3004, P3002

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	103. No/less Level	103.1. Operator does not stop P3002 on low level in V3004 (including LT-305 failure)	103.1.1. Possible damage to P3002 due to dry running with minor economical losses and delay in operation	103.1.1.1. LALL-305 activate the trip of pump (not effective in case of LT-305 failure)  103.1.1.2. Event detectable by PI-306 (operator is in place during transfer)	24. Add a level gauge on V3004	SIAD MI	
More	104. Higher Level	103.2. Operator does not stop P3002 on low level in equipment under drainage  104.1. Refer to More flow in this node  104.2. Malfunction of LT-305 leading to inadequate transfer of collected amine	103.2.1. Possible damage to P3002 due to dry running with minor economical losses and delay in operation  104.2.1. Possible level increase in V3004 leading to possible overflowing and amine release from vent line with possible injuries...	103.2.1.1. Event detectable by PI-306 (operator is in place during transfer)  104.2.1.1. MDEA blowdown tank located inside curbed area with adequate impermeable material	:See 18, 24		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Intention: OP = atm, OT = Ambient.

Notes: V3004 can collect the maximum capacity of one section (max inventory of amine in flash vessel). The vessel is used only for maintenance operation, during plant stop.

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Level

Equipment: V3004, P3002

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	104. Higher Level (cont.)	104.2. Malfunction of LT-305 leading to inadequate transfer of collected amine (cont.)	...to personnel/soil contamination	104.2.1.1. MDEA blowdown tank located inside curbed area with adequate impermeable material (cont.)	:See_18, 24 (cont.)		

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Intention: OP = atm, OT = Ambient.

Notes: V3004 can collect the maximum capacity of one section (max inventory of amine in flash vessel). The vessel is used only for maintenance operation, during plant stop.

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Composition

Equipment: V3004, P3002

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	105. Different Composition	105.1. No causes identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023  
 Node: (08) Antifoam dosing package  
 Notes:  
 Drawings: 2220698-0C-10-001 Sh 3  
 Parameter: Flow

Intention:

Equipment: AF drum, P2013

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	106. No/less Flow	106.1. Failure of P2013 when required in operation	106.1.1. Loss/Inadequate antifoam agent injection on demand and consequent increased foaming tendency on liquid stream resulting in operational upset	106.1.1.1. Periodical sampling  106.1.1.2. Discrepancy alarm provided for pump P2013			
More	107. More Flow	107.1. Increased flowrate through P2013 due to malfunction/excessive amount injected due to operator mistake	107.1.1. Minor economical losses due to consumption/possible plugging of carbon filter guard F2001 overtime due to antifoam agent accumulation	107.1.1.1. Periodical sampling  107.1.1.2. PDAH-243			
Reverse	108. Reverse Flow	108.1. Failure of P2013 when required in operation	108.1.1. Backflow from P2005A/B suction to antifoam agent drum is not expected since diaphragm pump is selected and check valve is available				
Misdirect	109. Misdirect Flow	109.1. Operator error lining up wrong injection point	109.1.1. Negligible impact				

Session: (3) 29/03/2023  
 Node: (08) Antifoam dosing package  
 Notes:  
 Drawings: 2220698-0C-10-001 Sh 3  
 Parameter: Temperature

Intention:

Equipment: AF drum, P2013

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	110. Lower Temperature	110.1. Unavailability of antifoam belt drum heater  110.2. Low ambient temperature	110.1.1. Increased viscosity of antifoam agent and consequent possible inadequate injection of antifoam agent (see no/less flow but less critical)  110.2.1. Increased viscosity of antifoam agent and consequent possible inadequate injection of ...	110.1.1.1. Routine inspection  110.2.1.1. Electrical tracing and insulation provided on antifoam agent piping...	:See 8		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023  
 Node: (08) Antifoam dosing package  
 Notes:  
 Drawings: 2220698-0C-10-001 Sh 3  
 Parameter: Temperature

Intention:

Equipment: AF drum, P2013

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	110. Lower Temperature (cont.)	110.2. Low ambient temperature (cont.)	...antifoam agent (see no/less flow but less critical)	...(electrical tracing also supplied by EDG)	:See 8 (cont.)		
More	111. Higher Temperature	111.1. No causes identified					

Session: (3) 29/03/2023  
 Node: (08) Antifoam dosing package  
 Notes:  
 Drawings: 2220698-0C-10-001 Sh 3  
 Parameter: Pressure

Intention:

Equipment: AF drum, P2013

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	112. Lower Pressure	112.1. Refer to No/Less flow in this node					
More	113. Higher Pressure	113.1. Blocked outlet for P2013	113.1.1. Possible damage to pump (economical losses)/potential overpressurization of downstream piping resulting in mechanical damage and potential injuries to personnel	113.1.1.1. Specific procedure for line up of antifoam agent injection line	25. Add pressure relief device on P2013 discharge line, sized for blocked outlet scenario	SIAD MI	

Session: (3) 29/03/2023  
 Node: (08) Antifoam dosing package  
 Notes:  
 Drawings: 2220698-0C-10-001 Sh 3  
 Parameter: Level

Intention:

Equipment: AF drum, P2013

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	114. No/less Level	114.1. No cause identified					
More	115. Higher Level	115.1. No cause identified					

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
Facility: LNG liquefaction plant

Page: 53 of 161

Session: (3) 29/03/2023

Node: (08) Antifoam dosing package

Intention:

Notes:

Drawings: 2220698-0C-10-001 Sh 3

Equipment: AF drum, P2013

Parameter: Composition

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	116. Different Composition	116.1. No cause identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OTin = 25 °C, OTout = 10 °C

HX7000: OTin = 10 °C, OTout = -168 °C

V4003: OT= 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Flow

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	117. No/less Flow	<p>117.1. Loss of natural gas from upstream section (any cause)</p> <p>117.2. No causes identified for unexpected closure of HV-427 or HV-443 (FL valves managed by automatic sequence)</p> <p>117.3. No causes identified for plugging of dryer bed</p> <p>117.4. Plugging of F4005 overtime</p> <p>117.5. Unexpected closure of HV-700</p>	<p>117.1.1. No impact on this node</p> <p>117.4.1. Increased DP accross F4005 leading to operational upset on downstream section</p> <p>117.5.1. No impact on this node and upstream system (pressure build up is not expected, however all natural gas loop from metering station let down valve to JT valve PV-703 is designed at same value (52 barg))</p> <p>117.5.2. Loss of natural gas feed to cold box and associated equipment on cryogenic equipment (see node #11)</p>	<p>117.4.1.1. PDAH-473</p> <p>117.5.1.1. Discrepancy alarm on HVs</p> <p>117.5.1.2. PAL-703</p> <p>117.5.2.1. Discrepancy alarm on HVs</p> <p>117.5.2.2. PAL-703</p>			
More	118. More Flow	<p>118.1. Higher demand rate of natural gas (JT valve PV-703 malfunction)</p>	<p>118.1.1. Higher flowrate of gas through dryers and potential for inadequate humidity removal and consequent humidity carry over to downstream section with potential impact on cold box (see relevant nodes)</p>	<p>118.1.1.1. FIC-713 to limit natural gas flowrate</p> <p>118.1.1.2. FAH-600</p> <p>118.1.1.3. AI-1013A to provide a high H2O...</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OTin = 25 °C, OTout = 10 °C

HX7000: OTin = 10 °C, OTout = -168 °C

V4003: OT= 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Flow

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	118. More Flow (cont.)	118.1. Higher demand rate of natural gas (JT valve PV-703 malfunction) (cont.)	118.1.1. Higher flowrate of gas through dryers and potential for inadequate humidity removal and consequent humidity carry over to downstream section with potential impact on cold box (see relevant nodes) (cont.)	...concentration alarm and to close HV-700 on high high H2O concentration through ESD			
Reverse	119. Reverse Flow	119.1. No causes identified					
Misdirect	120. Misdirect Flow	120.1. Wrong position for any KV in the position between high pressure stream and low pressure stream	120.1.1. Natural gas in operating mode (44 barg, 20 °C) routed to equipment and piping under regeneration mode. No impact on mechanical integrity according to design criteria (all the loop is designed at same condition)				
			120.1.2. Natural gas in operating mode (44 barg, 20 °C) routed to NG regeneration module (16 barg) resulting in possible overpressurization, mechanical damage and natural gas leak (possible fire/explosion)	120.1.2.1. Valve is FC 120.1.2.2. KV is managed by automatic sequence including discrepancy alarm to freeze the sequence (manual/semi-automatic mode of operation to manage software is not allowed)			
				120.1.2.3. PAHH-528 activate closure of PV-527 (for depressurization circuit) or PAHH-531 activate closure of PV-527 (for regeneration circuit)			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OTin = 25 °C, OTout = 10 °C

HX7000: OTin = 10 °C, OTout = -168 °C

V4003: OT= 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Flow

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	120. Misdirect Flow (cont.)	120.1. Wrong position for any KV in the position between high pressure stream and low pressure stream (cont.)	120.1.2. Natural gas in operating mode (44 barg, 20 °C) routed to NG regeneration module (16 barg) resulting in possible overpressurization, mechanical damage and natural gas leak (possible fire/explosion) (cont.)  120.1.3. Partial loss of natural gas to regeneration/depressurization loop resulting in higher NG flowrate from BL leading to potential loss of efficiency in CO2 and humidity removal with consequent impact on cold box (see relevant node)	120.1.2.4. PSV-530 sized including this scenario  120.1.3.1. Valve is FC  120.1.3.2. KV is managed by automatic sequence including discrepancy alarm to freeze the sequence (manual/semi-automatic mode of operation to manage software is not allowed)  120.1.3.3. FAHH-600 activate closure of HV-600 and HV-602  120.1.3.4. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD  120.1.3.5. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration...			



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OT<sub>in</sub> = 25 °C, OT<sub>out</sub> = 10 °C

HX7000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = -168 °C

V4003: OT = 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Flow

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	120. Misdirect Flow (cont.)	<p>120.1. Wrong position for any KV in the position between high pressure stream and low pressure stream (cont.)</p> <p>120.2. Tube rupture in HW4002</p> <p>120.3. Unexpected opening of HV-705</p>	<p>120.1.3. Partial loss of natural gas to regeneration/depressurization loop resulting in higher NG flowrate from BL leading to potential loss of efficiency in CO<sub>2</sub> and humidity removal with consequent impact on cold box (see relevant node) (cont.)</p> <p>120.2.1. NG (44 barg) enters into HW4002 shell side (DP= 8 barg) and potential overpressurization on chilled water circuit resulting in mechanical damage and loss of containment of natural gas, potential fire/explosion and injuries to personnel due to mechanical damage</p> <p>120.3.1. Natural gas sent to cold flare with environmental concern</p> <p>120.3.2. Partial loss of natural gas to cold flare resulting in higher NG flowrate from BL leading to potential loss of efficiency in CO<sub>2</sub> and humidity removal with consequent impact on cold box (see relevant node)</p>	<p>...through ESD</p> <p>120.2.1.1. PSV-478 sized for this scenario (routed to cold flare)</p> <p>120.3.1.1. Discrepancy alarm on HVs</p> <p>120.3.1.2. PDAH-708 activate closure of HV-600 and HV-602</p> <p>120.3.2.1. Discrepancy alarm on HVs</p> <p>120.3.2.2. PDAH-708 activate closure of HV-600 and HV-602 (same actions activated by FAHH-600)</p>	<p>26. Specify FO valve HV-705 since it is blow down valve for emergency purposes</p>	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OTin = 25 °C, OTout = 10 °C

HX7000: OTin = 10 °C, OTout = -168 °C

V4003: OT= 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Flow

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	120. Misdirect Flow (cont.)	120.3. Unexpected opening of HV-705 (cont.)	120.3.2. Partial loss of natural gas to cold flare resulting in higher NG flowrate from BL leading to potential loss of efficiency in CO2 and humidity removal with consequent impact on cold box (see relevant node) (cont.)	120.3.2.3. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD  120.3.2.4. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD			

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OTin = 25 °C, OTout = 10 °C

HX7000: OTin = 10 °C, OTout = -168 °C

V4003: OT= 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Temperature

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	121. Lower Temperature	121.1. No causes identified					
More	122. Higher Temperature	122.1. Loss of chilled water to HW4002	122.1.1. Natural gas routed to downstream equipment at 25°C instead of 10°C resulting in reduction of efficiency in liquefaction process	122.1.1.1. TI-485	27. Add a high temperature alarm on TI-485	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OTin = 25 °C, OTout = 10 °C

HX7000: OTin = 10 °C, OTout = -168 °C

V4003: OT= 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Pressure

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	123. Lower Pressure	123.1. Refer to No/Less flow in this node  123.2. Low pressure from upstream sections (any cause)	123.2.1. Loss of efficiency in humidity removal resultin in humidity carry over to downstream section (cold box, see relevant node)	123.2.1.1. PALL-449 activate closure HV-105, HV-106  123.2.1.2. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD			
More	124. Higher Pressure	124.1. PCV-700 malfunction (fully open)  124.2. Trapped chilled water in HW4002 shell side	124.1.1. Higher pressure of natural gas routed to analyser (44 barg instead of 1 barg) with potential overpressurization of analysers (AI-1013A, 1012) and associated items (DP= 0.5 barg) with mechanical damage and potential injuries to personnel  124.2.1. Thermal expansion of trapped chilled water resulting in mechanical damage and economical losses	124.2.1.1. PSV-478 sized for this scenario	28. Ensure provision for pressure release devices to protect analysers AI-1013A, 1012 and associated items in case of wide opening of pressure let down valve PCV-700	SIAD MI	

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OTin = 25 °C, OTout = 10 °C

HX7000: OTin = 10 °C, OTout = -168 °C

V4003: OT= 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Level

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	125. No/less Level	125.1. Not applicable					
More	126. Higher Level	126.1. Not applicable					

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Intention: HW4002: OTin = 25 °C, OTout = 10 °C

HX7000: OTin = 10 °C, OTout = -168 °C

V4003: OT= 25 °C

Notes: The process includes 8 h of operation and 8 h of bed regeneration (composed by following phases: heating, cooling, pressurization and depressurization)

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Composition

Equipment: V4003, F4005, HW4002, HX7000, HX7001

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	127. Different Composition	127.1. By-pass line left open after maintenance on filter F4005	127.1.1. Possible dust carry over in the downstream section resulting in increased DP on downstream equipment with operational upset	127.1.1.1. Event detectable by PDI-473			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 61 of 161

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	128. No/less Flow (regeneration gas supply line)	128.1. FIC-461 malfunction closing FV-461 or closure of any KV on regeneration gas loop	128.1.1. Inadequate regeneration resulting in possible slippage of humidity when dryer is put back in service with possible impact on cold box (see relevant node)  128.1.2. Possible overheating of H4006 and piping (DT = 350°C) with potential mechanical damage and loss of containment of natural gas product with personnel injuries/fire explosion hazard  128.1.3. Possible damage to thermal element of H4006 with consequent economical losses  128.1.4. Loss of suction feed NG regeneration compressor C5500 resulting in possible mechanical damage and economical losses	128.1.1.1. PDAL-481  128.1.1.2. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD  128.1.2.1. PDALL-481 activate shut-down H4006  128.1.2.2. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)  128.1.3.1. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)  128.1.4.1. Recirculating by-pass through PV-505 sized to cope with this scenario  128.1.4.2. PALL-510 activate trip of compressor C5500			
	129. No/less Flow (regeneration gas stream)	129.1. Unexpected closure of TV-530A	129.1.1. Inadequate regeneration resulting in possible slippage of humidity when dryer is put back...	129.1.1.1. PDAL-481  129.1.1.2. AI-1013A to...			Continuous stream from flash vessel is still available to avoid vacuum condition on compressor suction line

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	129. No/less Flow (regeneration gas stream) (cont.)	129.1. Unexpected closure of TV-530A (cont.)	...in service with possible impact on cold box (see relevant node)	...provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD			
			129.1.2. Possible overheating of H4006 and piping (DT = 350°C) with potential mechanical damage and loss of containment of natural gas product with personnel injuries/fire explosion hazard	129.1.2.1. PDALL-481 activate shut-down H4006  129.1.2.2. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)			
			129.1.3. Possible damage to thermal element of H4006 with consequent economical losses	129.1.3.1. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)			
			129.1.4. Loss of suction feed NG regeneration compressor C5500 resulting in possible mechanical damage and economical losses	129.1.4.1. Recirculating by- pass through PV-505 sized to cope with this scenario  129.1.4.2. PALL-510 activate trip of compressor C5500			
		129.2. Unexpected closure of HV-532 or malfunction of LI-530 closing DV-532	129.2.1. Condensate accumulation in ST5000 leading to level build up and liquid carry over to compressor and potential for mechanical damage leading to economical losses	129.2.1.1. LAHH-531 activate closure of TV-530A  129.2.1.2. LAHH-500B activate trip of compressor and close HV-500			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	130. No/less Flow (depressurization stream)	130.1. Unexpected closure of HV-525 or PV-527 or HV-525 not opening on demand including PT-525 malfunction	130.1.1. Inadequate depressurization of dryer under depressurization leading to freezing of sequence. Possible operational upset overtime (need to shut-down unit after 8 hours)	130.1.1.1. Inconsistent condition alarms generated by sequence (PT- 439,440,441)			
			130.1.2. No impact expected on compressor C5500				
	131. No/less Flow (compressor suction)	131.1. Unexpected closure of HV-500	131.1.1. Inadequate regeneration resulting in possible slippage of humidity when dryer is put back in service with possible impact on cold box (see relevant node)	131.1.1.1. PDAL-481  131.1.1.2. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD			
			131.1.2. Possible overheating of H4006 and piping (DT = 350°C) with potential mechanical damage and loss of containment of natural gas product with personnel injuries/fire explosion hazard	131.1.2.1. PDALL-481 activate shut-down H4006  131.1.2.2. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)			
			131.1.3. Possible damage to thermal element of H4006 with consequent economical losses	131.1.3.1. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)			
			131.1.4. Loss of suction feed...	131.1.4.1. Recirculating...			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	131. No/less Flow (compressor suction) (cont.)	131.1. Unexpected closure of HV-500 (cont.)  131.2. Potential plugging of strainer K500NG  131.3. Unexpected compressor stop (any cause)	...NG regeneration compressor C5500 resulting in possible mechanical damage and economical losses  131.1.5. Vacuum condition on compressor suction with no impact on mechanical integrity according to design criteria (FV)  131.2.1. Decrease in compressor efficiency and consequent operational upset  131.3.1. Inadequate regeneration resulting in possible slippage of humidity when dryer is put back in service with possible impact on cold box (see relevant node)  131.3.2. Possible overheating of H4006 and piping (DT = 350°C) with potential mechanical damage and loss of containment of natural gas product with personnel...	...by-pass through PV-505 sized to cope with this scenario  131.1.4.2. PALL-510 activate trip of compressor C5500  131.2.1.1. Differential pressure gauge provided for K500NG (see dedicated P&ID for compressor C5500)  131.3.1.1. PDAL-481  131.3.1.2. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD  131.3.2.1. PDALL-481 activate shut-down H4006  131.3.2.2. TAHH-466/467 activate trip of heater...			



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OTin = 0,9 °C , OTout = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OTin = 10 °C, OTout = 35 °C

C5500: OPsuction = 2,55 barg , OPdischarge = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES	
No/less (cont.)	131. No/less Flow (compressor suction) (cont.)	131.3. Unexpected compressor stop (any cause) (cont.)	...injuries/fire explosion hazard	...H4006 (same actions activated by TAHH-469)				
			131.3.3. Possible damage to thermal element of H4006 with consequent economical losses	131.3.3.1. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)				
	132. No/less Flow (compressor discharge)	131.4. Malfunction of PIC-500 reducing speed of compressor motor	131.4.1. See consequences for stop of compressor but less critical					
		132.1. Plugging of compressor post filter F5501	132.1.1. Increased DP accross filter with operational upset	132.1.1.1. Differential pressure gauge provided for F5501 (see dedicated P&ID for compressor C5500)				
		132.2. Unexpected closure of HV-504	132.2.1. See consequences of unexpected closure of HV-500 for impact on upstream section					
			132.2.2. Pressure build up on compressor discharge system (DP=49 barg) and possible overpressurization leading to mechanical damage, loss of containment, potential for fire/explosion, injuries to personnel	132.2.2.1. PIC-504 to open PV-505  132.2.2.2. PAHH-511 activate trip of compressor  132.2.2.3. PSV-503			Each stage is provided with PSV sized for blocked outlet (PSV-501/502) and high high pressure interlock (PAHH-501/502)	
		132.3. Unexpected closure of HV-511	132.3.1. Unavailability of bleed valve on demand		29. Specify HV-511 as FO valve	SIAD MI		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 66 of 161

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	133. More Flow	<p>133.1. Malfunction of FIC-461 fully opening FV-461</p> <p>133.2. Malfunction of PIC/HIC-525 opening PV-525 more than required</p>	<p>133.1.1. Increased flowrate through H4006 leading to possible inadequate heating up of regeneration gas resulting in potential uncomplete regeneration (possible humidity slippage when the dryer is put back in service and impact on cold box, see relevant node)</p> <p>133.1.2. Pressure build up on C5500 suction resulting in possible mechanical damage and economical losses</p> <p>133.2.1. Excessive depressurization rate for involved dryer resulting in possible reduction in lifetime of internals of absorption bed with economical losses</p> <p>133.2.2. Pressure build up on C5500 suction resulting in possible mechanical damage and economical losses</p>	<p>133.1.1.1. TAL-483</p> <p>133.1.1.2. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD</p> <p>133.1.2.1. PAH-531, PAH-500</p> <p>133.1.2.2. PAHH-510 activate trip of compressor</p> <p>133.1.2.3. PAHH-531 activate closure of TV-530A</p> <p>133.2.1.1. PAH-528</p> <p>133.2.2.1. PAH-500</p> <p>133.2.2.2. PAHH-510 activate trip of compressor</p> <p>133.2.2.3. PAHH-528 activate closure of PV-527</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	133. More Flow (cont.)	133.3. Malfunction of compressor control (PIC-500) system increasing motor speed through VFD	133.3.1. No impact on upstream section  133.3.2. Lower pressure on compressor suction side with possible compressor motor overload leading to damage to motor (economical losses)	133.3.2.1. Overload protection for compressor motor activate trip of compressor motor  133.3.2.2. PALL-510 activate trip of compressor motor			
Reverse	134. Reverse Flow	134.1. Compressor trip/stop (any cause)	134.1.1. Reverse flow from compressor discharge system (43 barg) toward compressor suction side (DP=8 barg for ST5000 and HW5000) has not been considered a credible scenario since compressor is reciprocating type and any cause of compressor trip/stop will lead to closure of HV-504, HV-500 and opening HV-505 (by-bass line through PV-505 is normally closed during normal operation)				
Misdirect	135. Misdirect Flow	135.1. Unexpected opening of HV-455/HV-535	135.1.1. Natural gas sent to cold flare with environmental concern	135.1.1.1. HV-455/HV-535 is FC and managed by depressurization/purging sequence  135.1.1.2. Discrepancy alarm on HVs			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 68 of 161

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OTin = 0,9 °C , OTout = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OTin = 10 °C, OTout = 35 °C

C5500: OPsuction = 2,55 barg , OPdischarge = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	135. Misdirect Flow (cont.)	<p>135.1. Unexpected opening of HV-455/HV-535 (cont.)</p> <p>135.2. Unexpected opening of HV-464</p> <p>135.3. Unexpected opening of HV-539</p>	<p>135.1.2. Loss of suction feed NG regeneration compressor C5500 resulting in possible mechanical damage and economical losses</p> <p>135.2.1. Limited amount of natural gas sent to cold flare (amount involved in depressurization) with minor environmental concern</p> <p>135.3.1. Nitrogen entrainment on depressurization gas stream routed to compressor suction side with increased content of nitrogen in process flow (minor operational upset)</p> <p>135.3.2. Nitrogen entrainment on depressurization gas stream with pressure build up on C5500 suction resulting in possible mechanical damage and...</p>	<p>135.1.2.1. HV-455/HV-535 is FC and managed by depressurization/purging sequence</p> <p>135.1.2.2. Recirculating by-pass through PV-505 sized to cope with this scenario</p> <p>135.1.2.3. PALL-510 activate trip of compressor C5500</p> <p>135.2.1.1. HV-464 is FC and managed by depressurization/purging sequence</p> <p>135.2.1.2. Discrepancy alarm on HVs</p> <p>135.3.1.1. Discrepancy alarm on HVs</p> <p>135.3.2.1. HV-539 is FC and managed by depressurization/purging sequence</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	135. Misdirect Flow (cont.)	135.3. Unexpected opening of HV-539 (cont.)	...economical losses	135.3.2.2. Discrepancy alarm on HVs  135.3.2.3. PAH-500  135.3.2.4. PAHH-510 activate trip of compressor C5500			
		135.3.3. After compressor shut down pressure build up (OP <sub>of</sub> nitrogen =9barg) on blocked in suction system (DP=10 barg) with no mechanical impact  135.3.4. Nitrogen at 9 barg routed to flash vessel S1003 with no impact on mechanical integrity according to design criteria (DP=10 barg for vessel and 16 barg for associated piping)	135.3.3. After compressor shut down pressure build up (OP <sub>of</sub> nitrogen =9barg) on blocked in suction system (DP=10 barg) with no mechanical impact  135.3.4. Nitrogen at 9 barg routed to flash vessel S1003 with no impact on mechanical integrity according to design criteria (DP=10 barg for vessel and 16 barg for associated piping)				
		135.4. Unexpected opening of TV-530B	135.4.1. During dryer heating mode, higher temperature of natural gas to downstream section (220°C instead of 10°C) due to by-pass of HW5000, with possible overheating (DT=65°C for EW5000) resulting in mechanical damage and possible leak of natural gas with possible fire		30. Add a high high temperature interlock initiated by TI-535 to close TV-530B	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	135. Misdirect Flow (cont.)	135.5. Tube rupture in HW5000	135.5.1. Chilled water (OP approximately 3 barg) enters into regeneration gas stream with possible liquid accumulation on ST5000 leading to level build up and liquid carry over to compressor and potential for mechanical damage leading to economical losses  135.5.2. In case of possible natural gas entrainment in chilled water circuit no significant consequences are expected during normal operation; accumulation of natural gas can lead to potential exposure of maintenance operator to flammable mixture	135.5.1.1. LAHH-500B activate trip of compressor and close HV-500			
		135.6. Unexpected opening of HV-505	135.6.1. Natural gas sent to cold flare with environmental concern  135.6.2. Loss of regeneration gas stream to natural gas feed stream with no impact	135.6.1.1. Discrepancy alarm on HVs	31. Maintenance procedure for chilled water circuit shall include actions and safeguards to avoid personnel exposure to natural gas possibly present	OSE (TZSA)	
		135.7. Inadvertent opening of separators drain valve	135.7.1. Potential operational upset due to unexpected trip of compressor due to PALL intervention/leakage of NG and potential for personnel exposure to fire/explosion hazards		32. Specify manual valves on recycle gas compressor separators drains as LC	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 71 of 161

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	135. Misdirect Flow (cont.)	135.8. Malfunction of PIC-500/PIC-504 opening PV-505 when not required	135.8.1. Pressure build up on C5500 suction (DP=6 barg) resulting in possible overpressurization leading to mechanical damage, loss of containment, potential for fire/explosion, injuries to personnel	135.8.1.1. PAHH-510 activate trip of compressor			

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Temperature

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	136. Lower Temperature	136.1. Failure of H4006 including TI-483 malfunction	136.1.1. Lower temperature of regeneration gas leading to inadequate regeneration resulting in possible slippage of humidity when dryer is put back in service with possible impact on cold box (see relevant node)	136.1.1.1. Discrepancy alarm provided by sequence if required temperature is not reached at the end of heating phase (TI-430-438)  136.1.1.2. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration...			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 72 of 161

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Temperature

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	136. Lower Temperature (cont.)	<p>136.1. Failure of H4006 including TI-483 malfunction (cont.)</p> <p>136.2. TV-530B does not open on demand including TAL-532 malfunction</p> <p>136.3. Loss of steam to EW5000 including TIC-555 malfunction closing TV-555</p> <p>136.4. Low ambient temperature</p>	<p>136.1.1. Lower temperature of regeneration gas leading to inadequate regeneration resulting in possible slippage of humidity when dryer is put back in service with possible impact on cold box (see relevant node) (cont.)</p> <p>136.2.1. Possible freezing of collected water in ST5000 resulting in possible damage of associated items (e.g. bottom drain valve) with no safety concern</p> <p>136.3.1. Regeneration gas routed to compressor C5500 at 10°C instead of 35°C with possible minor operational upset due to unstable operation conditions for compressor</p> <p>136.3.2. Possible freezing on water bath in EW5000 resulting in possible damage (economical losses)</p> <p>136.4.1. Possible freezing of stagnant piping on water side</p>	<p>...through ESD</p> <p>136.2.1.1. Gas is passing through HW5000 (operated with chilled water at 5°C)</p> <p>136.2.1.2. Electrical tracing provided for ST5000 and bottom drain lines</p> <p>136.3.1.1. TALL-535 activate closure of PV-527, TV-530A, TV-530B</p> <p>136.3.2.1. TALL-556 activate closure of PV-527, TV-530A, TV-530B</p> <p>136.4.1.1. Electrical tracing and insulation provided on water piping (electrical...</p>			<p>Low temperature scenario is expected only in the beginning of heating phase for limited period of time (few minutes)</p> <p>Low temperature scenario is expected only in the beginning of heating phase for limited period of time (few minutes)</p>
					:See 8		



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Temperature

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	136. Lower Temperature (cont.)	136.4. Low ambient temperature (cont.)	136.4.1. Possible freezing of stagnant piping on water side (cont.)	...tracing also supplied by EDG)	:See.8 (cont.)		
More	137. Higher Temperature	137.1. See no/less flow (overheating of H4006)  137.2. Failure of TI-483 leading to higher heat input in H4006  137.3. Inadequate cooling of dryer after regeneration (KV failure in close position)	137.2.1. Possible overheating of H4006 and piping (DT = 350°C) with potential mechanical damage and loss of containment of natural gas product with personnel injuries/fire explosion hazard  137.2.2. Possible damage to thermal element of H4006 with consequent economical losses  137.3.1. When dryer is put back in service transient higher temperature of process gas to downstream unit is expected with potential operational upset/thermal stress for HX-7000	137.2.1.1. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)  137.2.2.1. TAHH-466/467 activate trip of heater H4006 (same actions activated by TAHH-469)  137.3.1.1. KV is managed by automatic sequence including discrepancy alarm (on temperature, time and on valve position) to freeze the sequence (manual/semi-automatic mode of operation to manage software is not allowed)  137.3.1.2. TAHH-701 to activate closure of HV-700			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Temperature

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	137. Higher Temperature (cont.)	<p>137.3. Inadequate cooling of dryer after regeneration (KV failure in close position) (cont.)</p> <p>137.4. See misdirected flow (opening of TV-530B)</p> <p>137.5. Loss of chilled water supply to HW5000</p> <p>137.6. Malfunction of TIC-555 fully opening TV-555</p>	<p>137.3.2. When dryer is put back in service transient higher temperature of process gas to downstream unit and potential overheating of F4005 (DT=100°C) resulting in mechanical damage and possible leak of natural gas with possible fire</p> <p>137.5.1. During dryer heating mode, higher temperature of natural gas to downstream section (220°C instead of 10°C) with possible overheating (DT=65°C for EW5000) resulting in mechanical damage and possible leak of natural gas with possible fire</p> <p>137.6.1. Higher temperature (up to 100°C) of regeneration gas to compressor resulting in possible overheating of EW5000 process gas coils (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire</p>	<p>137.3.2.1. KV is managed by automatic sequence including discrepancy alarm (on temperature, time and on valve position) to freeze the sequence (manual/semi-automatic mode of operation to manage software is not allowed)</p> <p>137.5.1.1. TAHH-532 activate closure of TV-530A</p>	<p>33. Review design temperature of EW5000 process gas coils up to 100°C</p>	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Temperature

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	137. Higher Temperature (cont.)	137.7. Loss of cooling water to HW5501	137.7.1. Higher temperature of natural gas to second stage of compressor resulting in potential damage to internals and consequent economical losses	137.7.1.1. TAHH-502 activate trip of compressor			
		137.8. Loss of cooling water to HW5502	137.8.1. Higher temperature of natural gas to third stage of compressor resulting in potential damage to internals and consequent economical losses	137.8.1.1. TAHH-503 activate trip of compressor			
		137.9. Loss of cooling water to HW5503	137.9.1. Higher temperature of natural gas (estimated approximately 137°C) on equipment and piping on third stage discharge downstream aftercooler (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire  137.9.2. No impact on natural gas feed due to increased temperature of recycled gas stream due to limited flowrate from compressor		34. Add a high high temperature interlock downstream HW5503 to activate trip of compressor C5500	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 76 of 161

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Pressure

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	138. Lower Pressure	138.1. Rerer to No/Less and Misdirect Flow  138.2. Shut down of steam supply to EW5000 coil	138.2.1. Possible vacuum condition with no impact on mechanical integrity according to design criteria				
More	139. Higher Pressure	139.1. Refer to No/Less and Misdirect Flow  139.2. Trapped chilled water in HW5000 shell side	139.2.1. Thermal expansion of trapped chilled water resulting in mechanical damage and economical losses	139.2.1.1. PSV-550 sized for this scenario			

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Level

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	140. No/less Level	140.1. Malfunction of LIC-530 not closing DV-532 on demand	140.1.1. Natural gas at 2 barg routed to S2011 with no impact on mechanical integrity according to design criteria (DP=2 barg)				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OTin = 0,9 °C , OTout = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OTin = 10 °C, OTout = 35 °C

C5500: OPsuction = 2,55 barg , OPdischarge = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Level

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	140. No/less Level (cont.)	<p>140.1. Malfunction of LIC-530 not closing DV-532 on demand (cont.)</p> <p>140.2. Malfunction of LSL-545 not opening LV-545 on demand</p> <p>140.3. Malfunction of LIC-500A not closing DV-500 on demand</p>	<p>140.1.2. Partial loss of regeneration gas to S2011 and in turns to thermal oxidizer through PV-275 with minor economical losses</p> <p>140.1.3. Partial loss of regeneration gas to S2011 resulting in reduced flowrate to compressor leading to partial loss of suction feed NG regeneration compressor C5500 with possible mechanical damage and economical losses</p> <p>140.2.1. Inadequate water make up to EW5000 leading to loss of level and consequent loss of duty to regeneration gas stream (see lower temperature due to loss of steam to EW5000)</p> <p>140.3.1. Natural gas at 2 barg routed to S2011 with no impact on mechanical integrity according to design criteria (DP=2 barg)</p> <p>140.3.2. Partial loss of regeneration gas to S2011 and in turns to thermal oxidizer through PV-275 with minor economical...</p>	<p>140.1.2.1. LALL-531 activate closure of HV-532</p> <p>140.1.3.1. LALL-531 activate closure of HV-532</p> <p>140.1.3.2. Recirculating by-pass through PV-505 sized to cope with this scenario</p> <p>140.1.3.3. PALL-510 activate trip of compressor C5500</p> <p>140.2.1.1. TAL-535</p> <p>140.3.2.1. LALL-500B activate closure of HV-515</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Level

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	140. No/less Level (cont.)	140.3. Malfunction of LIC-500A not closing DV-500 on demand (cont.)	...losses  140.3.3. Partial loss of regeneration gas to S2011 resulting in reduced flowrate to compressor leading to partial loss of suction feed NG regeneration compressor C5500 with possible mechanical damage and economical losses	140.3.2.1. LALL-500B activate closure of HV-515 (cont.)  140.3.3.1. LALL-500B activate closure of HV-515  140.3.3.2. Recirculating by- pass through PV-505 sized to cope with this scenario  140.3.3.3. PALL-510 activate trip of compressor C5500			
		140.4. Malfunction of LIC-501A not closing DV-501 on demand	140.4.1. Natural gas at 4.9 barg routed to S2011 (DP=2 barg) with pressure build up, potential overpressurization resulting in mechanical damage and possible leak of natural gas with possible fire  140.4.2. No impact on compressor	140.4.1.1. LALL-501B activate closure of HV-515	35. Investigate additional safeguard to prevent overpressurization in S2011 in case of gas breakthrough from C5500 compressor separators (e.g. PSV routed to cold flare located downstream HV-515, additional PAHH on drain line to S2011 acting on additional on/off valve etc..)	SIAD MI	
		140.5. Malfunction of LIC-502A not closing DV-502 on demand	140.5.1. Natural gas at 15 barg routed to S2011 (DP=2 barg)...	140.5.1.1. LALL-502B activate closure of HV-515	:See.35		

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Level

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	140. No/less Level (cont.)	140.5. Malfunction of LIC-502A not closing DV-502 on demand (cont.)	...with pressure build up, potential overpressurization resulting in mechanical damage and possible leak of natural gas with possible fire	140.5.1.1. LALL-502B activate closure of HV-515 (cont.)	:See.35 (cont.)		
		140.6. Malfunction of LIC-503A not closing DV-503 on demand	140.5.2. No impact on compressor				
			140.6.1. Natural gas at 43 barg routed to S2011 (DP=2 barg) with pressure build up, potential overpressurization resulting in mechanical damage and possible leak of natural gas with possible fire	140.6.1.1. LALL-503B activate closure of HV-515	:See.35		
			140.6.2. No impact on compressor				
More	141. Higher Level	141.1. See No/Less and Misdirect Flow for level build up in ST5000					
		141.2. Malfunction of LSH-545 opening LV-545 when not required	141.2.1. Level build up in EW5000 resulting in overfilling and water carry over to drain collection pit at grade. Waste of water with no impact on personnel safety	141.2.1.1. TAL-556			
			141.2.2. Level build up in EW5000 resulting in overfilling...	141.2.2.1. TAL-535/TAL- 556			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OTin = 0,9 °C , OTout = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OTin = 10 °C, OTout = 35 °C

C5500: OPsuction = 2,55 barg , OPdischarge = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Level

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	141. Higher Level (cont.)	141.2. Malfunction of LSH-545 opening LV-545 when not required (cont.)	...and continuous water circulation through overflow line leading to lower temperature of recycling gas to compressor (see low temperature for loss of steam but less critical)	141.2.2.1. TAL-535/TAL-556 (cont.)			
		141.3. Malfunction of LIC-500A not opening DV-500 on demand	141.3.1. Condensate accumulation in ST5500 leading to level build up and possible liquid carry over to compressor first stage and potential for mechanical damage leading to economical losses	141.3.1.1. LAHH-500B activate trip of compressor and close HV-500			
		141.4. Malfunction of LIC-501A not opening DV-501 on demand	141.4.1. Condensate accumulation in ST5501 leading to level build up and possible liquid carry over to compressor second stage and potential for mechanical damage leading to economical losses	141.4.1.1. LAHH-501B activate trip of compressor and close HV-500			
		141.5. Malfunction of LIC-502A not opening DV-502 on demand	141.5.1. Condensate accumulation in ST5502 leading to level build up and possible liquid carry over to compressor third stage and potential for mechanical damage leading to economical losses	141.5.1.1. LAHH-502B activate trip of compressor and close HV-500			
		141.6. Malfunction of LIC-503A not opening DV-503 on demand	141.6.1. Condensate accumulation in ST5503 leading...				



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Level

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	141. Higher Level (cont.)	141.6. Malfunction of LIC-503A not opening DV-503 on demand (cont.)	...to level build up and possible liquid carry over to natural gas feed with negligible impact  141.6.2. In case compressor is operated in recycling mode (e.g. start up operation) possible condensate accumulation in ST5503 leading to level build up and possible liquid carry over to compressor first stage through PV-505 and potential for mechanical damage leading to economical losses	141.6.2.1. LAHH-503B activate trip of compressor			

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OT<sub>in</sub> = 0,9 °C , OT<sub>out</sub> = 250 °C

V4005: OT = 250 / 10 °C

EW5000: OT<sub>in</sub> = 10 °C, OT<sub>out</sub> = 35 °C

C5500: OP<sub>suction</sub> = 2,55 barg , OP<sub>discharge</sub> = 44,5 barg

V4004: OT = 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Composition

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	142. Different Composition	142.1. By-pass of NG regeneration gas compressor post-filter F5501 left open after maintenance	142.1.1. Possible carry over of piston ring wear material to NG feed with negligible impact				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Intention: H4006: OTin = 0,9 °C , OTout = 250 °C

V4005: OT= 250 / 10 °C

EW5000: OTin = 10 °C, OTout = 35 °C

C5500: OPsuction = 2,55 barg , OPdischarge = 44,5 barg

V4004: OT= 25 °C

Notes:

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Services / Utilities

Equipment: H4006, V4004, V4005, HW5000, ST5000, EW5000, C5500

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	143. No Services / Utilities	143.1. No additional cause identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (11) LNG separator

Intention: S7003: OT = -166,53 °C

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70

Parameter: Flow

Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	144. No/less Flow	<p>144.1. No/Less flow from upstream section</p> <p>144.2. Malfunction of FIC-713 closing FV-713</p> <p>144.3. Malfunction of PIC-703 closing PV-703 (JT valve)</p> <p>144.4. Malfunction of PIC-715A closing PV-715</p>	<p>144.1.1. No impact on this node</p> <p>144.2.1. No impact on this node and upstream system (pressure build up is not expected, however all natural gas loop from metering station let down valve to JT valve PV-703 is designed at same value (52 barg))</p> <p>144.2.2. Loss of LNG production and potential interruption of truck loading operation</p> <p>144.3.1. No impact on this node and upstream system (pressure build up is not expected, however all natural gas loop from metering station let down valve to JT valve PV-703 is designed at same value (52 barg))</p> <p>144.3.2. Loss of LNG production and potential interruption of truck loading operation</p> <p>144.4.1. Inadequate displacement of not condensable gas and consequent accumulation resulting in pressure build up in LNG separator S7003 (DP=16 barg) leading to potential overpressurization, mechanical damage and potential for LNG leakages inside the cold box...</p>	<p>144.2.2.1. LI-1901A/B on LNG storage tank including low level alarms</p> <p>144.3.2.1. LI-1901A/B on LNG storage tank including low level alarms</p> <p>144.4.1.1. PAHH-717 activate closure of HV-700</p> <p>144.4.1.2. PSV-705 sized including this scenario</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (11) LNG separator

Intention: S7003: OT = -166,53 °C

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70

Parameter: Flow

Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	144. No/less Flow (cont.)	144.4. Malfunction of PIC-715A closing PV-715 (cont.)	...with release of NG to atmosphere through cold box vent valve (no impact on personnel expected since breathing valve vent located at safe location). Possible operational disruption due to equipment damage and prolonged maintenance operation	144.4.1.2. PSV-705 sized including this scenario (cont.)			
			144.4.2. Inadequate displacement of not condensable gas and consequent accumulation resulting in pressure build up in LNG separator S7003 (DP=16 barg) leading to potential overpressurization, mechanical damage and potential for LNG leakages inside the cold box with potential cold box overpressurization, mechanical damage and injuries to personnel (fire/explosion hazard)	144.4.2.1. PAHH-717 activate closure of HV-700  144.4.2.2. PSV-705 sized including this scenario  144.4.2.3. Overpressure device provided on cold box			
		144.5. Malfunction of LIC-715A closing LV-715 or unexpected closure of HV-717 or HV-1913A/B	144.5.1. Level build up in LNG separator S7003 resulting in possible overflowing and LNG carry over to EW9000 with possible embrittlement of downstream piping leading to mechanical damage and loss of containment	144.5.1.1. LAHH-716 activate closure HV-700  144.5.1.2. TALL-915 activate closure HV-721			
			144.5.2. Level build up in LNG separator S7003 resulting in possible overflowing and LNG carry over to EW9000 with consequent vaporization resulting in...	144.5.2.1. LAHH-716 activate closure of HV-700 (same actions activated by PAHH-717)			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (11) LNG separator

Intention: S7003: OT = -166,53 °C

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70

Parameter: Flow

Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	144. No/less Flow (cont.)	144.5. Malfunction of LIC-715A closing LV-715 or unexpected closure of HV-717 or HV-1913A/B (cont.)	<p>...pressure build up in LNG separator S7003 (DP=16 barg) leading to potential overpressurization, mechanical damage and potential for LNG leakages inside the cold box with release of NG to atmosphere through cold box vent valve (no impact on personnel expected since breathing valve vent located at safe location). Possible operational disruption due to equipment damage and prolonged maintenance operation</p> <p>144.5.3. Level build up in LNG separator S7003 resulting in possible overfilling and LNG carry over to EW9000 with consequent vaporization resulting in pressure build up in LNG separator S7003 (DP=16 barg) leading to potential overpressurization, mechanical damage and potential for LNG leakages inside the cold box with potential cold box overpressurization, mechanical damage and injuries to personnel (fire/explosion hazard)</p> <p>144.5.4. Level build up in LNG separator S7003 resulting in possible overfilling and LNG carry over to EW9000 with consequent vaporization resulting in pressure build up in EW9000 and ...</p>	<p>144.5.2.2. PSH-715A activate opening HV-715 to cold flare KO drum V16000</p> <p>144.5.2.3. PSV-705 sized including this scenario</p> <p>144.5.3.1. LAHH-716 activate closure of HV-700 (same actions activated by PAHH-717)</p> <p>144.5.3.2. PSH-715A activate opening HV-715 to cold flare KO drum V16000</p> <p>144.5.3.3. PSV-705 sized including this scenario</p> <p>144.5.3.4. Overpressure device provided on cold box</p> <p>144.5.4.1. LAHH-716 activate closure of HV-700 (same actions activated by PAHH-717)</p> <p>144.5.4.2. PSH-715A...</p>	<p>36. PSV-914 shall be verified for LNG vaporization in EW9000</p>	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023  
 Node: (11) LNG separator  
 Intention: S7003: OT = -166,53 °C  
 EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70  
 Parameter: Flow Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	144. No/less Flow (cont.)	144.5. Malfunction of LIC-715A closing LV-715 or unexpected closure of HV-717 or HV-1913A/B (cont.)	...associated piping (DP=16 barg) leading to potential overpressurization, mechanical damage and potential for LNG leakages with possible injuries to personnel (fire/explosion hazard)	...activate opening HV-715 to cold flare KO drum V16000  144.5.4.3. Overpressure device provided on cold box	36. PSV-914 shall be verified for LNG vaporization in EW9000 (cont.)		
More	145. More Flow	145.1. Malfunction of FIC-713 opening FV-713  145.2. See pressure parameter for wide opening of PV-703	145.1.1. No significant impact (flowrate on NG, LNG system is managed by JT valve PV-703)				
Reverse	146. Reverse Flow	146.1. Shut-down of thermal oxidizer	146.1.1. Possible CO2 stream at 0,9 barg (from S2011) back flow from V16200 to LNG separator S7003 (OP = 0,5 barg) leading to possible LNG contamination and off spec products		37. PAHH-1640 shall close HV-1646 to avoid LNG contamination by CO2 in case of thermal oxidizer shut-down possibly leading to CO2 backflow from V16200 to LNG separator S7003	SIAD MI	
Misdirect	147. Misdirect Flow	147.1. HV-701 stuck in open position after start-up  147.2. Unexpected opening of HV-715	147.1.1. Negligible impact according to limited size of HV-701  147.2.1. Possible continuous NG routed to cold flare with environmental concern and loss of product  147.2.2. Pressure decrease in S7003 and consequent loss of driving force for LNG displacement to storage tank...		38. Provide alarm on HZI-715 for loss of closed position of HV-715  :See_38	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (4) 30/03/2023

Node: (11) LNG separator

Intention: S7003: OT = -166,53 °C

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70

Parameter: Flow

Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	147. Misdirect Flow (cont.)	147.2. Unexpected opening of HV-715 (cont.)	...resulting in level build up in S7003 (see no/less flow for overfilling in S7003 and consequent overpressurization)		:See_38 (cont.)		
			147.2.3. Pressure decrease in S7003 and consequent loss of driving force for LNG displacement to storage tank resulting in level build up in S7003 and consequent possible overfilling leading to possible LNG carry over to cold flare KO drum V16000 resulting in operational upset (vaporization of LNG on cold flare header will lead to fluctuation in separator pressure and discontinuous discharge to tank)	147.2.3.1. LAHH-716 activate closure HV-700			
		147.3. Unexpected opening of HV-711	147.3.1. LNG routed to cold flare KO drum V16000 resulting in KO drum overfilling and possible liquid carry over to cold flare resulting in LNG outflow from flare tips with potential injuries to personnel	147.3.1.1. Discrepancy alarm on HVs	39. Add a high high level interlock on V16000 to activate closure of HV-700 (relevant set point to be defined to allow adequate residual volume preventing overfilling after HV-700 closure)	SIAD MI	
		147.4. Unexpected opening of HV-916	147.4.1. Not condensable gas routed to cold flare instead of to thermal oxidizer leading to minor environmental concern	147.4.1.1. Valve is FC and has discrepancy alarm on HVs			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023  
 Node: (11) LNG separator  
 Intention: S7003: OT = -166,53 °C  
 EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70  
 Parameter: Temperature Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	148. Lower Temperature	148.1. Loss of LP steam in EW9000 including malfunction of TIC-952 closing TV-952  148.2. Low ambient temperature	148.1.1. Natural gas routed to thermal oxidizer inlet line at -168°C instead of 20°C with possible embrittlement of piping resulting in mechanical and injuries to personnel (fire/explosion hazard)  148.1.2. Freezing in EW9000 is not expected due to limited flowrate of cryogenic gas and continuous circulation of water through EW9000  148.2.1. Possible freezing of stagnant piping on water side of EW9000	148.1.1.1. TALL-915 activate closure HV-721  148.2.1.1. Electrical tracing and insulation provided on water piping (electrical tracing also supplied by EDG)	:See_8		
More	149. Higher Temperature	149.1. Higher temperature of natural gas from upstream section (see high temperature in node #9)  149.2. See higher temperature from node #10 (Inadequate cooling of dryer after refeneration (KV failure in close position))  149.3. Loss of cooling duty from primary heat exchanger HX7000 (any cause related to nodes #30 and #31)	149.3.1. Loss of cooling medium circulation through HX7000 with partial loss of LNG production (operation disruption/economical losses)	149.3.1.1. Event detectable by TI-705  149.3.1.2. Monitoring instrumentation provided...			



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (11) LNG separator

Intention: S7003: OT = -166,53 °C

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70

Parameter: Temperature

Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	149. Higher Temperature (cont.)	<p>149.3. Loss of cooling duty from primary heat exchanger HX7000 (any cause related to nodes #30 and #31) (cont.)</p> <p>149.4. Loss of duty in LNG subcooler SC7001 (See any cause related to node #31)</p> <p>149.5. Malfunction of TIC-952 fully opening TV-952 on LP steam to EW9000</p>	<p>149.3.1. Loss of cooling medium circulation through HX7000 with partial loss of LNG production (operation disruption/economical losses) (cont.)</p> <p>149.4.1. Loss of cooling medium circulation through SC7001 with partial loss of LNG production (operation disruption/economical losses)</p> <p>149.5.1. Abnormal input to EW9000 resulting in increased temperature (max estimated &lt; 90°C) of gas routed to thermal oxidizer with no impact</p> <p>149.5.2. Higher temperature of water bath in EW9000 (max 100°C) with no impact on EW9000 and coils according to selected material (stainless steel)</p> <p>149.5.3. Higher temperature of water bath in EW9000 leading to steam generation and consequent possible release from EW9000 atmospheric vent and potential injuries to personnel</p>	<p>...on cooling media (see nodes #30 and #31)</p> <p>149.4.1.1. Event detectable by TI-718</p> <p>149.4.1.2. Monitoring instrumentation provided on LNG subcooler SC7001 (see node #31)</p> <p>149.5.3.1. TAH-953</p>	<p>40. Review design temperature of EW9000 from 90°C to 100°C</p> <p>41. Ensure safe location requirements of EW5000 and EW9000 atmospheric vent</p>	<p>SIAD MI</p> <p>SIAD MI</p>	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023  
 Node: (11) LNG separator  
 Intention: S7003: OT = -166,53 °C  
 EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70  
 Parameter: Pressure Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	150. Lower Pressure	150.1. Refer to No/Less Flow in this node  150.2. Refer to Misdirect flow (opening of HV-715)  150.3. Malfunction of PIC-715 opening PV-715 when not required	150.3.1. Pressure decrease in S7003 and consequent loss of driving force for LNG displacement to storage tank resulting in level build up in S7003 (see no/less flow for overfilling in S7003 and consequent overpressurization)				
More	151. Higher Pressure	151.1. Refer to No/Less Flow in this node  151.2. Malfunction of PIC-703 fully opening PV-703	151.2.1. LNG at 43 barg sent to LNG separator S7003 and associated piping (DP= 16 barg) leading to potential overpressurization, mechanical damage with possible operational disruption due to equipment damage and prolonged maintenance operation  151.2.2. LNG at 43 barg sent to LNG separator S7003 and associated piping (DP= 16 barg) leading to potential for LNG leakages inside the cold box with potential cold box...	151.2.1.1. PSH-715A activate opening HV-715 to cold flare KO drum V16000 (sized for JT valve PV-703 wide opening)  151.2.1.2. PAHH-717 activate closure of HV-700  151.2.1.3. PSV-705 sized including this scenario  151.2.2.1. PSH-715A activate opening HV-715 to cold flare KO drum V16000 (sized for JT valve PV-703 wide opening)			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023  
 Node: (11) LNG separator  
 Intention: S7003: OT = -166,53 °C  
 EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70  
 Parameter: Pressure Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	151. Higher Pressure (cont.)	151.2. Malfunction of PIC-703 fully opening PV-703 (cont.)  151.3. External fire/Thermal expansion	...overpressurization, mechanical damage and injuries to personnel (fire/explosion hazard)  151.3.1. Overpressurization of involved equipment/piping with possible mechanical damage	151.2.2.2. PAHH-717 activate closure of HV-700  151.2.2.3. PSV-705 sized including this scenario  151.2.2.4. Overpressure hatch on cold box  151.3.1.1. All isolatable equipment and piping on LNG sections are protected by pressure relief devices sized for this case	:See_Z		

Session: (5) 31/03/2023  
 Node: (11) LNG separator  
 Intention: S7003: OT = -166,53 °C  
 EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70  
 Parameter: Level Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	152. No/less Level	152.1. Malfunction of LIC-715 fully opening LV-715	152.1.1. Loss of level in S7003 and consequent gas breakthrough (0,5 barg) to LNG VT19000 and VT19001 (DP=5barg) with no impact on mechanical integrity according to design criteria  152.1.2. Loss of level in S7003 and consequent gas breakthrough (0,5 barg), involving not condensable gases to LNG VT19000 and VT19001...	152.1.2.1. LALL-716 activate closure of HV-717			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023  
 Node: (11) LNG separator  
 Intention: S7003: OT = -166,53 °C  
 EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70  
 Parameter: Level Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	152. No/less Level (cont.)	152.1. Malfunction of LIC-715 fully opening LV-715 (cont.)	...(DP=5barg) resulting in uncondensable gas accumulation into BOG and relevant circuit and consequent operational upset overtime due to unstable operations	152.1.2.1. LALL-716 activate closure of HV-717 (cont.)			
		152.2. Malfunction of LSL-940 not opening LV-940 on demand	152.2.1. Inadequate water make up to EW9000 leading to loss of level and consequent loss of duty to regeneration gas stream (see lower temperature due to loss of steam to EW9000)				
More	153. Higher Level	153.1. Refer to No/Less and misdirect flow					
		153.2. Refer to low pressure					
		153.3. Malfunction of LSH-940 opening LV-940 when not required	153.3.1. Level build up in EW9000 resulting in overfilling and water carry over to drain collection pit at grade. Waste of water with no impact on personnel safety	153.3.1.1. TAL-953			
			153.3.2. Level build up in EW9000 resulting in overfilling and continuous water circulation through overflow line leading to lower temperature of cryogenic gas to thermal oxidizer (see low temperature for loss of steam but less critical)	153.3.2.1. TAL-953			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023  
 Node: (11) LNG separator  
 Intention: S7003: OT = -166,53 °C  
 EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70  
 Parameter: Composition Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	154. Different Composition	154.1. Presence of humidity/CO2 due to upset on upstream treatment sections (See nodes relevant to CO2 removal and to gas drying)  154.2. See no/less flow and lower level for inadequate displacement of not condensable gas (N2, H2, O2)	154.1.1. Freezing of water and/or CO2 inside LNG coils of primary heat exchanger HX7000 resulting in plugging leading to reduction/loss of LNG production overtime. No safety concern	154.1.1.1. See dedicated safeguards provided on upstream section and dedicated to prevent slippage of CO2 and humidity (see relevant nodes)  154.1.1.2. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD  154.1.1.3. AI-1013A to provide a high H2O concentration alarm and to close HV-700 on high high H2O concentration through ESD			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (11) LNG separator

Intention: S7003: OT = -166,53 °C

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes:

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70

Parameter: Services / Utilities

Equipment: S7003, EW9000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	155. No Services / Utilities	155.1. No additional cause identified					

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OT<sub>in</sub> = -166,53 °C, OT<sub>out</sub> = 20 °C

C9100: OP<sub>suction</sub> = 1,2 barg; OP<sub>discharge</sub> = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OP<sub>suction</sub> = 1,5 barg; OP<sub>discharge</sub> = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Flow

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES	
No/less	156. No/less Flow	<p>156.1. Unexpected closure of PV1910A (including PIC1910A malfunction) or unexpected closure of additional HV provided at liquid outlet from tank connected to BOG system</p> <p>156.2. Unexpected closure of PV1910B (including PIC1910B malfunction) or unexpected closure of HV939 or unexpected closure of HV900</p>	<p>156.1.1. Low pressure on LNG storage tanks VT19000 and VT19001 (see node #13)</p> <p>156.1.2. No impact expected on BOG compressor since when build-up vaporizer is required in operation, compressor is not foreseen to suct build up gas from tank VT19000</p> <p>156.2.1. High pressure on LNG storage tanks VT19000 and VT19001 (see node #13)</p> <p>156.2.2. Blocked outlet condition for truck loading BOG line only in case of closure oh HV-900 (See No/Less Flow in node #13 due to closure of FV-914)</p> <p>156.2.3. Reduced BOG feed to BOG compressor C9100 / Loss of BOG feed to BOG compressor C9100 (when truck loading is not in place) resulting in possible mechanical damage and economical losses</p> <p>156.2.4. No impact on NG feed due to loss of BOG recovery stream (less than 5% of feed)</p>	<p>156.2.3.1. Recirculating by-pass through PV-905 sized to cope with this scenario</p> <p>156.2.3.2. PALL-910 activate trip of compressor C9100</p>				Additional HV will be provided on each tank liquid outlet to LNG build-up vaporizer

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OT<sub>in</sub> = -166,53 °C, OT<sub>out</sub> = 20 °C

C9100: OP<sub>suction</sub> = 1,2 barg; OP<sub>discharge</sub> = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OP<sub>suction</sub> = 1,5 barg; OP<sub>discharge</sub> = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Flow

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	156. No/less Flow (cont.)	156.3. Potential plugging of strainer K900NG	156.3.1. Decrease in compressor efficiency and consequent operational upset	156.3.1.1. Differential pressure gauge provided for K900NG (see dedicated P&ID for compressor C9100)			
		156.4. Compressor C9100 failure	156.4.1. High pressure on LNG storage tanks VT19000 and VT19001 (see node #13)  156.4.2. Blocked outlet condition for truck loading BOG line (See No/Less Flow in node #13 due to closure of FV-914)  156.4.3. No impact on NG feed due to loss of BOG recovery stream (less than 5% of feed)				
		156.5. Malfunction of compressor control system (PIC-900/PIC-904) reducing compressor motor speed to VFD	156.5.1. High pressure on LNG storage tanks VT19000 and VT19001 (see node #13)  156.5.2. Blocked outlet condition for truck loading BOG line (See No/Less Flow in node #13 due to closure of FV-914)  156.5.3. No impact on NG feed due to loss of BOG recovery stream (less than 5% of feed)				
	157. No/less Flow (compressor discharge)	157.1. Plugging of compressor post filter F9101	157.1.1. Increased DP across filter with operational upset	157.1.1.1. Differential pressure gauge provided...			



# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OTin = -166,53 °C, OTout = 20 °C

C9100: OPsuction = 1,2 barg; OPdischarge = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OPsuction = 1,5 barg; OPdischarge = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Flow

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	157. No/less Flow (compressor discharge) (cont.)	157.1. Plugging of compressor post filter F9101 (cont.)  157.2. Unexpected closure of HV-904	157.1.1. Increased DP accross filter with operational upset (cont.)  157.2.1. No impact on NG feed due to loss of BOG recovery stream (less than 5% of feed)  157.2.2. Pressure build up on LNG storage tanks VT19000 and VT19001 (see node #13)  157.2.3. Pressure build up on compressor discharge system (DP=49 barg) and possible overpressurization leading to mechanical damage, loss of containment, potential for fire/explosion, injuries to personnel	...for F9101 (see dedicated P&ID for compressor C9100)  157.2.3.1. PIC-904 to open PV-905  157.2.3.2. PAHH-911 activate trip of compressor  157.2.3.3. PSV-903			Each stage is provided with PSV sized for blocked outlet (PSV-901/902) and high high pressure interlock (PAHH-901/902)
More	158. More Flow	158.1. Malfunction of compressor control system (PIC-900/PIC-904) increasing compressor motor speed to VFD	158.1.1. No impact on usptream section  158.1.2. Lower pressure on compressor suction side with possible compressor motor overload leading to damage to motor (economical losses)  158.1.3. No impact on NG feed...	158.1.2.1. Overload protection for compressor motor activate trip of compressor motor  158.1.2.2. PALL-910 activate trip of compressor motor			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OTin = -166,53 °C, OTout = 20 °C

C9100: OPsuction = 1,2 barg; OPdischarge = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OPsuction = 1,5 barg; OPdischarge = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Flow

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	158. More Flow (cont.)	158.1. Malfunction of compressor control system (PIC-900/PIC-904) increasing compressor motor speed to VFD (cont.)	...due to transient increase of BOG recovery stream (less than 5% of feed)				
Reverse	159. Reverse Flow	159.1. Compressor trip/stop (any cause)	159.1.1. Reverse flow from compressor discharge system (OP=43 barg) toward compressor suction side (DP=5 barg for VT19000 and VT19001) has not been considered a credible scenario since compressor is reciprocating type and any cause of compressor trip/stop will lead to closure of HV-904, HV-900 and opening HV-905 (by-bass line through PV-905 is normally closed during normal operation)				
Misdirect	160. Misdirect Flow	160.1. PV-1910A suck in open position during compressor in operation (PV-1910B opened)	160.1.1. Transient slight pressure build up on LNG storage tanks VT19000 and VT19001  160.1.2. Increased BOG flowrate through EW9000 coil and consequent lower temperature on downstream piping with possible embrittlement of piping leading to mechanical damage and loss of containment with possible fire/explosion hazard  160.1.3. Increased LNG...	160.1.2.1. TALL-913 activate closure of HV-939  160.1.3.1. TALL-913...			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OTin = -166,53 °C, OTout = 20 °C

C9100: OPsuction = 1,2 barg; OPdischarge = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OPsuction = 1,5 barg; OPdischarge = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Flow

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	160. Misdirect Flow (cont.)	<p>160.1. PV-1910A suck in open position during compressor in operation (PV-1910B opened) (cont.)</p> <p>160.2. Malfunction of PIC-1900A opening HV-1912 when is not required</p> <p>160.3. Unexpected opening of HV-915</p> <p>160.4. Unexpected opening of HV-917</p>	<p>...circulation through build up vaporizer E1900 leading to ice formation and inadequate vaporization resulting in possible LNG carry over to EW9000 leading to lower temperature of gas to compressor with possible damage (economical losses)</p> <p>160.2.1. BOG routed to cold flare with minor environmental concern</p> <p>160.2.2. BOG routed to cold flare resulting in loss of suction flowrate/pressure to compressor (see loss of compressor suction feed in no/less flow in this node)</p> <p>160.3.1. BOG gas routed to cold flare instead of to compressor suction leading to minor environmental concern</p> <p>160.3.2. BOG routed to cold flare resulting in loss of suction flowrate/pressure to compressor (see loss of compressor suction feed in no/less flow in this node)</p> <p>160.4.1. BOG partially routed to thermal oxidizer with potential operational upsets for thermal oxidizer</p>	<p>...activate closure of HV-939</p> <p>160.2.1.1. HV-1912 reported to PLC screen</p> <p>160.3.1.1. Valve is FC and has discrepancy alarm on HVs</p> <p>160.3.2.1. Valve is FC and has discrepancy alarm on HVs</p> <p>160.4.1.1. Valve is FC and has discrepancy alarm on HVs</p>			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OT<sub>in</sub> = -166,53 °C, OT<sub>out</sub> = 20 °C

C9100: OP<sub>suction</sub> = 1,2 barg; OP<sub>discharge</sub> = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OP<sub>suction</sub> = 1,5 barg; OP<sub>discharge</sub> = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Flow

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	160. Misdirect Flow (cont.)	<p>160.5. Malfunction PIC-900/PIC-904 opening PV-905 when not required</p> <p>160.6. Unexpected opening of HV-905</p>	<p>160.5.1. Compressor put in recycle mode resulting in impact on upstream system (see compressor failure) and loss recovery BOG to NG feed</p> <p>160.5.2. Possible pressure build up on compressor suction system (DP=6 barg) and possible overpressurization leading to mechanical damage, loss of containment, potential for fire/explosion, injuries to personnel</p> <p>160.6.1. BOG gas routed to cold flare instead of to NG feed suction leading to minor environmental concern</p> <p>160.6.2. BOG routed to cold flare resulting in loss of BOG recovery stream (less than 5% of feed)</p>	<p>160.5.2.1. PAHH-911 activate trip of compressor</p> <p>160.6.1.1. Discrepancy alarm on HVs</p> <p>160.6.2.1. Discrepancy alarm on HVs</p>			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OT<sub>in</sub> = -166,53 °C, OT<sub>out</sub> = 20 °C

C9100: OP<sub>suction</sub> = 1,2 barg; OP<sub>discharge</sub> = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OP<sub>suction</sub> = 1,5 barg; OP<sub>discharge</sub> = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Temperature

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	161. Lower Temperature	161.1. Refer to More and Misdirect Flow in this node  161.2. Loss of duty in EW9000 (loss of LP steam supply including malfunction of TIC-952)	161.2.1. Lower temperature on downstream EW9000 coil and consequent lower temperature on downstream piping with possible embrittlement of piping leading to mechanical damage and loss of containment with possible fire/explosion hazard	161.2.1.1. TALL-913 activate closure of HV-939 (same action initiated by TALL-952)			
More	162. Higher Temperature	162.1. TIC-952 malfunction increasing heat input to EW9000  162.2. Loss of cooling water to HW9101  162.3. Loss of cooling water to HW9102  162.4. Loss of cooling water to...	162.1.1. Higher temperature (up to 100°C) of BOG gas to compressor resulting in possible overheating of EW9000 process gas coils (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire  162.2.1. Higher temperature of natural gas to second stage of compressor resulting in potential damage to internals and consequent economical losses  162.3.1. Higher temperature of natural gas to third stage of compressor resulting in potential damage to internals and consequent economical losses  162.4.1. Higher temperature of...	162.2.1.1. TAHH-902 activate trip of compressor  162.3.1.1. TAHH-903 activate trip of compressor	:See 47		
					42. Add a high high...	SIAD...	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 102 of 161

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OT<sub>in</sub> = -166,53 °C, OT<sub>out</sub> = 20 °C

C9100: OP<sub>suction</sub> = 1,2 barg; OP<sub>discharge</sub> = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OP<sub>suction</sub> = 1,5 barg; OP<sub>discharge</sub> = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Temperature

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	162. Higher Temperature (cont.)	...HW9103	<p>...BOG recovery gas (estimated approximately 175°C) on equipment and piping on third stage discharge downstream aftercooler (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire</p> <p>162.4.2. No impact on natural gas feed due to increased temperature of BOG recovery gas stream due to limited flowrate from compressor (less than 5% of feed)</p>		...temperature interlock downstream HW9103 to activate trip of BOG compressor C9100	...MI	

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OT<sub>in</sub> = -166,53 °C, OT<sub>out</sub> = 20 °C

C9100: OP<sub>suction</sub> = 1,2 barg; OP<sub>discharge</sub> = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OP<sub>suction</sub> = 1,5 barg; OP<sub>discharge</sub> = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Pressure

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	163. Lower Pressure	163.1. Refer to No/Less and Misdirect flow in this node					
More	164. Higher Pressure	164.1. Refer to No/Less and Misdirect flow in this node					
		164.2. External fire/Thermal...	164.2.1. Overpressurization of...	164.2.1.1. All isolatable...	:See 7		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 103 of 161

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OT<sub>in</sub> = -166,53 °C, OT<sub>out</sub> = 20 °C

C9100: OP<sub>suction</sub> = 1,2 barg; OP<sub>discharge</sub> = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OP<sub>suction</sub> = 1,5 barg; OP<sub>discharge</sub> = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Pressure

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	164. Higher Pressure (cont.)	...expansion	...involved equipment/piping with possible mechanical damage	...equipment and piping on LNG sections are protected by pressure relief devices sized for this case	43. Provide additional pressure relief device against External fire/Thermal expansion on LNG build up line between last block valve and new HV	SIAD MI	

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OT<sub>in</sub> = -166,53 °C, OT<sub>out</sub> = 20 °C

C9100: OP<sub>suction</sub> = 1,2 barg; OP<sub>discharge</sub> = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OP<sub>suction</sub> = 1,5 barg; OP<sub>discharge</sub> = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Level

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	165. No/less Level	165.1. Not applicable					
More	166. Higher Level	166.1. Not applicable					

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OTin = -166,53 °C, OTout = 20 °C

C9100: OPsuction = 1,2 barg; OPdischarge = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OPsuction = 1,5 barg; OPdischarge = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Composition

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	167. Different Composition	167.1. By-pass of BOG compressor post-filter F9101 left open after maintenance	167.1.1. Possible carry over of piston ring wear material to NG feed with negligible impact				

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Intention: EW9000: OTin = -166,53 °C, OTout = 20 °C

C9100: OPsuction = 1,2 barg; OPdischarge = 44,5 barg

VT19001: OT = -166,53 °C

P19001: OPsuction = 1,5 barg; OPdischarge = 6,5 barg

Notes:

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Services / Utilities

Equipment: VT19001, E19000, EW9000, C9100

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	168. No Services / Utilities	168.1. No additional cause identified					



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Flow

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	169. No/less Flow	<p>169.1. Unexpected closure of HV-1902A during truck loading mode</p> <p>169.2. Failure of pump P19000 when required in operation</p> <p>169.3. Malfunction of FIC-1950A acting on P19000 pump VFD resulting in reduced pump motor speed</p>	<p>169.1.1. No impact on LNG tank</p> <p>169.1.2. Loss of suction feed to P19000 with possible pump damage due to dry running (economical losses with no safety impact since pump is submerged pump without seals)</p> <p>169.1.3. Interruption of truck loading operation with operational upset (loss of 50% capacity to be sent to truck)</p> <p>169.2.1. No impact on LNG tank</p> <p>169.2.2. Interruption of truck loading operation with operational upset (loss of 50% capacity to be sent to truck)</p> <p>169.3.1. Increased duration in truck loading operation and consequent operational upset (loss of 50% capacity to be sent...</p>	<p>169.1.2.1. PDALL-1938A activate trip of pump P19000</p> <p>169.1.3.1. Discrepancy alarm on HVs</p> <p>169.1.3.2. Intervention of pump protection will freeze the loading sequence providing an alarm at loading area. On control room board operator will receive alarm associated to intervention of PDALL-1938A</p> <p>169.2.2.1. Discrepancy alarm on pump status</p> <p>169.2.2.2. Pump faulty status will freeze the loading sequence providing an alarm at loading area.</p>			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Flow

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	169. No/less Flow (cont.)	<p>169.3. Malfunction of FIC-1950A acting on P19000 pump VFD resulting in reduced pump motor speed (cont.)</p> <p>169.4. Unexpected closure of HV-1951A, FV-1950A, HV-1952A</p>	<p>...to truck)</p> <p>169.4.1. Pressure build up on pump discharge line up to shut-off pressure of pump P19000 (estimated &lt;15 barg) with no impact on mechanical integrity of piping according to design criteria</p> <p>169.4.2. Overheating of LNG trapped in the pump (no safety impact since pump is submerged pump without seals)</p> <p>169.4.3. Interruption of truck loading operation with operational upset (loss of 50% capacity to be sent to truck)</p> <p>169.4.4. Potential pressure surge resulting in mechanical damage...</p>	<p>169.4.2.1. PDIC-1939A to open PDV-1939A to recycle LNG back to tank</p> <p>169.4.2.2. PDAHH-1938A activate trip of pump P19000</p> <p>169.4.3.1. Discrepancy alarm on HVs (not effective for FV-1950A)</p> <p>169.4.3.2. Intervention of pump protection will freeze the loading sequence providing an alarm at loading area. On control room board operator will receive alarm associated to intervention of PDALL-1938A</p>	<p>44. Surge study to be provided for LNG truck...</p>	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Flow

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	169. No/less Flow (cont.)	169.4. Unexpected closure of HV-1951A, FV-1950A, HV-1952A (cont.)  169.5. Blocked inlet of LNG connection on road tanker	...to LNG transfer line from pump to last on/off valve resulting in potential LNG leak and possible fire/explosion hazard  169.5.1. Pressure build up on pump discharge line up to shut-off pressure of pump P19000 (estimated <15 barg) with no impact on mechanical integrity of piping according to design criteria. No impact on flexible hoses according to design criteria (PN40)  169.5.2. Overheating of LNG trapped in the pump (no safety impact since pump is submerged pump without seals)  169.5.3. Interruption of truck loading operation with operational upset (loss of 50% capacity to be sent to truck)	169.5.2.1. PDIC-1939A to open PDV-1939A to recycle LNG back to tank  169.5.2.2. PDAHH-1938A activate trip of pump P19000  169.5.3.1. Discrepancy alarm on HVs (not effective for FV-1950A)  169.5.3.2. Intervention of pump protection will freeze the loading sequence providing an alarm at loading area. On control room board operator will receive alarm associated to intervention of PDALL-1938A	...loading lines (including worst case scenario: closure of on/off valve on road tanker side)		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Flow

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	169. No/less Flow (cont.)	169.6. Unexpected closure of HV-1957A, PV-1958A, HV-1956A (when BOG is routed back to tank) or unexpected closure of PV-1959A, HV-1958A, FV-914 (when BOG from road tanker is routed to BOG compressor)	169.6.1. Pressure build up in road tanker up to shut-off pressure of pump P19000 (estimated <15 barg) and potential overpressurization leading to mechanical damage, LNG leakage and possible fire/explosion hazard and injuries to personnel  169.6.2. No impact on LNG tank	169.6.1.1. PAHH-1960A to activate trip of pump P19000 and to close on/off pneumatic valve on truck inlet by means of SY-1950AA (same actions initiated also by PAHH-1961A, not effective only in case of blocked outlet on gas return line inside road tanker)	45. Set point of PAHH-1960A and PAHH-1961A shall be defined taking into account lowest design pressure for road tankers (design pressure of road tankers to be checked by OGE, currently available value is 7 barg)	OGE	
More	170. More Flow	170.1. Malfunction of FIC-1950A opening more than required FV-1950A at the beginning of loading operation  170.2. Malfunction of FIC-1950A opening FV-1950A more than required and increasing pump motor speed through VFD	170.1.1. In case road tanker is warm, possible increased of generation of BOG resulting in pressure build up in road tanker and potential overpressurization leading to mechanical damage, LNG leakage and possible fire/explosion hazard and injuries to personnel  170.2.1. No significant consequences identified	170.1.1.1. PAHH-1960A to activate trip of pump P19000 and to close on/off pneumatic valve on truck inlet by means of SY-1950AA (same actions initiated also by PAHH-1961A)			
	171. More Flow (LNG loaded Amount)	171.1. Malfunction of WQ-1900A leading to higher amount of LNG loaded on road tanker	171.1.1. Possible overfilling of road tanker with consequent overpressurization of road tanker leading to mechanical damage, LNG leakage and possible fire/explosion hazard and injuries to personnel	171.1.1.1. FQI-1950A to provide alarm in case of discrepancy higher than 5% with WI-1900A (if loaded amount is above 80% of tanker capacity sequence is stopped)			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 109 of 161

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Flow

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	171. More Flow (LNG loaded Amount) (cont.)	171.1. Malfunction of WQ-1900A leading to higher amount of LNG loaded on road tanker (cont.)	171.1.1. Possible overfilling of road tanker with consequent overpressurization of road tanker leading to mechanical damage, LNG leakage and possible fire/explosion hazard and injuries to personnel (cont.)  171.1.2. Possible overfilling of road tanker with consequent liquid carry over to BOG line back to heater EW9000 with possible embrittlement of downstream piping leading to mechanical damage and loss of containment	171.1.1.2. PAHH-1960A to activate trip of pump P19000 and to close on/off pneumatic valve on truck inlet by means of SY-1950AA (same actions initiated also by PAHH-1961A)  171.1.2.1. FQI-1950A to provide alarm in case of discrepancy higher than 5% with WI-1900A (if loaded amount is above 80% of tanker capacity sequence is stopped)  171.1.2.2. TALL-914 activate closure HV-1958A/B			
Reverse	172. Reverse Flow	172.1. Failure of pump P19000 when required in operation	172.1.1. Possible back flow from road tanker to tank with no impact				
Misdirect	173. Misdirect Flow	173.1. HV-1932A stuck in open position  173.2. Malfunction of PDIC-1939A opening PDV-1939A when not required	173.1.1. No impact expected  173.2.1. Reduced pressure and flowrate on P19000 discharge resulting in delayed operation and consequent operational upset. Potential damage to pump motor due to overload (possible economical losses)	173.1.1.1. Discrepancy alarm on HVs  173.2.1.1. Internal protection provided against pump motor overload  173.2.1.2. PDALL-1938A activate trip of pump P19000			
		173.3. HV-1950A stuck in...	173.3.1. LNG partially routed...				

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Flow

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	173. Misdirect Flow (cont.)	<p>...open position after cooling (if required)</p> <p>173.4. HV-1953A stuck in open position after hose drain</p> <p>173.5. HV-1954A / HV-1955A stuck in open position after end of purging operation</p>	<p>...back to tank through BOG line with no impact on storage tank</p> <p>173.3.2. Reduced flowrate to road tanker resulting in delayed operation and consequent operational upset. Potential damage to pump motor due to overload (possible economical losses)</p> <p>173.4.1. During next loading operation, LNG partially routed to BOG line with consequent liquid carry over to heater EW9000 with possible embrittlement of downstream piping leading to mechanical damage and loss of containment</p> <p>173.5.1. Nitrogen at 9 barg enters into LNG loading / BOG lines and consequent pressure build up with no impact on mechanical integrity (DP=15 barg)</p> <p>173.5.2. After the end of pressure test, in case of increased pressure on LNG loading / BOG lines, sequence will be stopped by PAHH-1960A / PAHH-1961A leading to delay in operation</p>	<p>173.3.2.1. Discrepancy alarm on HVs</p> <p>173.3.2.2. Internal protection provided against pump motor overload</p> <p>173.3.2.3. PDALL-1938A activate trip of pump P19000</p> <p>173.4.1.1. Permissive to not start loading sequence if HV-1953A is detected in inconsistent position</p> <p>173.4.1.2. TALL-914 activate closure HV-1958A/B</p>	<p>46. Provide a PSV on nitrogen purging line to LNG / BOG lines (set at adequate value)</p>	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 111 of 161

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Flow

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	173. Misdirect Flow (cont.)	<p>173.6. Unexpected opening of HV-1959A</p> <p>173.7. Malfunction of PIC-1959AB opening PV-1959 when not required</p> <p>173.8. Unexpected opening of HV-1963A</p>	<p>173.6.1. BOG routed to cold flare and possible minor environmental concern</p> <p>173.7.1. BOG routed to BOG compressor instead that directly to tank with minor operational upset</p> <p>173.8.1. Nitrogen entrainment on BOG stream routed to compressor suction side with increased content of nitrogen in process flow (minor operational upset)</p> <p>173.8.2. Nitrogen entrainment on BOG stream with pressure build up on C9100 suction resulting in possible mechanical damage and economical losses</p> <p>173.8.3. After compressor shut down pressure build up (OP of nitrogen =9barg) on blocked in suction system (DP=10 barg) with no impact on mechanical integrity</p>	<p>173.6.1.1. Discrepancy alarm on HVs</p> <p>173.8.1.1. Discrepancy alarm on HVs</p> <p>173.8.2.1. HV-1963A is FC and managed by depressurization/purging sequence</p> <p>173.8.2.2. Discrepancy alarm on HVs</p> <p>173.8.2.3. PAH-900</p> <p>173.8.2.4. PAHH-910 activate trip of compressor C9100</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Temperature

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	174. Lower Temperature	174.1. No causes identified for tank VT19000, pump P19000 and truck loading bay TL19000  174.2. See overfilling scenario for road tanker (More flow)  174.3. Loss of LP steam in EW9000 including malfunction of TIC-952 closing TV-952	174.3.1. BOG routed to BOG compressor inlet line at -168°C instead of 20°C with possible embrittlement of piping resulting in mechanical and injuries to personnel (fire/explosion hazard)  174.3.2. Freezing in EW9000 is not expected due to limited flowrate of BOG and continuous circulation of water through EW9000	174.3.1.1. TALL-914 activate closure HV-1958A/B			
More	175. Higher Temperature	175.1. No causes identified for tank VT19000  175.2. Loss of pump cool down (HV-1932A not open on demand including TSL-1932A malfunction)  175.3. See more flow to road tanker during loading operation  175.4. Inadequate cooling of LNG line (HV-1950 not opening on demand including TSL-...	175.2.1. Loss of pump cooling down with possible pump damage due to cavitation (economical losses with no safety impact since pump is submerged pump without seals)  175.4.1. At the beginning of road tanker loading, possible increased of generation of BOG...	175.2.1.1. PDALL-1938A activate trip of pump P19000  175.4.1.1. PAHH-1960A activate trip of pump P19000 and to close...			



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 113 of 161

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Temperature

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	175. Higher Temperature (cont.)	...1951 malfunction)  175.5. TIC-952 malfunction increasing heat input to EW9000	...resulting in pressure build up in road tanker and potential overpressurization leading to mechanical damage, LNG leakage and possible fire/explosion hazard and injuries to personnel  175.5.1. Higher temperature (up to 100°C) of BOG gas to compressor resulting in possible overheating of EW9000 process gas coils (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire	...on/off pneumatic valve on truck inlet by means of SY-1950AA (same actions initiated also by PAHH-1961A)	47. Review design temperature of EW9000 coils up to 100°C	SIAD MI	

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Pressure

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	176. Lower Pressure	176.1. Malfunction of PIC-1910A to not open PV-1910A on demand  176.2. See Misdirect and No/Less flow in this node  176.3. PIC-1959AB malfunction fully opening PV-1959A	176.1.1. Pressure decrease in VT-19000, no impact expected on VT19000 operation according to NPSH requirement  176.3.1. No impact on loading operation				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Pressure

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	176. Lower Pressure (cont.)	176.3. PIC-1959AB malfunction fully opening PV-1959A (cont.)	176.3.2. Transient increase overall BOG flowrate to compressor suction side managed by FV-914				
More	177. Higher Pressure	177.1. See flow parameter and high temperature					
		177.2. Malfunction PIC-1910 to improperly manage BOG system or any other upset on BOG loop (including compressor C9100 failure)	177.2.1. Pressure build up in VT19000 leading to potential overpressurization (DP=5 barg) leading to mechanical damage, LNG leakage and possible fire/explosion hazard and injuries to personnel	177.2.1.1. PAH1900A and operator response / to open HV1912 to cold flare 177.2.1.2. PSV 1AB/ 1AA or PSV 2AA/ 2AB (2x100%)			
		177.3. Loss of vacuum on V19000 jacket	177.3.1. Loss of insulation capacity and consequent operational upset	177.3.1.1. Event detectable by ice formation on VT19000			
		177.4. Undetected leakage on VT19000	177.4.1. LNG entrainment on V19000 jacket resulting in potential overpressurization and mechanical damage	177.4.1.1. Rupture disk DS1A sized according to design code for cryogenic tank EN13458			
		177.5. External fire/Thermal expansion	177.5.1. Overpressurization of involved equipment/piping with possible mechanical damage	177.5.1.1. All isolatable equipment and piping on LNG sections are protected by pressure relief devices sized for this case	:See_Z		

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Level

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	178. No/less Level	178.1. Inadequate monitoring of tank level including LI-1900A or LI-1901A malfunction	178.1.1. Loss of level in VT19000 and consequent possible pump damage due to dry running (economical losses with no safety impact since pump is submerged pump without seals)	178.1.1.1. LALL-1900A or LALL1901A to trip pump P19000 (at least one is available since level transmitter are fully independent)  178.1.1.2. PDALL-1938A activate trip of pump P19000			
More	179. Higher Level	179.1. Inadequate monitoring of tank level including LI-1900A or LI-1901A malfunction	179.1.1. Level build up in VT19000 and consequent overflowing leading to blocked outlet condition for LNG separator bottom line resulting in level build up in S7003 (see no/less flow in node #11)	179.1.1.1. LAHH-1900A or LAHH1901A activate closure of HV-1913A (after closure of HV-1913A all LNG production will be diverted to VT19001)  179.1.1.2. See dedicated safeguard against overflowing provided for S7003 (node #11) in case second tank is not available to accommodate overall LNG			

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Composition

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	180. Different Composition	180.1. No causes identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Services / Utilities

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	181. No Services / Utilities	181.1. No additional cause identified					

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Intention: P19000: OPsuction = 1,5 barg, OPdischarge = 6,5 barg

EW9000: OTin = -166,53 °C, OTout = 20 °C

Notes: During normal operation both tanks are in filling mode and simultaneous truck loading mode

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Other

Equipment: VT19000, P19000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Other Than	182. Other Than Other	182.1. Hose failure	182.1.1. Release of LNG on loading area with possible fire/explosion hazard	182.1.1.1. PALL-1960A activate trip of pump P19000, close HV-1952A and SY-1950AA	48. Shut down of LNG loading shall be also activated by LNG high flow gradient according to requirement of TRGS 751 4.1.6 paragraph 6 codes	SIAD MI	

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023  
 Node: (14) Heavy HCs KO drum  
 Notes:  
 Drawings: I20784 Sh 70  
 Parameter: Flow

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	183. No/less Flow	<p>183.1. Loss of gas stream from analyzers fast loop to V16200 or loss of stream from EW9000 (not condensable gas from LNG separator) to V16200</p> <p>183.2. Unexpected closure of HV-1646</p> <p>183.3. No HC flow from S1003 (any cause relative to node #03)</p> <p>183.4. Unexpected closure of HV-1645</p>	<p>183.1.1. No impact on this node</p> <p>183.2.1. Blocked outlet for stripping condensate separator S2011 (see no/less flow in node #6 due to PV-275 unexpected closure)</p> <p>183.2.2. No impact on this node</p> <p>183.3.1. No impact on this node</p> <p>183.4.1. Pressure build up in V16200 leading to increase back pressure for incoming streams (see blocked outlet scenario for node #11 and #06)</p> <p>183.4.2. Pressure build up in V16200 leading to increase back pressure for analyzers fast loop. No impact on mechanical integrity according to design criteria</p> <p>183.4.3. Pressure build up in V16200 due to vaporization of liquid and possible overpressurization resulting in possible mechanical damage leading to injuries to personnel/leakages and fire hazard</p>		<p>49. PAHH-1640 shall also close HV-1646 to segregate stripper condensate separator S2011 from heavy HC KO drum V16200</p> <p>50. PSV-914 shall be verified for blocked outlet condition on V16200</p> <p>51. PAHH-1640 shall also close HV-721 and trip H16200/H16201</p>	<p>SIAD MI</p> <p>SIAD MI</p> <p>SIAD MI</p>	

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023  
 Node: (14) Heavy HCs KO drum  
 Notes:  
 Drawings: I20784 Sh 70  
 Parameter: Flow

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	183. No/less Flow (cont.)	183.4. Unexpected closure of HV-1645 (cont.)	183.4.4. No impact on thermal oxidizer				
More	184. More Flow	184.1. Gas breakthrough from S1003 (see Low level in node #03)	184.1.1. See node #03 for impact on V16200 mechanical integrity  184.1.2. Pressure build up in V16200 leading to potential increase back pressure for incoming streams (see blocked outlet scenario for node #11 and #06)		:See.49		
Reverse	185. Reverse Flow	185.1. Refer to no/less flow and more flow in this node  185.2. No causes identified for backflow from thermal oxidizer IN16200					
Misdirect	186. Misdirect Flow	186.1. No causes identified					

Session: (7) 04/04/2023  
 Node: (14) Heavy HCs KO drum  
 Notes:  
 Drawings: I20784 Sh 70  
 Parameter: Temperature

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	187. Lower Temperature	187.1. No causes identified for low temperature on incoming streams	:				Even in case of upset in EW9000 significant temperature decrease in not expected taking into account limited flowrate compared to CO2 incoming...

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023  
 Node: (14) Heavy HCs KO drum  
 Notes:  
 Drawings: I20784 Sh 70  
 Parameter: Temperature

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	187. Lower Temperature (cont.)	187.1. No causes identified for low temperature on incoming streams (cont.)  187.2. See more level in this node (Failure on demand of H16200)  187.3. Failure on demand of H16201 including TDY-1644 malfunction to switch off H16201 or to not switch on on demand	: (cont.)  187.3.1. Lower temperature of stream routed to thermal oxidizer inlet resulting in possible condensation and droplets carry over to thermal oxidizer leading to operational upset / possible damage		52. Investigate impact of liquid carry over to thermal oxidizer in case of unavailability of superheater H16201 or in case of loss of heater H16200	SIAD MI	...flowrate at approximately 100°C
More	188. Higher Temperature	188.1. Higher temperature of gas stream from EW9000 (<100°C) (see node #11)  188.2. Higher temperature of CO2 vent stream S2011/H2001 (see node #06)  188.3. No causes identified for higher temperature from flash vessel S1003  188.4. Malfunction of LI-1641 to switch on H16200 when not required or to not stop on demand  188.5. Malfunction of TDY-1644 to not switch off H16201 on demand or to switch on when not required	188.1.1. No impact on this node  188.2.1. No impact on this node  188.4.1. Loss of level in V16200 leading to dry running of H16200 with consequent potential overheating of electrical bundles and damage (economical losses)  188.5.1. Higher temperature of gas routed to thermal oxidizer and potential for damage to internals (economical losses)	188.4.1.1. LALL-1640 activate trip of H16200 (same action is initiated by TAHH-1640)	53. Relocate TI-1644 downstream H16201 and add a high high temperature interlock to...	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 120 of 161

Session: (7) 04/04/2023

Node: (14) Heavy HCs KO drum

Notes:

Drawings: I20784 Sh 70

Parameter: Temperature

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	188. Higher Temperature (cont.)	188.5. Malfunction of TDY-1644 to not switch off H16201 on demand or to switch on when not required (cont.)	188.5.1. Higher temperature of gas routed to thermal oxidizer and potential for damage to internals (economical losses) (cont.)  188.5.2. Higher temperature of gas on V16200 overhead line. According to limited duty of H16201 temperature build up is estimated in approximately 10 °C with no impact on mechanical integrity of piping  188.5.3. Possible overheating of H16201 electrical bundle leading to mechanical damage and economical losses	188.5.3.1. TAHH-1641 activate trip of H16201	...trip H16201  :See 53		

Session: (8) 05/04/2023

Node: (14) Heavy HCs KO drum

Notes:

Drawings: I20784 Sh 70

Parameter: Pressure

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	189. Lower Pressure	189.1. No causes identified					
More	190. Higher Pressure	190.1. Refer to no/less and more flow in this node  190.2. External fire	190.2.1. Overpressurization of involved equipment	190.2.1.1. PSV-914 to protect V16200 including fire scenario			



# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023  
 Node: (14) Heavy HCs KO drum  
 Notes:  
 Drawings: I20784 Sh 70  
 Parameter: Level

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	191. No/less Level	191.1. See higher temperature in this node					
More	192. Higher Level	192.1. Failure on demand of H16200 including malfunction of LI-1641	192.1.1. Liquid accumulation on V16200 resulting in possible overflowing and liquid carry over to thermal oxidizer leading to operational upset/possible damage	192.1.1.1. LAHH-1640 activate trip of thermal oxidizer and close HV-1645	:See 52 54. LAHH-1640 shall also close HV-1646 to prevent potential liquid backflow to S2011 and trip H16201 to prevent thermal expansion of trapped material	SIAD MI	

Session: (8) 05/04/2023  
 Node: (14) Heavy HCs KO drum  
 Notes:  
 Drawings: I20784 Sh 70  
 Parameter: Composition

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	193. Different Composition	193.1. No causes identified					

Session: (8) 05/04/2023  
 Node: (14) Heavy HCs KO drum  
 Notes:  
 Drawings: I20784 Sh 70  
 Parameter: Other

Intention:

Equipment: V16200

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Other Than	194. Other Than Other	194.1. Corrosion due to presence of CO2 is not expected according to operating condition (low partial pressure) and material selection (stainless steel)					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (15) LNG drain KO drum and cold flare

Intention:

Notes:

Drawings: I20784 Sh 39A

Equipment: V16000, FL16000

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	195. No/less Flow	195.1. No cause identified (during normal operation)					
	196. No/less Flow (nitrogen flushing)	196.1. Refer To node #32					
More	197. More Flow	197.1. Relief scenario - worst case (PV-703 wide opening leading to intervention of PV-705 or HV-715)	197.1.1. No impact since cold flare and cold flare header are sized according to worst relief scenario				
Reverse	198. Reverse Flow	198.1. Refer To node #32 for potential air entrainment in case of loss of flushing nitrogen					
Misdirect	199. Misdirect Flow	199.1. Unexpected intervention of snuffing gas system	199.1.1. Emptying of snuffing gas cylinders leading to unavailability on demand	199.1.1.1. Weight scale provided including alarm to detect emptying of cylinders (minimum requirement to vendor)			
		199.2. Cold flare drain valve left open after maintenance or valve passing	199.2.1. Continuous leakage of nitrogen during normal operation. Potential hydrocarbon leak with fire hazard in case of relief on cold flare header		55. Provide additional positive isolation device on cold flare bottom drain line	SIAD MI	

Session: (7) 04/04/2023

Node: (15) LNG drain KO drum and cold flare

Intention:

Notes:

Drawings: I20784 Sh 39A

Equipment: V16000, FL16000

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	200. Lower Temperature	200.1. Cold relief	200.1.1. No consequences since flare header material is compliant with cryogenic service				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023  
 Node: (15) LNG drain KO drum and cold flare  
 Notes:  
 Drawings: I20784 Sh 39A  
 Parameter: Temperature

Intention:

Equipment: V16000, FL16000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less (cont.)	200. Lower Temperature (cont.)	200.2. Low ambient temperature	200.2.1. In case of injection of snuffing gas (CO2) potential condensation leading to potential mechanical damage of cold flare tip		56. Investigate if CO2 is suitable for snuffing purpose on cold flare, taking into account minimum ambient temperature and possibility of condensation	SIAD MI	
More	201. Higher Temperature	201.1. Hot relief due to fire scenario  201.2. Ignition of gas at cold flare tip during relief scenario	201.1.1. No impact on mechanical integrity of flare header according to relevant design temperature (260°C) defined taking into account worst case for relief scenario in case of external fire  201.2.1. Potential mechanical damage of cold flare tip leading to operation disruption (plant shut down for unplanned maintenance)	201.2.1.1. TAHH-1600 activate snuffing system by opening solenoid valves provided on each cylinder (3 cylinder in operation and 3 in stand-by)			No injuries to personnel expected since flare elevation has been defined to not exceed 3 kW/m2 at 1.5 m above ground level, at 1 m from flare stack

Session: (7) 04/04/2023  
 Node: (15) LNG drain KO drum and cold flare  
 Notes:  
 Drawings: I20784 Sh 39A  
 Parameter: Pressure

Intention:

Equipment: V16000, FL16000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	202. Lower Pressure	202.1. See no/less and misdirect flow  202.2. See no/less flow of nitrogen (node #32)					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (15) LNG drain KO drum and cold flare

Notes:

Drawings: I20784 Sh 39A

Parameter: Pressure

Intention:

Equipment: V16000, FL16000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	203. Higher Pressure	203.1. Relief scenario - worst case (PV-703 wide opening leading to intervention of PV-705 or HV-715)	203.1.1. Increase back pressure on cold flare header up to 1 barg with no impact on functionality of pressure relief devices since they're designed taking into account maximum back pressure on cold flare header				

Session: (7) 04/04/2023

Node: (15) LNG drain KO drum and cold flare

Notes:

Drawings: I20784 Sh 39A

Parameter: Level

Intention:

Equipment: V16000, FL16000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	204. No/less Level	204.1. No causes identified					
More	205. Higher Level	205.1. Refer to misdirect flow in node #11 (opening of HV-711) for massive incoming liquid flowrate from LNG separator S7003					

Session: (7) 04/04/2023

Node: (15) LNG drain KO drum and cold flare

Notes:

Drawings: I20784 Sh 39A

Parameter: Composition

Intention:

Equipment: V16000, FL16000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	206. Different Composition	206.1. No additional causes identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 125 of 161

Session: (8) 05/04/2023

Node: (20) Cooling water circuit

Intention: OT to process = 40 °C , OT return = 50 °C

Notes:

Drawings: I20784 Sh 50; I20784 Sh 51; I20784 Sh 65; I20784 Sh 66; I20784 Sh 67; I20784 Sh 68

Parameter: Composition

Equipment: E8000, E8001, P8000A/B, V8000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	207. Different Composition	207.1. Injection of biocide agent	:		57. Properties of biocide agent and potential associated hazards to be investigated	SIAD MI	

Session: (8) 05/04/2023

Node: (20) Cooling water circuit

Intention: OT to process = 40 °C , OT return = 50 °C

Notes:

Drawings: I20784 Sh 50; I20784 Sh 51; I20784 Sh 65; I20784 Sh 66; I20784 Sh 67; I20784 Sh 68

Parameter: Services / Utilities

Equipment: E8000, E8001, P8000A/B, V8000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	208. No Services / Utilities	208.1. Loss of electrical power	208.1.1. Unavailability of cooling water and loss of circulation leading to potential freezing	208.1.1.1. Cooling water pumps P8000A/B are supplied by EDG (automatically started in case of black out)			

Session: (8) 05/04/2023

Node: (20) Cooling water circuit

Intention: OT to process = 40 °C , OT return = 50 °C

Notes:

Drawings: I20784 Sh 50; I20784 Sh 51; I20784 Sh 65; I20784 Sh 66; I20784 Sh 67; I20784 Sh 68

Parameter: Other

Equipment: E8000, E8001, P8000A/B, V8000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Other Than	209. Other Than Other	209.1. Removal of vibration protection from air cooler fans	209.1.1. No impact expected under safety prospective since area underneath air coolers is not accessible (damage to personnel in case of fan mechanical failure is not possible)				
		209.2. Unavailability of cooling water circuit (loss of circulation or higher temperature due to air cooler failure)	209.2.1. See nodes relevant to cooling water users for impact on process in case of unavailability of cooling water				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 126 of 161

Session: (8) 05/04/2023

Node: (21) Steam generation

Intention:

Notes:

Drawings: I20784 Sh 10; I20784 Sh 15; I20784 Sh 37; I20784 Sh 38; I20784 Sh 50

Equipment: V15100, P15100A/B, SG15200

Parameter: Other

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Other Than	210. Other Than Other	210.1. Unavailability of steam circuit (loss of circulation)	210.1.1. See nodes relevant to steam users for impact on process in case of unavailability of steam				

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023

Node: (22) Condensate collection

Intention:

Notes:

Drawings: I20784 Sh 10; I20784 Sh 16; I20784 Sh 37; I20784 Sh 38; I20784 Sh 50

Equipment: HW15000, P15000

Parameter: Level

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	211. Higher Level	211.1. Unavailability of condensate pump P15000	211.1.1. Level build up in condensate collection drum, leading to potential overflowing and release of hot condensate (85°C) from vent leading to possible injuries to personnel		58. Ensure condensate collection drum vent to be routed to safe location	SIAD MI	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 128 of 161

Session: (8) 05/04/2023

Node: (23) Chilled water circuit

Notes:

Drawings: I20784 Sh 15; I20784 Sh 25; I20784 Sh 36; I20784 Sh 51

Parameter: Temperature

Intention: P11000A/B: OPsuction = 2 barg, OPdischarge = 4 barg

Equipment: P11000A/B, V11000, FRU11000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	212. Lower Temperature	212.1. Chilled water pump P11000A/B shut down	212.1.1. Possible freezing on piping downstream chilled package due to thermal inertia of chiller	212.1.1.1. Adequate glycol content to prevent freezing of chilled water			

Session: (8) 05/04/2023

Node: (23) Chilled water circuit

Notes:

Drawings: I20784 Sh 15; I20784 Sh 25; I20784 Sh 36; I20784 Sh 51

Parameter: Services / Utilities

Intention: P11000A/B: OPsuction = 2 barg, OPdischarge = 4 barg

Equipment: P11000A/B, V11000, FRU11000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	213. No Services / Utilities	213.1. Loss of electrical power	213.1.1. Unavailability of chilled water and loss of circulation leading to potential freezing	213.1.1.1. Chilled water pumps P11000A/B are supplied by EDG (automatically started in case of black out)			

Session: (8) 05/04/2023

Node: (23) Chilled water circuit

Notes:

Drawings: I20784 Sh 15; I20784 Sh 25; I20784 Sh 36; I20784 Sh 51

Parameter: Other

Intention: P11000A/B: OPsuction = 2 barg, OPdischarge = 4 barg

Equipment: P11000A/B, V11000, FRU11000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Other Than	214. Other Than Other	214.1. Unavailability of chilled water circuit (loss of circulation or higher temperature due to chiller failure)	214.1.1. See nodes relevant to chilled water users for impact on process in case of unavailability of chilled water				



# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023  
 Node: (24) Demi water package  
 Notes:  
 Drawings: I20784 Sh 68  
 Parameter: Composition

Intention:

Equipment:

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	215. High Concentration	215.1. Higher salt (conductivity) on reverse osmosis drain	215.1.1. Possible off spec stream to downstream treatment unit		59. Investigate potential impact of waste water from demi water package routed to waste water collection/treatment system	OGE (TPLT)	

Session: (8) 05/04/2023  
 Node: (24) Demi water package  
 Notes:  
 Drawings: I20784 Sh 68  
 Parameter: Other

Intention:

Equipment:

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Other Than	216. Other Than Other	216.1. Handling of chemicals harmful for eye and skin	216.1.1. Possible injuries to personnel in case of leakage		60. Investigate requirement for emergency showers/eye showers on demi water package due to presence of harmful chemicals	OGE (TZSA)	

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023

Node: (25) Instrument air production

Intention:

Notes:

Drawings: I20784 Sh 42; I20784 Sh 43; I20784 Sh 60

Equipment: F7701, V7701, V7703, V7702

Parameter: Pressure

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	217. Lower Pressure	217.1. Upset on instrument air package	217.1.1. Loss of instrument air to users resulting in taking of fail safe position for each pneumatic valve leading to unexpected plant shut-down	217.1.1.1. Nitrogen back up activated by any malfunction on the package (to open HV-1601 (FO) and consequent nitrogen injection through PCV-1612)			
More	218. Higher Pressure	218.1. Malfunction of PCV-770 (fully open)	218.1.1. IA supplied to header at 12 barg instead of 7 barg. No impact on mechanical integrity of piping according to relevant schedule (DP = 16 barg)	218.1.2.1. PSV-771			
		218.2. Malfunction of dedicated inlet filter reducer on single pneumatic valve	218.2.1. Possible damage of actuator on involved pneumatic valve with economical losses / impact on operation	218.2.1.1. Pneumatic valves provided with inlet filter reducer are protected by dedicated PSVs to prevent damage in case of inlet filter reducer failure			

Session: (8) 05/04/2023

Node: (25) Instrument air production

Intention:

Notes:

Drawings: I20784 Sh 42; I20784 Sh 43; I20784 Sh 60

Equipment: F7701, V7701, V7703, V7702

Parameter: Composition

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	219. Different Composition	219.1. Upset in instrument air package leading to inadequate drying of air	219.1.1. Possible presence of humidity on IA supply to pneumatic valve leading to accumulation on valve pressure...	219.1.1.1. Dew point analyzer provided on AI package as minimum requirement for vendor			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023

Node: (25) Instrument air production

Intention:

Notes:

Drawings: I20784 Sh 42; I20784 Sh 43; I20784 Sh 60

Equipment: F7701, V7701, V7703, V7702

Parameter: Composition

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different (cont.)	219. Different Composition (cont.)	219.1. Upset in instrument air package leading to inadequate drying of air (cont.)	...reducer drainage pot and potential for damage in case of freezing due to ambient temperature	219.1.1.1. Dew point analyzer provided on AI package as minimum requirement for vendor (cont.)			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	220. No/less Flow	<p>220.1. Malfunction of PIC-740A closing PV-740A on nitrogen make up stream or any other cause for loss of nitrogen make-up or unexpected closure of HV-714, HV-706</p> <p>220.2. Unexpected closure of PCV-736</p>	<p>220.1.1. Inadequate compensation of nitrogen losses through compressor and turbine seals with loss of efficiency of nitrogen compressor overtime and upset in liquefaction (nitrogen make up is approximately 0,3% of nitrogen circulation to compressor)</p> <p>220.1.2. In case of unexpected closure of HV-714, HV-706, loss of nitrogen purging to cold box resulting in potential humidity entrainment and consequent freezing and potential ice formation on perlite pellet leading to decrease in efficiency of primary exchanger overtime</p> <p>220.2.1. In case of unexpected closure of HV-714, HV-706, loss of nitrogen purging to cold box resulting in potential humidity entrainment and consequent freezing and potential ice formation on perlite pellet...</p>	<p>220.1.1.1. Independent pressure monitoring at compressor suction</p> <p>220.1.2.1. Nitrogen back-up through PCV-737</p> <p>220.1.2.2. Routine inspection on PDI-735 and PDI-739</p> <p>220.2.1.1. Routine inspection on PDI-735 and PDI-739</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 133 of 161

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	220. No/less Flow (cont.)	<p>220.2. Unexpected closure of PCV-736 (cont.)</p> <p>220.3. Potential plugging of temporary strainer on compressor C7400 suction</p> <p>220.4. Compressor failure/stop (any cause)</p>	<p>...leading to decrease in efficiency of primary exchanger overtime</p> <p>220.3.1. No impact during normal operation since this strainer will be removed after start-up phase</p> <p>220.4.1. Loss of circulation for cooling medium resulting in loss of LNG production (see higher temperature in node #11)</p> <p>220.4.2. Lower suction pressure/flowrate for C7500/C7600 turbines boosters resulting in lower speed on turbines T7500/T7600 and potential for mechanical stress leading to reduction in equipment lifetime (economical losses)</p> <p>220.4.3. Lower suction pressure/flowrate for C7500/C7600 turbines boosters resulting in potential surge condition leading to turbines...</p>	<p>220.2.1.1. Routine inspection on PDI-735 and PDI-739 (cont.)</p> <p>220.4.2.1. PALL-750 activate shut-down of turbines T7500/T7600 and relevant boosters (through closure of HV-710/712 and opening UV-760)</p> <p>220.4.3.1. Anti surge control system opening UV-760</p> <p>220.4.3.2. PALL-750...</p>			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 134 of 161

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	220. No/less Flow (cont.)	220.4. Compressor failure/stop (any cause) (cont.)  220.5. Malfunction of compressor capacity control system leading to closure of compressor IGV	...boosters damage and consequent extensive damage (major economical losses including operation disruption)/ possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)  220.5.1. Possible reduced suction pressure/flowrate resulting in potential surge condition leading to compressor damage and consequent extensive damage (major economical losses including operation disruption)/ possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)  220.5.2. Reduction of circulation for cooling medium resulting in...	...activate shut-down of turbines T7500/T7600 and relevant boosters (through closure of HV-710/712 and opening UV-760)  220.4.3.3. Oxygen monitoring inside building to give alarm (inside horn and outside light)  220.5.1.1. Anti surge control system to open compressor by-pass valve (PCV)  220.5.1.2. USPM system to trip compressor in case of surge conditions  220.5.1.3. Oxygen monitoring inside building to give alarm (inside horn and outside light)			These safeguards are reported in detailed P&IDs of nitrogen compressor loop

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 135 of 161

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	220. No/less Flow (cont.)	<p>220.5. Malfunction of compressor capacity control system leading to closure of compressor IGV (cont.)</p> <p>220.6. Potential plugging of strainer on turbine boosters C7500/7600 suction</p> <p>220.7. Unexpected closure of UV-761</p>	<p>...reduced efficiency of LNG production (see higher temperature in node #11)</p> <p>220.6.1. Slight reduction on turbine boosters C7500/7600 efficiency and consequent potential minor operational upset</p> <p>220.7.1. Lower speed on turbines T7500/T7600 and potential for mechanical stress leading to reduction in equipment lifetime (economical losses)</p> <p>220.7.2. Loss of circulation for cooling medium resulting in loss of LNG production (see higher temperature in node #11)</p>	<p>220.7.1.1. Low low speed interlock protection SALL 9B on cold turbine and SALL 9A on warm turbine to close HV-712/HV-710</p>	<p>61. Provide differential pressure measurements across filters on turbine boosters C7500/7600 suctions by using existing instrumentation</p>	SIAD MI	<p>Additional temporary filter is provided for commissioning phase only. This temporary filter will be removed for normal operation as per SIAD commissioning procedure</p>

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	220. No/less Flow (cont.)	220.7. Unexpected closure of UV-761 (cont.)	220.7.3. Blocked outlet condition for compressor resulting in potential surge condition leading to compressor damage and consequent extensive damage (major economical losses including operation disruption)/ possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)	220.7.3.1. Anti surge control system to open compressor by-pass valve (PCV)  220.7.3.2. USPM system to trip compressor in case of surge conditions  220.7.3.3. Oxygen monitoring inside building to give alarm (inside horn and outside light)			
			220.7.4. Blocked outlet condition for boosters resulting in potential pressure build up on boosters discharge side leading to potential overpressurization (DP=31 barg), mechanical damage and potential injuries to personnel/nitrogen accumulation inside building with asphyxiation hazard	220.7.4.1. Anti surge control system opening UV- 760  220.7.4.2. PSV-755 (warm booster outlet) and PSV- 765 (cold booster outlet)			
		220.8. Potential plugging of strainer on turbine...	220.8.1. Slight reduction on turbine T7500/7600 efficiency...		62. Provide differential pressure measurements...	SIAD MI	Additional temporary filter is provided for...



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	220. No/less Flow (cont.)	...T7500/7600 suctions  220.9. Unexpected closure of HV-712 or HV-710 (quick closing valves)	...and consequent potential minor operational upset  220.9.1. Loss of circulation for cooling medium resulting in loss of LNG production (see higher temperature in node #11)  220.9.2. Blocked outlet condition for compressor resulting in potential surge condition leading to compressor damage and consequent extensive damage (major economical losses including operation disruption)/ possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)	220.9.2.1. Anti surge control system to open compressor by-pass valve (PCV)  220.9.2.2. USPM system to trip compressor in case of surge conditions  220.9.2.3. Oxygen monitoring inside building to give alarm (inside horn and outside light)	...across filters on turbines T7500/7600 suctions by using existing instrumentation		...commissioning phase only. This temporary filter will be removed for normal operation as per SIAD commissioning procedure  Any inizerator that lead to turbine trip will also will also unload the compressor and open the by-pass valve UV-760 on boosters by-pass lines

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	221. More Flow	<p>221.1. Malfunction of compressor capacity control system leading to opening of compressor IGV more than required</p> <p>221.2. Control room operator to increase opening of IGV on warm or cold turbine</p>	<p>221.1.1. No significant consequences expected on process side and machine integrity</p> <p>221.1.2. Possible overload of C7400 compressor motor resulting in damage with economical losses</p> <p>221.2.1. Increased speed of turbine with potential overspeed and possible damage to turbine with economical losses</p> <p>221.2.2. Increased speed of turbine with loss of efficiency in cooling capacity (see impact on node #11)</p>	<p>221.1.2.1. Overload protection (high windings temperature) provided on compressor motor to trip the motor itself</p> <p>221.2.1.1. High high speed interlock protection SAHH 9B on cold turbine and SAHH 9A on warm turbine to close HV-712/HV-710</p>			
Reverse	222. Reverse Flow	<p>222.1. No causes identified</p> <p>222.2. UV-761 doesn't close on demand (section shut down and depressurization)</p>	<p>222.2.1. Possible counter rotation of boosters and turbine. Damage is not expected since lubrication...</p>				

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Reverse (cont.)	222. Reverse Flow (cont.)	222.2. UV-761 doesn't close on demand (section shut down and depressurization) (cont.)	...is ensured by electrical driven lube oil pump (as per minimum requirement to vendor)				
Misdirect	223. Misdirect Flow	223.1. Malfunction of PIC-740B opening PV-740B when not required	223.1.1. Nitrogen partially routed to atmosphere (safe location) leading to lower suction pressure/flowrate for C7500/C7600 turbines boosters resulting in potential surge condition leading to turbines boosters damage and consequent extensive damage (major economical losses including operation disruption)/ possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)  223.1.2. Loss of nitrogen to atmosphere resulting in reduced circulation of cooling medium resulting in loss of LNG production (see higher temperature in node #11)	223.1.1.1. Anti surge control system opening UV-760  223.1.1.2. PALL-750 activate shut-down of turbines T7500/T7600 and relevant boosters (through closure of HV-710/712 and opening UV-760)  223.1.1.3. Oxygen monitoring inside building to give alarm (inside horn and outside light)			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 140 of 161

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	223. Misdirect Flow (cont.)	223.2. Malfunction of compressor antisurge control system opening PCV	223.2.1. Lower speed on turbines T7500/T7600 and potential for mechanical stress leading to reduction in equipment lifetime (economical losses)  223.2.2. Loss of circulation for cooling medium resulting in loss of LNG production (see higher temperature in node #11)  223.2.3. Pressure build up on compressor suction side leading to potential overpressurization, mechanical damage and potential injuries to personnel/nitrogen accumulation inside building with asphyxiation hazard	223.2.1.1. Low low speed interlock protection SALL 9B on cold turbine and SALL 9A on warm turbine to close HV-712/HV-710  223.2.3.1. PIC-740B to open PV-740B discharging to atmosphere (safe location) adequate for this scenario  223.2.3.2. Independent pressure monitoring at compressor suction with high high pressure interlock  223.2.3.3. PSV-741 sized including this scenario			
		223.3. Tube rupture in HW7400	223.3.1. Nitrogen at 27 barg enters into HW7400 and chilled ...	223.3.1.1. PSV-746 sized including this scenario			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 141 of 161

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	223. Misdirect Flow (cont.)	223.3. Tube rupture in HW7400 (cont.)	...water circuit (DP=8 barg) with potential mechanical damage and potential injuries to personnel	223.3.1.1. PSV-746 sized including this scenario (cont.)			
		223.4. Tube rupture in HW7601	223.4.1. Nitrogen at 70 barg enters into HW7601 and chilled water circuit (DP=8 barg) with potential mechanical damage and potential injuries to personnel	223.4.1.1. PSV-763 sized including this scenario			
		223.5. Unexpected opening of UV-760	223.5.1. Unloading condition for turbine booster resulting in loss of efficiency of cold turbine and reduction of cooling capacity (see impact on node #11)	223.5.1.1. Discrepancy alarm on UV			
			223.5.2. Pressure build up on compressor discharge side leading to potential overpressurization (DP=31 barg), mechanical damage and potential injuries to personnel/nitrogen accumulation inside building with asphyxiation hazard	223.5.2.1. Anti surge control system to open compressor by-pass valve (PCV)  223.5.2.2. USPM system to trip compressor in case of surge conditions  223.5.2.3. PSV-749 sized including this scenario			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

**Notes:**

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect (cont.)	223. Misdirect Flow (cont.)	223.6. Unexpected opening of UV-763	223.6.1. Nitrogen partially routed to atmosphere (safe location) leading to lower suction pressure/flowrate for C7500/C7600 turbines boosters resulting in potential surge condition leading to turbines boosters damage and consequent extensive damage (major economical losses including operation disruption)/ possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)  223.6.2. Loss of nitrogen to atmosphere resulting in reduced circulation of cooling medium resulting in loss of LNG production (see higher temperature in node #11)	223.6.1.1. Anti surge control system opening UV- 760  223.6.1.2. PALL-750 activate shut-down of turbines T7500/T7600 and relevant boosters (through closure of HV-710/712 and opening UV-760)  223.6.1.3. Oxygen monitoring inside building to give alarm (inside horn and outside light)			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C  
 C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg  
 E7400/E7401: OTin = 126 °C, OTout = 40 °C  
 C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg  
 E7500: OTin = 88,2 °C, OTout = 40 °C  
 C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg  
 E7600: OTin = 105,4 °C, OTout = 40 °C  
 HW7601: OTin = 40 °C, OTout = 10 °C  
 CB7000: OTin = 10 °C, OTout = - 160 °C  
 T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

**Notes:**

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Temperature

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	224. Lower Temperature	224.1. Malfunction of TIC-747 or TIC-748 increasing speed of fan E7400/E7401  224.2. Malfunction of TIC-754 or TIC-764 increasing speed of fan E7500/E7600  224.3. No causes identified for warm turbine T7500  224.4. No causes identified for cold turbine T7600 during normal operation  224.5. Start up in cold condition for cold turbine T7600 including malfunction of TIC-712 closing TV-712  224.6. Refer to More Level in node #31 for liquid nitrogen carry over from LNG subcooler from primary heat exchanger	224.1.1. Negligible impact on process side  224.2.1. Negligible impact on process side  224.5.1. Possible liquid nitrogen formation at turbine outlet resulting in potential damage to turbine impeller (economical losses including potential for major operation disruption)	224.5.1.1. TALL-714/713 activate closure of HV-710/712			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 144 of 161

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Temperature

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	225. Higher Temperature	225.1. Malfunction of TIC-747 or TIC-748 reducing speed of fan E7400/E7401 or air coolers E7400/E7401 failure	<p>225.1.1. Temperature build up on compressor second stage suction (approximately 106°C instead of 40°C) with potential overheating and mechanical damage (possible damage to impeller bearings and motor overload, economical losses)</p> <p>225.1.2. Higher temperature of nitrogen sent to downstream sections (DT = 65°C) with possible mechanical damage of piping overtime leading to loss of containment resulting in possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)/possible injuries due to contact with hot product</p> <p>225.1.3. Higher temperature of stream routed to primary heat exchanger (DT=65°C) resulting in possible mechanical damage due to overheating and consequent economical losses/operation...</p>	<p>225.1.1.1. TAHH-749/TAHH-3101 activate trip of compressor</p> <p>225.1.2.1. TAHH-749/TAHH-3101 activate trip of compressor</p> <p>225.1.2.2. Oxygen monitoring inside building to give alarm (inside horn and outside light)</p> <p>225.1.3.1. TAHH-708 activate trip of compressor</p>			TAHH-3101 represented in detailed P&ID of nitrogen compressor



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Temperature

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	225. Higher Temperature (cont.)	225.1. Malfunction of TIC-747 or TIC-748 reducing speed of fan E7400/E7401 or air coolers E7400/E7401 failure (cont.)  225.2. Loss of chilled water to HW7400  225.3. Malfunction of TIC-754...	...disruption  225.1.4. Higher temperature of stream routed to primary heat exchanger (DT=65°C) resulting in possible mechanical damage due to overheating leading to possible leakages of pressurized nitrogen inside cold box with potential overpressurization and mechanical damage (injuries to personnel)  225.2.1. Higher temperature of nitrogen stream at the outlet of HW7400 (40°C instead of 10°C) with no impact on mechanical integrity downstream equipment  225.2.2. Loss of efficiency of primary heat exchanger resulting in higher temperature in node #11 (partial loss of LNG production)  225.3.1. Higher temperature of...	225.1.3.1. TAHH-708 activate trip of compressor (cont.)  225.1.4.1. TAHH-708 activate trip of compressor  225.1.4.2. Overpressure hatch provided on cold box  225.2.2.1. TAHH-708 activate trip of compressor  225.3.1.1. Oxygen...	63. Relocate TAHH-752...	SIAD...	Additional...

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 146 of 161

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Temperature

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	225. Higher Temperature (cont.)	...or TIC-764 reducing speed of fan E7500/E7600 or air coolers E7500/E7600 failure	<p>...stream routed to downstream systems leading to possible overheating on downstream sections leading to loss of containment resulting in possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)/possible injuries due to contact with hot product</p> <p>225.3.2. Higher temperature of stream routed to cold booster C7600 inlet (approximately 90°C instead of 40°C) and potential damage due to overheating and economical losses</p> <p>225.3.3. Higher temperature of stream routed to primary heat exchanger (DT=65°C) resulting in possible mechanical damage due to overheating and consequent economical losses/operation disruption</p> <p>225.3.4. Higher temperature of...</p>	<p>...monitoring inside building to give alarm (inside horn and outside light)</p> <p>225.3.3.1. TAHH-709 activate closure of HV-710/712</p> <p>225.3.4.1. TAHH-709...</p>	<p>...downstream E7500 and TAHH-762 downstream E7600</p> <p>64. Consider to review DT of piping downstream aircoolers E7400/7401/7500/7600 taking into account air cooler failure scenario</p> <p>:See 63</p>	<p>...MI</p> <p>SIAD MI</p>	<p>...temperature monitoring at warm and cold boosters outlet is provided as per scope of work of relevant manufacturer (see detailed machine P&amp;ID)</p> <p>Action of TAHH-752 is to close quick closing valves HV-710/712</p>

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C  
 C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg  
 E7400/E7401: OTin = 126 °C, OTout = 40 °C  
 C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg  
 E7500: OTin = 88,2 °C, OTout = 40 °C  
 C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg  
 E7600: OTin = 105,4 °C, OTout = 40 °C  
 HW7601: OTin = 40 °C, OTout = 10 °C  
 CB7000: OTin = 10 °C, OTout = - 160 °C  
 T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

**Notes:**

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Temperature

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	225. Higher Temperature (cont.)	225.3. Malfunction of TIC-754 or TIC-764 reducing speed of fan E7500/E7600 or air coolers E7500/E7600 failure (cont.)  225.4. Loss of chilled water to HW7601  225.5. Malfunction of TIC-712 opening TV-712 when not required	...stream routed to primary heat exchanger (DT=65°C) resulting in possible mechanical damage due to overheating leading to possible leakages of pressurized nitrogen inside cold box with potential overpressurization and mechanical damage (injuries to personnel)  225.4.1. Higher temperature of nitrogen stream at the outlet of HW7601 (40°C instead of 10°C) with no impact on mechanical integrity downstream equipment  225.4.2. Loss of efficiency of primary heat exchanger resulting in higher temperature in node #11 (partial loss of LNG production)  225.5.1. Higher temperature of HPN stream to cold turbine stream resulting in slight reduction of efficiency for cold turbine	...activate closure of HV-710/712  225.3.4.2. Overpressure hatch provided on cold box  225.4.2.1. TAHH-709 activate closure of HV-710/712  225.5.1.1. Event detectable by TI-714/713			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C

C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg

E7400/E7401: OTin = 126 °C, OTout = 40 °C

C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg

E7500: OTin = 88,2 °C, OTout = 40 °C

C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg

E7600: OTin = 105,4 °C, OTout = 40 °C

HW7601: OTin = 40 °C, OTout = 10 °C

CB7000: OTin = 10 °C, OTout = - 160 °C

T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

**Notes:**

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Pressure

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	226. Lower Pressure	226.1. Refer to no/less and misdirect flow					
More	227. Higher Pressure	227.1. Refer to no/less flow  227.2. Malfunction of PIC-740A fully opening PV-740A on nitrogen make-up  227.3. Malfunction of PCV-736 (fully opening)	227.2.1. Pressure build up overtime on compressor suction side with consequent possible mechanical stress and damage to rotating parts of first stage (economical losses)  227.2.2. Pressure build up overtime on compressor suction side with no impact on mechanical integrity of piping and compressor casing according to design criteria  227.3.1. Nitrogen sent to cold box casing at 10 barg instead of 0,2 barg with potential overpressurization, mechanical damage and economical...	227.2.1.1. Independent pressure monitoring at compressor suction including high high pressure trip (see detailed compressor P&ID)  227.2.1.2. PSV-741 sized including this scenario  227.3.1.1. Pressure monitoring on cold box  227.3.1.2. Overpressure hatch provided on cold box			

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C  
 C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg  
 E7400/E7401: OTin = 126 °C, OTout = 40 °C  
 C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg  
 E7500: OTin = 88,2 °C, OTout = 40 °C  
 C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg  
 E7600: OTin = 105,4 °C, OTout = 40 °C  
 HW7601: OTin = 40 °C, OTout = 10 °C  
 CB7000: OTin = 10 °C, OTout = - 160 °C  
 T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

**Notes:**

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Pressure

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	227. Higher Pressure (cont.)	227.3. Malfunction of PCV-736 (fully opening) (cont.)  227.4. Thermal expansion of trapped liquid/cold gas	...losses/injuries to personnel  227.4.1. Possible mechanical damage on involved pipe/equipment	227.3.1.2. Overpressure hatch provided on cold box (cont.)  227.4.1.1. PSV-706 (pass N), PSV-709 (pass HPN2) on nitrogen side to protect primary exchanger  227.4.1.2. PSV-763 on HW7601 shell side  227.4.1.3. PSV-746 on HW7004 shell side			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C  
 C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg  
 E7400/E7401: OTin = 126 °C, OTout = 40 °C  
 C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg  
 E7500: OTin = 88,2 °C, OTout = 40 °C  
 C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg  
 E7600: OTin = 105,4 °C, OTout = 40 °C  
 HW7601: OTin = 40 °C, OTout = 10 °C  
 CB7000: OTin = 10 °C, OTout = - 160 °C  
 T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Level

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	228. No/less Level	228.1. Not applicable					
More	229. Higher Level	229.1. Not applicable					

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Intention: HX7000: OTin = -168 °C, OTout = 8,1 °C  
 C7400: OPsuction = 6,1 barg, OPdischarge = 28,3 barg  
 E7400/E7401: OTin = 126 °C, OTout = 40 °C  
 C7500: OPsuction = 28,2 barg, OPdischarge = 42 barg  
 E7500: OTin = 88,2 °C, OTout = 40 °C  
 C7600: OPsuction = 41,9 barg, OPdischarge = 69 barg  
 E7600: OTin = 105,4 °C, OTout = 40 °C  
 HW7601: OTin = 40 °C, OTout = 10 °C  
 CB7000: OTin = 10 °C, OTout = - 160 °C  
 T7600: OPsuction = 68,4 barg, OPdischarge = 6,6 barg

Notes:

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Composition

Equipment: CB7000, SE7400, C7400, E7400, E7401, C7500, E7500, C7600, E7600, HW7601, SE7500, T7600

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	230. Different Composition	230.1. No causes identified for make-up nitrogen (supplied by cryogenic storage)					



# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (31) LNG subcooler

Intention: T7500: OPsuction = 28,12 barg, OPdischarge = 6,5 barg

HW7400: OTin = 40 °C, OTout = 10 °C

HX7000: OTin = -160,42 °C, OTout = 8,1 °C

Notes:

Drawings: I20784 Sh 23

Parameter: Flow

Equipment: SC7001, E7001, T7500, HW7400, HX7000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	231. No/less Flow (cont.)	231.2. Malfunction of PIC-719 closing PV-719 (cont.)  231.3. No causes identified for subcooler bottom line (NNF)	...overpressurization of cold box with mechanical damage (injuries to personnel)	...hatch on cold box			
More	232. More Flow	232.1. No causes identified					
Reverse	233. Reverse Flow	233.1. No causes identified					
Misdirect	234. Misdirect Flow	234.1. Inadvertent opening of HV-720	234.1.1. Nitrogen vaporized and sent to safe location with loss of nitrogen and economical losses  234.1.2. Nitrogen vaporized and sent to safe location with loss of nitrogen with loss of level in SC7001 (loss of cooling medium through SC7001) with partial loss of LNG production (operation disruption/economical losses)	234.1.2.1. LALL-720 activate closure of HV-700	65. Provide a PLC function to not allow manual selection of HV-720 if plant is detected in operating mode	SIAD MI	



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (31) LNG subcooler

Intention: T7500: OPsuction = 28,12 barg, OPdischarge = 6,5 barg

HW7400: OTin = 40 °C, OTout = 10 °C

HX7000: OTin = -160,42 °C, OTout = 8,1 °C

Notes:

Drawings: I20784 Sh 23

Parameter: Temperature

Equipment: SC7001, E7001, T7500, HW7400, HX7000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	235. Lower Temperature	235.1. No causes identified					
More	236. Higher Temperature	236.1. See No/Less flow in this node					

Session: (6) 03/04/2023

Node: (31) LNG subcooler

Intention: T7500: OPsuction = 28,12 barg, OPdischarge = 6,5 barg

HW7400: OTin = 40 °C, OTout = 10 °C

HX7000: OTin = -160,42 °C, OTout = 8,1 °C

Notes:

Drawings: I20784 Sh 23

Parameter: Pressure

Equipment: SC7001, E7001, T7500, HW7400, HX7000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	237. Lower Pressure	237.1. Malfunction of PIC-719 fully opening PV-719	237.1.1. Increased consumption of liquid nitrogen with slight reduction of efficiency of liquefaction loop	237.1.1.1. Event detectable by PI-722			
More	238. Higher Pressure	238.1. Refer to no/less flow in this node  238.2. Malfunction of LIC-719 wide opening LV-719	238.2.1. Sudden increase of two phase flow (OP=70 barg) of nitrogen stream to LNG subcooler (DP = 8 barg) leading to potential overpressurization, mechanical damage and injuries to personnel	238.2.1.1. PSV-718 sized for this scenario			PAHH-722 would not be 100% effective in this case to prevent overpressurization
		238.3. External fire/Thermal expansion	238.3.1. Overpressurization of involved equipment/piping with possible mechanical damage	238.3.1.1. PSV-718 sized including this scenario			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (31) LNG subcooler

Intention: T7500: OPsuction = 28,12 barg, OPdischarge = 6,5 barg

HW7400: OTin = 40 °C, OTout = 10 °C

HX7000: OTin = -160,42 °C, OTout = 8,1 °C

Notes:

Drawings: I20784 Sh 23

Parameter: Level

Equipment: SC7001, E7001, T7500, HW7400, HX7000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	239. No/less Level	239.1. Refer to no/less and misdirect flow in this node					
More	240. Higher Level	240.1. Malfunction of LIC-719 opening LV-719 more than required	240.1.1. No impact on LNG temperature since LNG subcooler operates submerged  240.1.2. Level build up in SC7001 resulting in possible overfilling and consequent liquid nitrogen carry over to main exchanger HX7000 resulting in lower temperature affecting recycling nitrogen stream to compressor suction (lower temperature of this stream) possibly damaging the compressor due to thermal stress (economical losses)	240.1.2.1. LAHH-720 activate closure of HV-700 (leading to trip of turbine through quick closure valve HV-710 and HV-712)  240.1.2.2. TALL-707 activate trip of compressor C7400			

Session: (6) 03/04/2023

Node: (31) LNG subcooler

Intention: T7500: OPsuction = 28,12 barg, OPdischarge = 6,5 barg

HW7400: OTin = 40 °C, OTout = 10 °C

HX7000: OTin = -160,42 °C, OTout = 8,1 °C

Notes:

Drawings: I20784 Sh 23

Parameter: Composition

Equipment: SC7001, E7001, T7500, HW7400, HX7000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	241. Different Composition	241.1. No causes identified					

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (31) LNG subcooler

Intention: T7500: OPsuction = 28,12 barg, OPdischarge = 6,5 barg

HW7400: OTin = 40 °C, OTout = 10 °C

HX7000: OTin = -160,42 °C, OTout = 8,1 °C

Notes:

Drawings: I20784 Sh 23

Parameter: Services / Utilities

Equipment: SC7001, E7001, T7500, HW7400, HX7000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No	242. No Services / Utilities	242.1. No additional causes identified					

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Intention: H17000: OTin = 10 °C, OTout (min/max) = -35/25 °C

E17002A/B: OTin (min/max) = -35/25 °C, OTout = -168 °C

Notes:

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Flow

Equipment: E17002A/B, H17000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	243. No/less Flow	243.1. Unexpected closure of HV-1700 or unexpected closure of KV-1700 A/B	243.1.1. No impact on upstream nitrogen storage tank  243.1.2. Possible overheating of nitrogen back-up trim heater H17000 with possible damage of electrical bundles (economical losses)  243.1.3. Loss of nitrogen to loading bay for purging purposes (see relevant node #13) resulting in delay in loading operation (stop of loading phase)  243.1.4. Unavailability of back-up nitrogen on demand resulting in delay on compressor start-up	243.1.2.1. TAHH-1700 activate trip of H17000  243.1.3.1. PAL-1711  243.1.4.1. PAL-1711			
		243.2. Unexpected closure of TV-1705	243.2.1. No impact on upstream nitrogen storage tank  243.2.2. Possible overheating of nitrogen back-up trim heater H17000 with possible damage of electrical bundles (economical losses)  243.2.3. Loss of nitrogen to loading bay for purging purposes (see relevant node #13) resulting in delay in loading operation (stop of loading phase)  243.2.4. Unavailability of back-up nitrogen on demand resulting in...	243.2.2.1. TAHH-1700 activate trip of H17000  243.2.3.1. PAL-1711  243.2.4.1. PAL-1711			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 157 of 161

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Intention: H17000: OTin = 10 °C, OTout (min/max) = -35/25 °C

E17002A/B: OTin (min/max) = -35/25 °C, OTout = -168 °C

Notes:

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Flow

Equipment: E17002A/B, H17000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less (cont.)	243. No/less Flow (cont.)	243.2. Unexpected closure of TV-1705 (cont.)  243.3. Loss of level in nitrogen storage tank	...delay on compressor start-up  243.3.1. Possible overheating of nitrogen back-up trim heater H17000 with possible damage of electrical bundles (economical losses)  243.3.2. Loss of nitrogen to loading bay for purging purposes (see relevant node #13) resulting in delay in loading operation (stop of loading phase)  243.3.3. Unavailability of back-up nitrogen on demand resulting in delay on compressor start-up	243.2.4.1. PAL-1711 (cont.)  243.3.1.1. Each LIN tank is provided with low level alarm and level gauge  243.3.1.2. TAHH-1700 activate trip of H17000  243.3.2.1. Each LIN tank is provided with low level alarm and level gauge  243.3.2.2. PAL-1711  243.3.3.1. Each LIN tank is provided with low level alarm and level gauge  243.3.3.2. PAL-1711			
		243.4. Loss of nitrogen supply to cold flare header due to compressor shut down	243.4.1. Inadequate purging of cold flare header leading to potential for ambient air entrainment and consequent formation of flammable mixture inside cold flare header with potential explosion hazard	243.4.1.1. Back-up nitrogen injection to cold flare header through PCV-1708  243.4.1.2. Status of TV- 1702 reported to DCS			
More	244. More Flow	244.1. Higher demand rate during emergency shut down	244.1.1. Possible inadequate purging of equipment/piping	244.1.1.1. Sequence to open KV stand by valve (to operate both vaporizers in parallel mode) and to open HV-1702			

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Intention: H17000: OTin = 10 °C, OTout (min/max) = -35/25 °C

E17002A/B: OTin (min/max) = -35/25 °C, OTout = -168 °C

Notes:

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Flow

Equipment: E17002A/B, H17000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Reverse	245. Reverse Flow	245.1. No cause identified					
Misdirect	246. Misdirect Flow	246.1. KV-1700A/B stuck in open position during vaporizer switch over (every 8 hours)	246.1.1. Inadequate ice removal from vaporizer left in service, during normal operation according to limited flowrate of LIN through vaporizers, no significant consequences are expected	246.1.1.1. Discrepancy alarm on KVs			
		246.2. Unexpected opening of HV-1702	246.2.1. Nitrogen sent to cold flare header when not required leading to increased back pressure on LIN stream through primary exchanger with consequent reduced efficiency. Minor economical losses due to loss of nitrogen to cold flare	246.2.1.1. Discrepancy alarm on HVs			
		246.3. Malfunction of PCV-1708 (fully opening)	246.3.1. Nitrogen sent to cold flare header when not required leading to increased back pressure on LIN stream through primary exchanger with consequent slight reduction of efficiency. Negligible impact				The purpose of PCV-1708 is to segregate nitrogen stream on primary exchanger (vaporized LIN in cold box) from back-up nitrogen
		246.4. Unexpected opening of HV-1701	246.4.1. No consequences as long as instrument air system is working properly (OP=7 barg vs set point of PCV-1712 = 5 barg)				

## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 159 of 161

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Intention: H17000: OTin = 10 °C, OTout (min/max) = -35/25 °C

E17002A/B: OTin (min/max) = -35/25 °C, OTout = -168 °C

Notes:

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Temperature

Equipment: E17002A/B, H17000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	247. Lower Temperature	247.1. Higher LIN demand rate during maintenance (cold box defrosting)	247.1.1. Lower temperature of nitrogen downstream vaporizer E17002A/B with possible damage of piping downstream TV-1702 and TV-1705 due to embrittlement with possible injuries to personnel/economical losses	247.1.1.1. TALL-1707 activate closure of HV-1700			
		247.2. Failure of H17000 including TIC-1703 malfunction reducing heat input to H17000	247.2.1. Lower temperature of nitrogen downstream heater H17000 with possible damage of piping downstream TV-1702 and TV-1705 due to embrittlement with possible injuries to personnel/economical losses	247.2.1.1. TALL-1704 activate closure of TV-1702 and TV-1705			
More	248. Higher Temperature	248.1. Refer to no/less flow in this node					
		248.2. TIC-1703 malfunction increasing heat input to H17000	248.2.1. Possible overheating of nitrogen back-up trim heater H17000 with possible damage of electrical bundles (economical losses)	248.2.1.1. TAAH-1700 activate trip of H17000			
			248.2.2. Higher temperature of nitrogen stream at outlet of H17000 with no impact during normal operation. Possible damage to turbine seal package during shut-down/start-up (economical losses)	248.2.2.1. TAAH-1700 activate trip of H17000	66. Add a high high temperature interlock initiated by TI-1704 to trip H17000	SIAD MI	

# Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Intention: H17000: OTin = 10 °C, OTout (min/max) = -35/25 °C

E17002A/B: OTin (min/max) = -35/25 °C, OTout = -168 °C

Notes:

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Pressure

Equipment: E17002A/B, H17000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	249. Lower Pressure	249.1. Refer to no/less flow in this node					
More	250. Higher Pressure	250.1. Malfunction of PCV-1712 (fully open)	250.1.1. During normal operation pressure build up to 10 barg between PCV-1712 and HV-1701. No impact on mechanical integrity according to design criteria. Possible nitrogen losses to atmosphere due to intervention of PSV-1713 set at 10 barg  250.1.2. In case nitrogen is required as back-up for instrument air, possible pressure build up on instrument air pipe up to 10 barg. No impact on mechanical integrity according to design criteria.		67. Increase set point of PSV-1713 at 13 barg (to guarantee also protection for fire scenario according to pipe schedule)	SIAD MI	
		250.2. Malfunction of PCV-742 (fully open)	250.2.1. Possible pressure build up on seal gas line between PCV-742 and next PCV included on compressor package. No impact on mechanical integrity according to design criteria.	250.2.1.1. PAH2100 on compressor package			Refer to detailed P&ID of nitrogen compressor
		250.3. Malfunction of PCV-743 (fully open)	250.3.1. Higher consumption of back up nitrogen with no significant impact				
		250.4. External fire/Thermal expansion	250.4.1. Possible overpressurization of involved equipment/piping	250.4.1.1. All isolatable equipment/piping are protected by PSVs sized for fire or thermal expansion case depending on...			



## Worksheet

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Intention: H17000: OTin = 10 °C, OTout (min/max) = -35/25 °C

E17002A/B: OTin (min/max) = -35/25 °C, OTout = -168 °C

Notes:

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Pressure

Equipment: E17002A/B, H17000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	250. Higher Pressure (cont.)	250.4. External fire/Thermal expansion (cont.)	250.4.1. Possible overpressurization of involved equipment/piping (cont.)	...relevant service			

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Intention: H17000: OTin = 10 °C, OTout (min/max) = -35/25 °C

E17002A/B: OTin (min/max) = -35/25 °C, OTout = -168 °C

Notes:

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Level

Equipment: E17002A/B, H17000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	251. No/less Level	251.1. Not applicable					
More	252. Higher Level	252.1. Not applicable					

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Intention: H17000: OTin = 10 °C, OTout (min/max) = -35/25 °C

E17002A/B: OTin (min/max) = -35/25 °C, OTout = -168 °C

Notes:

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Composition

Equipment: E17002A/B, H17000

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	253. Different Composition	253.1. No causes identified					

## Worksheet - Index

Node 00: General issues	1
Parameter: Flow	1
Node 01A: Fiscal metering station	2
Parameter: Flow	2
Parameter: Temperature	3
Parameter: Pressure	5
Parameter: Level	6
Parameter: Composition	6
Parameter: Services / Utilities	7
Node 01B: Natural gas supply, preheating, HG removal and absorption	8
Parameter: Flow	8
Parameter: Temperature	11
Parameter: Pressure	13
Parameter: Level	14
Parameter: Composition	15
Parameter: Services / Utilities	15
Node 02: Natural gas supply to steam generator	16
Parameter: Flow	16
Parameter: Temperature	18
Parameter: Pressure	19
Parameter: Level	20
Parameter: Composition	20
Parameter: Services / Utilities	20
Node 03: Flash vessel	21
Parameter: Flow	21
Parameter: Temperature	23
Parameter: Pressure	24
Parameter: Level	25
Parameter: Composition	26
Node 04: NG stream to dryers and condensate separator	27
Parameter: Flow	27
Parameter: Temperature	28
Parameter: Pressure	29
Parameter: Level	29
Parameter: Composition	30
Node 05: MDEA Storage tank and dosing	31
Parameter: Flow	31
Parameter: Temperature	32
Parameter: Pressure	32
Parameter: Level	33
Parameter: Composition	33
Parameter: Services / Utilities	33
Node 06: MDEA stripping column	34
Parameter: Flow	34
Parameter: Temperature	39
Parameter: Pressure	42
Parameter: Level	45

## Worksheet - Index

Parameter: Composition	46
Parameter: Services / Utilities	46
Node 07: MDEA blowdown tank	47
Parameter: Flow	47
Parameter: Temperature	48
Parameter: Pressure	48
Parameter: Level	49
Parameter: Composition	50
Node 08: Antifoam dosing package	51
Parameter: Flow	51
Parameter: Temperature	51
Parameter: Pressure	52
Parameter: Level	52
Parameter: Composition	53
Node 09: Natural gas precooling, drying and liquefaction	54
Parameter: Flow	54
Parameter: Temperature	58
Parameter: Pressure	59
Parameter: Level	60
Parameter: Composition	60
Node 10: Natural gas dryers regeneration loop	61
Parameter: Flow	61
Parameter: Temperature	71
Parameter: Pressure	76
Parameter: Level	76
Parameter: Composition	81
Parameter: Services / Utilities	82
Node 11: LNG separator	83
Parameter: Flow	83
Parameter: Temperature	88
Parameter: Pressure	90
Parameter: Level	91
Parameter: Composition	93
Parameter: Services / Utilities	94
Node 12: LNG storage tank including BOG loop	95
Parameter: Flow	95
Parameter: Temperature	101
Parameter: Pressure	102
Parameter: Level	103
Parameter: Composition	104
Parameter: Services / Utilities	104
Node 13: LNG tank and truck loading system	105
Parameter: Flow	105
Parameter: Temperature	112
Parameter: Pressure	113
Parameter: Level	115
Parameter: Composition	115

## Worksheet - Index

Parameter: Services / Utilities	116
Parameter: Other	116
Node 14: Heavy HCs KO drum	117
Parameter: Flow	117
Parameter: Temperature	118
Parameter: Pressure	120
Parameter: Level	121
Parameter: Composition	121
Parameter: Other	121
Node 15: LNG drain KO drum and cold flare	122
Parameter: Flow	122
Parameter: Temperature	122
Parameter: Pressure	123
Parameter: Level	124
Parameter: Composition	124
Node 20: Cooling water circuit	125
Parameter: Composition	125
Parameter: Services / Utilities	125
Parameter: Other	125
Node 21: Steam generation	126
Parameter: Other	126
Node 22: Condensate collection	127
Parameter: Level	127
Node 23: Chilled water circuit	128
Parameter: Temperature	128
Parameter: Services / Utilities	128
Parameter: Other	128
Node 24: Demi water package	129
Parameter: Composition	129
Parameter: Other	129
Node 25: Instrument air production	130
Parameter: Pressure	130
Parameter: Composition	130
Node 30: Liquid Nitrogen supply to cold box and nitrogen recycle compressor	132
Parameter: Flow	132
Parameter: Temperature	143
Parameter: Pressure	148
Parameter: Level	150
Parameter: Composition	150
Node 31: LNG subcooler	151
Parameter: Flow	151
Parameter: Temperature	153
Parameter: Pressure	153
Parameter: Level	154
Parameter: Composition	154
Parameter: Services / Utilities	155
Node 32: Liquid nitrogen vaporizers, nitrogen heater and distribution	156

## Worksheet - Index

Parameter: Flow	156
Parameter: Temperature	159
Parameter: Pressure	160
Parameter: Level	161
Parameter: Composition	161

**LNG liquefaction plant**

HAZOP and SIL Allocation Report

PROJECT  
23123I

DATE  
April 2023

PAGE  
4 di 7

**ATTACHMENT 4**

HAZOP Action List

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
Location: Renzenhof, Germany  
Facility: LNG liquefaction plant  
PHA Method: HAZOP  
PHA Type: Initial

Process:

File Description:

Date:

Process Description:

Chemicals:

Purpose:

Scope:

Objectives:

Project Notes:





## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 2 of 28

Session: (1) 27/03/2023  
 Node: (01A) Fiscal metering station  
 Drawings: I20784 Sh 10  
 Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	6. Lower Temperature	6.2. Failure of heater W-B41 or failure of relevant temperature control system (TT-B40621)	6.2.1. Lower temperature of natural gas at the outlet of fiscal metering station (estimated -2 °C instead of 10°C) with no impact on mechanical integrity of piping and potential operational upset on downstream sections.		3. Ensure that signal from TT-B41320 and TT-B42320 are reported to DCS including high and low temperature alarm	OGE (TPG)	
More	7. Higher Temperature	7.2. Higher heat input from heater W-B41 due to failure of relevant temperature control system (TT-B40621)	7.2.1. Increase of natural gas temperature and potential overheating of downstream piping (DT=80°C) with potential mechanical damage and loss of containment (possible fire/explosion)	7.2.1.1. Internal independent high high temperature interlock provided for heater W-B41 (Minimum requirement included on data sheet for vendor)	4. Ensure provision for internal independent high high temperature interlock provided for heater W-B41 to protect heater itself and downstream piping from overheating scenario	OGE (TPG)	

Session: (1) 27/03/2023  
 Node: (01A) Fiscal metering station  
 Drawings: I20784 Sh 10  
 Parameter: Pressure

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	9. Higher Pressure	9.3. PCV-B41540 malfunction (fully open), including PT-B40622 malfunction  9.4. PCV-610 malfunction (fully open)	9.3.1. Pressure build-up downstream valve PCV-B41540 up to 65 barg and potential overpressurization (DP=52 barg) with mechanical damage, loss of containment and potential for fire/explosion  9.4.1. Higher pressure of natural gas routed to analyser (44 barg instead of 1 barg) with potential overpressurization of analysers (AI-1001, 1010, 1011, 1016) and associated items (DP= 0.5 barg) with mechanical damage and potential injuries to personnel	9.3.1.1. SSV-B41520/B41530 (mechanical/pneumactical devices to cut off natural gas supply)	5. Ensure adequate set point for SSV-B41520/B41530 intervention to prevent opening of PSVs located on downstream piping (set at 52 barg)  6. Ensure provision for pressure release devices to protect analysers AI-1001, 1010, 1011, 1016 and associated items in case of wide opening of pressure let down valve PCV-610/602	OGE (TPG)  SIAD MI	  Tubing and first valve downstream PCV-610 are rated to withstand 65 barg

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023  
 Node: (01A) Fiscal metering station  
 Drawings: I20784 Sh 10  
 Parameter: Pressure

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	9. Higher Pressure (cont.)	9.5. External fire	:		7. Investigate requirement for pressure relief devices for external fire case in compliance with criteria adopted for production plant	OGE (TPG)	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (1) 27/03/2023

Node: (01B) Natural gas supply, preheating, HG removal and absorption

Drawings: 2220698-0C-10-001 Sh 2; I20784 Sh 10; I20784 Sh 15

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	21. Lower Temperature	21.3. Low ambient temperature	21.3.1. Possible freezing of stagnant piping on rich amine side	21.3.1.1. Electrical tracing and insulation provided on rich amine piping (electrical tracing also supplied by EDG)	8. Investigate appropriate monitoring system to check functionality/effectiveness of electrical tracing systems	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023  
 Node: (04) NG stream to dryers and condensate separator  
 Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 5  
 Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	62. Lower Temperature	62.2. Low ambient temperature	62.2.1. Possible freezing of stagnant piping on condensate side	62.2.1.1. Electrical tracing and insulation provided on condensate piping (electrical tracing also supplied by EDG)	9. Provide winterization on low points where condensation may happen on naturale gas line from TW1002 to HW4001	SIAD MI	

Session: (2) 28/03/2023  
 Node: (04) NG stream to dryers and condensate separator  
 Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 5  
 Parameter: Level

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	66. Lower Level	66.1. Malfunction of LIC-419 fully opening LV-419	66.1.1. Loss of level on ST-4001 and consequent gas breakthrough (44 barg) to flash vessel S1003 (DP=10 barg) leading to potential overpressurization with mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to mechanical damage	66.1.1.1. LALL-472 activate closure of LV-413  66.1.1.2. PSV-167 on S1003 sized including gas breakthrough scenario	10. Closure of LV-413 shall be also initiated by PAHH-172	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (05) MDEA Storage tank and dosing

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Level

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	77. No/less Level	77.1. Unappropriate monitoring of level in IBC	77.1.1. Emptying of IBC during fresh amine transfer and potential damage to P3001 due to dry running, economical losses		11. Provide additional gauging system to monitor level inside amine IBC (e.g. pressure gauge on bottom outlet line to P3001 pump suction, etc.)	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 7 of 28

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	81. No/less Flow (lean amine to TW1002)	81.2. Malfunction of FIC-227 to reduce rpm of pump P2005A/B through relevant VFD	81.2.1. Reduced of lean amine supply to TW1002 and consequent inadequate CO2 removal and consequent CO2 slippage to cold box (see relevant node)	81.2.1.1. AI-1012 to provide a high CO2 concentration alarm and to close HV-700 on high high CO2 concentration through ESD	12. Add a low pressure alarm to PI-201A/B	SIAD MI	
	83. No/less Flow (Overhead circuit)	83.1. Malfunction of PIC-275 closing PV-275 on CO2 vent to thermal oxidizer	83.1.1. Pressure build up on TW2008 and S2011 (DP=2barg) leading to potential overpressurization overtime, mechanical damage and injuries to personnel	83.1.1.1. PAHH-282 activate closure of FV-204  83.1.1.2. PSV-271 sized including this scenario	13. Add closure of LV-151 among actions initiated by PAHH-282  14. Investigate appropriate routing of PSV-271 (currently routed to atm at safe location) taking into account either potential presence of amine and requirements from national regulation	SIAD MI  SIAD MI / OGE	
	84. No/less Flow (Bottom circuit)	84.1. Failure of pump P2012A/B	84.1.1. Level build up in S2011 leading to possible overfilling resulting in HW2010 flooding, loss of condensation and pressure build up on TW2008 and S2011 (DP=2barg) leading to potential overpressurization overtime, damage and injuries to personnel	84.1.1.1. Discrepancy signal from on duty P2012A/B starting stand-by pump  84.1.1.2. LAHH-279 activate closure of FV-204 (same action is initiated by PAHH-282)  84.1.1.3. PSV-271 sized including this scenario	15. Add closure of LV-151 among actions initiated by LAHH-279	SIAD MI	
Reverse	86. Reverse Flow	86.1. Failure of pump P2005A/B	86.1.1. Possible natural gas reverse flow from TW1002 (44barg) to TW2008 (DP=2barg) leading to pressure build up in stripping column, mechanical damage and potential for...	86.1.1.1. Discrepancy signal from on duty P2005A/B starting stand-by pump	16. Add dedicated interlock to shut down HV-138 in case of back flow due to both P2005A/B not running (e.g. high high pressure detected on...	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (2) 28/03/2023

Node: (06) MDEA stripping column

Drawings: 2220698-0C-10-001 Sh 2; 2220698-0C-10-001 Sh 3; I20784 Sh 15

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Reverse (cont.)	86. Reverse Flow (cont.)	86.1. Failure of pump P2005A/B (cont.)	...injuries to personnel including fire/explosion hazard	86.1.1.1. Discrepancy signal from on duty P2005A/B starting stand-by pump (cont.)	...common pump suction line)  17. Add additional check valve dissimilar type at lean amine injection line in TW1002	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 9 of 28

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	96. More Flow	96.1. Operator mistake starting simultaneous drainage of different equipment	96.1.1. Possible level increase in V3004 leading to possible overfilling and amine release from vent line with possible injuries to personnel/soil contamination	96.1.1.1. Specific maintenance procedures which foresees single drainage at once  96.1.1.2. LAH/LAHH-305 activate trip of pump P3002 (used for equipment drainage)  96.1.1.3. MDEA blowdown tank located inside curbed area with adequate impermeable material	18. Provide overflow line for V3004 discharging to ground (located below inlet nozzle of PSV header)	SIAD MI	
Reverse	97. Reverse Flow	97.1. Failure of pump P3002 during transfer to truck	97.1.1. Possible reverse flow from truck to MDEA blow down tank with negligible impact (delay in operation). Overfilling is not expected according to tank elevation.		19. Add check valve on P3002 discharge line to truck loading (downstream recirculation line)	SIAD MI	
Misdirect	98. Misdirect Flow	98.2. Inadvertent opening of valve X318 or valve passing	98.2.1. Possible contamination of fresh amine and consequent operational upset		20. Specify NC valve X307 on IBC bottom	SIAD MI	

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	100. Higher Temperature	100.1. Operator mistake draining hot amine from TW2008 bottom (120 °C)	100.1.1. Possible overheating of V3004 (DT=60°C) resulting in mechanical damage and possible leakages (injuries to personnel/economical losses)	100.1.1.1. Specific drainage procedure which foresees adequate amine cooling before transfer to V3004  100.1.1.2. TAL-214 to give permission to pump...	21. Relocate TAL to give permission to pump P3002 to start from TT-214 to TT-127  22. Review V3004 design temperature up to 100 °C	SIAD MI  SIAD MI	



## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	100. Higher Temperature (cont.)	100.1. Operator mistake draining hot amine from TW2008 bottom (120 °C) (cont.)	100.1.1. Possible overheating of V3004 (DT=60°C) resulting in mechanical damage and possible leakages (injuries to personnel/economical losses) (cont.)	...P3002 to start only if temperature is adequate for transfer to blowdown tank	22. Review V3004 design temperature up to 100 °C (cont.)		

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Pressure

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	102. Higher Pressure	102.2. Pump P3002 blocked outlet condition	102.2.1. Pressure built up on blocked in piping (including flexible hoses) up to pump shut-off pressure (approximately 4 barg). No impact on mechanical integrity of piping according to design criteria. Possible overpressurization of flexible hose resulting in amine solution leak and possible injuries to personnel/soil contamination		23. Ensure that flexible hoses used for amine transfer to truck have adequate design pressure to cope with shut-off pressure of P3002	OGE (TBF)	

Session: (3) 29/03/2023

Node: (07) MDEA blowdown tank

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 4

Parameter: Level

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	103. No/less Level	103.1. Operator does not stop P3002 on low level in V3004 (including LT-305 failure)	103.1.1. Possible damage to P3002 due to dry running with minor economical losses and delay in operation	103.1.1.1. LALL-305 activate the trip of pump (not effective in case of LT-305 failure)  103.1.1.2. Event detectable by PI-306 (operator is in place during transfer)	24. Add a level gauge on V3004	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (3) 29/03/2023  
 Node: (08) Antifoam dosing package  
 Drawings: 2220698-0C-10-001 Sh 3  
 Parameter: Pressure

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	113. Higher Pressure	113.1. Blocked outlet for P2013	113.1.1. Possible damage to pump (economical losses)/potential overpressurization of downstream piping resulting in mechanical damage and potential injuries to personnel	113.1.1.1. Specific procedure for line up of antifoam agent injection line	25. Add pressure relief device on P2013 discharge line, sized for blocked outlet scenario	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 12 of 28

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect	120. Misdirect Flow	120.3. Unexpected opening of HV-705	120.3.1. Natural gas sent to cold flare with environmental concern	120.3.1.1. Discrepancy alarm on HVs  120.3.1.2. PDAHH-708 activate closure of HV-600 and HV-602	26. Specify FO valve HV-705 since it is blow down valve for emergency purposes	SIAD MI	

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	122. Higher Temperature	122.1. Loss of chilled water to HW4002	122.1.1. Natural gas routed to downstream equipment at 25°C instead of 10°C resulting in reduction of efficiency in liquefaction process	122.1.1.1. TI-485	27. Add a high temperature alarm on TI-485	SIAD MI	

Session: (3) 29/03/2023

Node: (09) Natural gas precooling, drying and liquefaction

Drawings: 2220698-0C-10-001 Sh 5; I20784 Sh 15; I20784 Sh 20

Parameter: Pressure

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	124. Higher Pressure	124.1. PCV-700 malfunction (fully open)	124.1.1. Higher pressure of natural gas routed to analyser (44 barg instead of 1 barg) with potential overpressurization of analysers (AI-1013A, 1012) and associated items (DP= 0.5 barg) with mechanical damage and potential injuries to personnel		28. Ensure provision for pressure release devices to protect analysers AI-1013A, 1012 and associated items in case of wide opening of pressure let down valve PCV-700	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 13 of 28

Session: (3) 29/03/2023

Node: (10) Natural gas dryers regeneration loop

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	132. No/less Flow (compressor discharge)	132.3. Unexpected closure of HV-511	132.3.1. Unavailability of bleed valve on demand		29. Specify HV-511 as FO valve	SIAD MI	
Misdirect	135. Misdirect Flow	135.4. Unexpected opening of TV-530B	135.4.1. During dryer heating mode, higher temperature of natural gas to downstream section (220°C instead of 10°C) due to by-pass of HW5000, with possible overheating (DT=65°C for EW5000) resulting in mechanical damage and possible leak of natural gas with possible fire		30. Add a high high temperature interlock initiated by TI-535 to close TV-530B	SIAD MI	
		135.5. Tube rupture in HW5000	135.5.2. In case of possible natural gas entrainment in chilled water circuit no significant consequences are expected during normal operation; accumulation of natural gas can lead to potential exposure of maintenance operator to flammable mixture		31. Maintenance procedure for chilled water circuit shall include actions and safeguards to avoid personnel exposure to natural gas possibly present	OSE (TZSA)	
		135.7. Inadvertent opening of separators drain valve	135.7.1. Potential operational upset due to unexpected trip of compressor due to PALL intervention/leakage of NG and potential for personnel exposure to fire/explosion hazards		32. Specify manual valves on recycle gas compressor separators drains as LC	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 14 of 28

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	137. Higher Temperature	137.6. Malfunction of TIC-555 fully opening TV-555  137.9. Loss of cooling water to HW5503	137.6.1. Higher temperature (up to 100°C) of regeneration gas to compressor resulting in possible overheating of EW5000 process gas coils (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire  137.9.1. Higher temperature of natural gas (estimated approximately 137°C) on equipment and piping on third stage discharge downstream aftercooler (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire		33. Review design temperature of EW5000 process gas coils up to 100°C  34. Add a high high temperature interlock downstream HW5503 to activate trip of compressor C5500	SIAD MI  SIAD MI	

Session: (4) 30/03/2023

Node: (10) Natural gas dryers regeneration loop

Drawings: 2220698-0C-10-001 Sh 3; 2220698-0C-10-001 Sh 5; I20784 Sh 10; I20784 Sh 15; I20784 Sh 36; I20784 Sh 37; I20784 Sh 37A; I20784 Sh 37B; I20784 Sh 39B

Parameter: Level

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	140. No/less Level	140.4. Malfunction of LIC-501A not closing DV-501 on demand	140.4.1. Natural gas at 4.9 barg routed to S2011 (DP=2 barg) with pressure build up, potential overpressurization resulting in mechanical damage and possible leak of natural gas with possible fire	140.4.1.1. LALL-501B activate closure of HV-515	35. Investigate additional safeguard to prevent overpressurization in S2011 in case of gas breakthrough from C5500 compressor separators (e.g. PSV routed to cold flare located downstream HV-515, additional PAHH on drain line to S2011 acting on additional on/off valve etc..)	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 15 of 28

Session: (4) 30/03/2023

Node: (11) LNG separator

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	144. No/less Flow	144.5. Malfunction of LIC-715A closing LV-715 or unexpected closure of HV-717 or HV-1913A/B	144.5.4. Level build up in LNG separator S7003 resulting in possible overflowing and LNG carry over to EW9000 with consequent vaporization resulting in pressure build up in EW9000 and associated piping (DP=16 barg) leading to potential overpressurization, mechanical damage and potential for LNG leakages with possible injuries to personnel (fire/explosion hazard)	144.5.4.1. LAHH-716 activate closure of HV-700 (same actions activated by PAHH-717)  144.5.4.2. PSH-715A activate opening HV-715 to cold flare KO drum V16000  144.5.4.3. Overpressure device provided on cold box	36. PSV-914 shall be verified for LNG vaporization in EW9000	SIAD MI	
Reverse	146. Reverse Flow	146.1. Shut-down of thermal oxidizer	146.1.1. Possible CO2 stream at 0,9 barg (from S2011) back flow from V16200 to LNG separator S7003 (OP = 0,5 barg) leading to possible LNG contamination and off spec products		37. PAHH-1640 shall close HV-1646 to avoid LNG contamination by CO2 in case of thermal oxidizer shut-down possibly leading to CO2 backflow from V16200 to LNG separator S7003	SIAD MI	
Misdirect	147. Misdirect Flow	147.2. Unexpected opening of HV-715	147.2.1. Possible continuous NG routed to cold flare with environmental concern and loss of product		38. Provide alarm on HZI-715 for loss of closed position of HV-715	SIAD MI	
		147.3. Unexpected opening of HV-711	147.3.1. LNG routed to cold flare KO drum V16000 resulting in KO drum overflowing and possible liquid carry over to cold flare resulting in LNG outflow from flare tips with potential injuries to personnel	147.3.1.1. Discrepancy alarm on HVs	39. Add a high high level interlock on V16000 to activate closure of HV-700 (relevant set point to be defined to allow adequate residual volume preventing overflowing after HV-700 closure)	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (11) LNG separator

Drawings: I20784 Sh 20; I20784 Sh 22; I20784 Sh 23; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 70

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	149. Higher Temperature	149.5. Malfunction of TIC-952 fully opening TV-952 on LP steam to EW9000	149.5.2. Higher temperature of water bath in EW9000 (max 100°C) with no impact on EW9000 and coils according to selected material (stainless steel)	149.5.3.1. TAH-953	40. Review design temperature of EW9000 from 90°C to 100°C	SIAD MI	
			149.5.3. Higher temperature of water bath in EW9000 leading to steam generation and consequent possible release from EW9000 atmospheric vent and potential injuries to personnel		41. Ensure safe location requirements of EW5000 and EW9000 atmospheric vent	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	162. Higher Temperature	162.4. Loss of cooling water to HW9103	162.4.1. Higher temperature of BOG recovery gas (estimated approximately 175°C) on equipment and piping on third stage discharge downstream aftercooler (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire		42. Add a high high temperature interlock downstream HW9103 to activate trip of BOG compressor C9100	SIAD MI	

Session: (6) 03/04/2023

Node: (12) LNG storage tank including BOG loop

Drawings: I20784 Sh 10; I20784 Sh 30; I20784 Sh 31; I20784 Sh 38; I20784 Sh 38A; I20784 Sh 38B

Parameter: Pressure

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	164. Higher Pressure	164.2. External fire/Thermal expansion	164.2.1. Overpressurization of involved equipment/piping with possible mechanical damage	164.2.1.1. All isolatable equipment and piping on LNG sections are protected by pressure relief devices sized for this case	43. Provide additional pressure relief device against External fire/Thermal expansion on LNG build up line between last block valve and new HV	SIAD MI	



## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 18 of 28

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	169. No/less Flow	169.4. Unexpected closure of HV-1951A, FV-1950A, HV-1952A  169.6. Unexpected closure of HV-1957A, PV-1958A, HV-1956A (when BOG is routed back to tank) or unexpected closure of PV-1959A, HV-1958A, FV-914 (when BOG from road tanker is routed to BOG compressor)	169.4.4. Potential pressure surge resulting in mechanical damage to LNG transfer line from pump to last on/off valve resulting in potential LNG leak and possible fire/explosion hazard  169.6.1. Pressure build up in road tanker up to shut-off pressure of pump P19000 (estimated <15 barg) and potential overpressurization leading to mechanical damage, LNG leakage and possible fire/explosion hazard and injuries to personnel	169.6.1.1. PAHH-1960A to activate trip of pump P19000 and to close on/off pneumatic valve on truck inlet by means of SY-1950AA (same actions initiated also by PAHH-1961A, not effective only in case of blocked outlet on gas return line inside road tanker)	44. Surge study to be provided for LNG truck loading lines (including worst case scenario: closure of on/off valve on road tanker side)  45. Set point of PAHH-1960A and PAHH-1961A shall be defined taking into account lowest design pressure for road tankers (design pressure of road tankers to be checked by OGE, currently available value is 7 barg)	SIAD MI  OGE	
Misdirect	173. Misdirect Flow	173.5. HV-1954A / HV-1955A stuck in open position after end of purging operation	173.5.2. After the end of pressure test, in case of increased pressure on LNG loading / BOG lines, sequence will be stopped by PAHH-1960A / PAHH-1961A leading to delay in operation		46. Provide a PSV on nitrogen purging line to LNG / BOG lines (set at adequate value)	SIAD MI	

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	175. Higher Temperature	175.5. TIC-952 malfunction increasing heat input to EW9000	175.5.1. Higher temperature (up to 100°C) of BOG gas to compressor resulting in possible overheating of EW9000 process gas coils (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible ...		47. Review design temperature of EW9000 coils up to 100°C	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More (cont.)	175. Higher Temperature (cont.)	175.5. TIC-952 malfunction increasing heat input to EW9000 (cont.)	...fire		47. Review design temperature of EW9000 coils up to 100°C (cont.)		

Session: (5) 31/03/2023

Node: (13) LNG tank and truck loading system

Drawings: I20784 Sh 30; I20784 Sh 32; I20784 Sh 34; I20784 Sh 38

Parameter: Other

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Other Than	182. Other Than Other	182.1. Hose failure	182.1.1. Release of LNG on loading area with possible fire/explosion hazard	182.1.1.1. PALL-1960A activate trip of pump P19000, close HV-1952A and SY-1950AA	48. Shut down of LNG loading shall be also activated by LNG high flow gradient according to requirement of TRGS 751 4.1.6 paragraph 6 codes	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023  
 Node: (14) Heavy HCs KO drum  
 Drawings: I20784 Sh 70  
 Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	183. No/less Flow	183.4. Unexpected closure of HV-1645	183.4.1. Pressure build up in V16200 leading to increase back pressure for incoming streams (see blocked outlet scenario for node #11 and #06)  183.4.3. Pressure build up in V16200 due to vaporization of liquid and possible overpressurization resulting in possible mechanical damage leading to injuries to personnel/leakages and fire hazard		49. PAHH-1640 shall also close HV-1646 to segregate stripper condensate separator S2011 from heavy HC KO drum V16200  50. PSV-914 shall be verified for blocked outlet condition on V16200  51. PAHH-1640 shall also close HV-721 and trip H16200/H16201	SIAD MI  SIAD MI  SIAD MI	

Session: (7) 04/04/2023  
 Node: (14) Heavy HCs KO drum  
 Drawings: I20784 Sh 70  
 Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	187. Lower Temperature	187.3. Failure on demand of H16201 including TDY-1644 malfunction to switch off H16201 or to not switch on on demand	187.3.1. Lower temperature of stream routed to thermal oxidizer inlet resulting in possible condensation and droplets carry over to thermal oxidizer leading to operational upset / possible damage		52. Investigate impact of liquid carry over to thermal oxidizer in case of unavailability of superheater H16201 or in case of loss of heater H16200	SIAD MI	
More	188. Higher Temperature	188.5. Malfunction of TDY-1644 to not switch off H16201 on demand or to switch on when not required	188.5.1. Higher temperature of gas routed to thermal oxidizer and potential for damage to internals (economical losses)		53. Relocate TI-1644 downstream H16201 and add a high high temperature interlock to trip H16201	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023  
 Node: (14) Heavy HCs KO drum  
 Drawings: I20784 Sh 70  
 Parameter: Level

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	192. Higher Level	192.1. Failure on demand of H16200 including malfunction of LI-1641	192.1.1. Liquid accumulation on V16200 resulting in possible overfilling and liquid carry over to thermal oxidizer leading to operational upset/possible damage	192.1.1.1. LAHH-1640 activate trip of thermal oxidizer and close HV-1645	54. LAHH-1640 shall also close HV-1646 to prevent potential liquid backflow to S2011 and trip H16201 to prevent thermal expansion of trapped material	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023  
 Node: (15) LNG drain KO drum and cold flare  
 Drawings: I20784 Sh 39A  
 Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect	199. Misdirect Flow	199.2. Cold flare drain valve left open after maintenance or valve passing	199.2.1. Continuous leakage of nitrogen during normal operation. Potential hydrocarbon leak with fire hazard in case of relief on cold flare header		55. Provide additional positive isolation device on cold flare bottom drain line	SIAD MI	

Session: (7) 04/04/2023  
 Node: (15) LNG drain KO drum and cold flare  
 Drawings: I20784 Sh 39A  
 Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Less	200. Lower Temperature	200.2. Low ambient temperature	200.2.1. In case of injection of snuffing gas (CO2) potential condensation leading to potential mechanical damage of cold flare tip		56. Investigate if CO2 is suitable for snuffing purpose on cold flare, taking into account minimum ambient temperature and possibility of condensation	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023

Node: (20) Cooling water circuit

Drawings: I20784 Sh 50; I20784 Sh 51; I20784 Sh 65; I20784 Sh 66; I20784 Sh 67; I20784 Sh 68

Parameter: Composition

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Different	207. Different Composition	207.1. Injection of biocide agent :			57. Properties of biocide agent and potential associated hazards to be investigated	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023

Node: (22) Condensate collection

Drawings: I20784 Sh 10; I20784 Sh 16; I20784 Sh 37; I20784 Sh 38; I20784 Sh 50

Parameter: Level

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	211. Higher Level	211.1. Unavailability of condensate pump P15000	211.1.1. Level build up in condensate collection drum, leading to potential overfilling and release of hot condensate (85°C) from vent leading to possible injuries to personnel		58. Ensure condensate collection drum vent to be routed to safe location	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (8) 05/04/2023  
 Node: (24) Demi water package  
 Drawings: I20784 Sh 68  
 Parameter: Composition

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	215. High Concentration	215.1. Higher salt (conductivity) on reverse osmosis drain	215.1.1. Possible off spec stream to downstream treatment unit		59. Investigate potential impact of waste water from demi water package routed to waste water collection/treatment system	OGE (TPLT)	

Session: (8) 05/04/2023  
 Node: (24) Demi water package  
 Drawings: I20784 Sh 68  
 Parameter: Other

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Other Than	216. Other Than Other	216.1. Handling of chemicals harmful for eye and skin	216.1.1. Possible injuries to personnel in case of leakage		60. Investigate requirement for emergency showers/eye showers on demi water package due to presence of harmful chemicals	OGE (TZSA)	



## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Page: 26 of 28

Session: (6) 03/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
No/less	220. No/less Flow	220.6. Potential plugging of strainer on turbine boosters C7500/7600 suction	220.6.1. Slight reduction on turbine boosters C7500/7600 efficiency and consequent potential minor operational upset		61. Provide differential pressure measurements across filters on turbine boosters C7500/7600 suctions by using existing instrumentation	SIAD MI	Additional temporary filter is provided for commissioning phase only. This temporary filter will be removed for normal operation as per SIAD commissioning procedure
		220.8. Potential plugging of strainer on turbine T7500/7600 suctions	220.8.1. Slight reduction on turbine T7500/7600 efficiency and consequent potential minor operational upset		62. Provide differential pressure measurements across filters on turbines T7500/7600 suctions by using existing instrumentation	SIAD MI	Additional temporary filter is provided for commissioning phase only. This temporary filter will be removed for normal operation as per SIAD commissioning procedure

Session: (7) 04/04/2023

Node: (30) Liquid Nitrogen supply to cold box and nitrogen recycle compressor

Drawings: I20784 Sh 22; I20784 Sh 23; I20784 Sh 25; I20784 Sh 26; I20784 Sh 27; I20784 Sh 30; I20784 Sh 31

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	225. Higher Temperature	225.3. Malfunction of TIC-754 or TIC-764 reducing speed of fan E7500/E7600 or air coolers E7500/E7600 failure	225.3.1. Higher temperature of stream routed to downstream systems leading to possible overheating on downstream sections leading to loss of containment resulting in possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)/possible injuries due to contact with hot product	225.3.1.1. Oxygen monitoring inside building to give alarm (inside horn and outside light)	63. Relocate TAHH-752 downstream E7500 and TAHH-762 downstream E7600  64. Consider to review DT of piping downstream aircoolers E7400/7401/7500/7600 taking into account air cooler failure scenario	SIAD MI  SIAD MI	Additional temperature monitoring at warm and cold boosters outlet is provided as per scope of work of relevant manufacturer (see detailed machine P&ID)

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (6) 03/04/2023  
 Node: (31) LNG subcooler  
 Drawings: I20784 Sh 23  
 Parameter: Flow

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
Misdirect	234. Misdirect Flow	234.1. Inadvertent opening of HV-720	234.1.1. Nitrogen vaporized and sent to safe location with loss of nitrogen and economical losses		65. Provide a PLC function to not allow manual selection of HV-720 if plant is detected in operating mode	SIAD MI	

## Action Items

Company: SIAD / OGE / BIOPLUS GmbH  
 Facility: LNG liquefaction plant

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Temperature

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	248. Higher Temperature	248.2. TIC-1703 malfunction increasing heat input to H17000	248.2.2. Higher temperature of nitrogen stream at outlet of H17000 with no impact during normal operation. Possible damage to turbine seal package during shut-down/start-up (economical losses)	248.2.2.1. TAHH-1700 activate trip of H17000	66. Add a high high temperature interlock initiated by TI-1704 to trip H17000	SIAD MI	

Session: (7) 04/04/2023

Node: (32) Liquid nitrogen vaporizers, nitrogen heater and distribution

Drawings: I20784 Sh 22; I20784 Sh 25; I20784 Sh 34; I20784 Sh 37A; I20784 Sh 38A; I20784 Sh 38B; I20784 Sh 40; I20784 Sh 41; I20784 Sh 42

Parameter: Pressure

GW	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	RECOMMENDATIONS	BY	NOTES
More	250. Higher Pressure	250.1. Malfunction of PCV-1712 (fully open)	250.1.1. During normal operation pressure build up to 10 barg between PCV-1712 and HV-1701. No impact on mechanical integrity according to design criteria. Possible nitrogen losses to atmosphere due to intervention of PSV-1713 set at 10 barg		67. Increase set point of PSV-1713 at 13 barg (to guarantee also protection for fire scenario according to pipe schedule)	SIAD MI	

## Action Items - Index

Node 00: General issues	1
Parameter: Flow	1
Node 01A: Fiscal metering station	2
Parameter: Temperature	2
Parameter: Pressure	2
Node 01B: Natural gas supply, preheating, HG removal and absorption	4
Parameter: Temperature	4
Node 04: NG stream to dryers and condensate separator	5
Parameter: Temperature	5
Parameter: Level	5
Node 05: MDEA Storage tank and dosing	6
Parameter: Level	6
Node 06: MDEA stripping column	7
Parameter: Flow	7
Node 07: MDEA blowdown tank	9
Parameter: Flow	9
Parameter: Temperature	9
Parameter: Pressure	10
Parameter: Level	10
Node 08: Antifoam dosing package	11
Parameter: Pressure	11
Node 09: Natural gas precooling, drying and liquefaction	12
Parameter: Flow	12
Parameter: Temperature	12
Parameter: Pressure	12
Node 10: Natural gas dryers regeneration loop	13
Parameter: Flow	13
Parameter: Temperature	14
Parameter: Level	14
Node 11: LNG separator	15
Parameter: Flow	15
Parameter: Temperature	16
Node 12: LNG storage tank including BOG loop	17
Parameter: Temperature	17
Parameter: Pressure	17
Node 13: LNG tank and truck loading system	18
Parameter: Flow	18
Parameter: Temperature	18
Parameter: Other	19
Node 14: Heavy HCs KO drum	20
Parameter: Flow	20
Parameter: Temperature	20
Parameter: Level	21
Node 15: LNG drain KO drum and cold flare	22
Parameter: Flow	22
Parameter: Temperature	22
Node 20: Cooling water circuit	23

## Action Items - Index

Parameter: Composition	23
Node 22: Condensate collection	24
Parameter: Level	24
Node 24: Demi water package	25
Parameter: Composition	25
Parameter: Other	25
Node 30: Liquid Nitrogen supply to cold box and nitrogen recycle compressor	26
Parameter: Flow	26
Parameter: Temperature	26
Node 31: LNG subcooler	27
Parameter: Flow	27
Node 32: Liquid nitrogen vaporizers, nitrogen heater and distribution	28
Parameter: Temperature	28
Parameter: Pressure	28

**LNG liquefaction plant**

HAZOP and SIL Allocation Report

PROJECT  
23123I

DATE  
April 2023

PAGE  
5 di 7

**ATTACHMENT 5**

SIL Worksheet

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	S1001		
<b>Session/Date</b>	#1/05/04/23			<b>Parameter</b>	Flow		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Misdirect		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 20.3		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PDAHH-105</b>	#	1
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 2	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PDT-105	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-105, HV-106	activate closure of HV-105, HV-106 in case of high high DP

Scenario description	
<b>Initiating events</b>	Unexpected opening of HV-164
<b>Consequences</b>	Significant portion of natural gas sent to cold flare resulting in possible environmental concern

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S0 - No consequences	0	<b>SIL (People)</b>	-
<b>Consequences to Environment</b>	<b>E</b>	E2 - Release within the fence with significant damage	2		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	a
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1		
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b> a
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b> a

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	Discrepancy alarm on HVs and operator response
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	TW1002		
<b>Session/Date</b>	#1/05/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 25.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LALL-144</b>	#	2
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 2	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LSLL-144	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	LV-146	activate closure of LV-146

Scenario description	
<b>Initiating events</b>	Malfunction of LIC-152 fully opening LV-152 on TW1002 bottom side
<b>Consequences</b>	Loss of level on TW-1002 and consequent gas breakthrough (44 barg) to flash vessel S1003 (DP=10 barg) leading to potential overpressurization with mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to mechanical damage

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	a	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	a
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	a

<b>Notes</b>	Same function is also initiated by PSHH-172
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-167 on S1003 sized including gas breakthrough scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--



<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	MDL6000		
<b>Session/Date</b>	#1/05/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 36.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-601</b>	#	3
<b>P&amp;Id n.</b>	I20784 Sh 11	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-601	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-600	activate closure of HV-600

Scenario description	
<b>Initiating events</b>	Malfunction of pressure controller on feed gas module
<b>Consequences</b>	Higher pressure of natural gas at feed gas module outlet resulting in potential overpressurization, mechanical damage, natural gas leak and fire / explosion hazard

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	a	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	a
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 1000	1000		<b>Selected</b>	a

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	Shut-off valves provided within MDL6000 as per national regulation (RRF=10) PSV-605 sized including this scenario (RRF=100)
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	S1003		
<b>Session/Date</b>	#1/05/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 41.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-172</b>	#	<b>4</b>
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 2	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PSHH-172	
<b>Logic Solver</b>	-	
<b>Final elements</b>	LV-146	activate closure of LV-146

Scenario description	
<b>Initiating events</b>	Malfunction of PIC-171 closing PV-171 or PV spurious closure
<b>Consequences</b>	Pressure build up in S1003 leading to potential overpressurization with mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to mechanical damage

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>1</b>	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	<b>1</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	<b>1</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-167 sized including this scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	TW2008		
<b>Session/Date</b>	#1/05/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 43.1, 92.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LALL-209</b>	#	5
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 3	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LT-209	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	P-2005A/B	activate trip of pump P-2005A/B

Scenario description	
<b>Initiating events</b>	1) Malfunction of LIC-163 closing LV-163 or not opening on demand or spurious closure of LV-151 2) Malfunction of LIC202/TIC-272 leading to reduced condensation rate in HW2010/inadequate demi water make-up through TV-291
<b>Consequences</b>	Loss of level in TW2008 and potential damage to P-2005A/B due to dry-running with potential localized NG leakage due to backflow from TW1002 resulting in possible fire and injuries to personnel

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S2 - Injuries with reversible effects	2	<b>SIL (People)</b>	a
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1		
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b> a
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b> a

<b>Notes</b>	
<b>S selection</b>	S2 selected taking into account additional check valve dissimilar type as per HAZOP Recommendation N 17
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	Presence of gas detection system including on site acoustic and visual alarm warning
<b>W selection</b>	
<b>IPL</b>	Additional high high pressure interlock provided on P2005A/B suction as per HAZOP Recommendation N 16, assumed RRF=10
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	S1003		
<b>Session/Date</b>	#1/05/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 54.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LALL-164</b>	#	6
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 2	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LSLL-164	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	LV-151	activate closure of LV-151

Scenario description	
<b>Initiating events</b>	Malfunction of LIC-163 fully opening LV-163
<b>Consequences</b>	Loss of amine level on S1003 and consequent gas breakthrough (5 barg) to stripping column TW2008 (DP= 2 barg) with potential mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to mechanical damage

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-271 sized including gas breakthrough scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	ST4001		
<b>Session/Date</b>	#1/05/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 66.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LALL-472</b>	#	<b>7</b>
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 5	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LSLL-472	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	LV-413	activate closure of LV-413

Scenario description	
<b>Initiating events</b>	Malfunction of LIC-419 fully opening LV-419
<b>Consequences</b>	Loss of level on ST4001 and consequent gas breakthrough (44 barg) to flash vessel S1003 (DP=10 barg) leading to potential overpressurization with mechanical damage and loss of containment of natural gas/rich amine, potential fire/explosion and injuries to personnel due to mechanical damage

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>a</b>	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	<b>a</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	<b>a</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-167 on S1003 sized including gas breakthrough scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	S2011		
<b>Session/Date</b>	#1/xx/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 83.1, 87.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-282</b>	#	8
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 3	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-282	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	FV-204, LV-151 activate closure of FV-204 and closure of LV-151	

Scenario description	
<b>Initiating events</b>	1) Malfunction of PIC-275 closing PV-275 on CO2 vent to thermal oxidizer 2) Tube rupture in HW2009
<b>Consequences</b>	Pressure build up on TW2008 and S2011 (DP=2barg) leading to potential overpressurization overtime, mechanical damage and injuries to personnel

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S2 - Injuries with reversible effects	2	<b>SIL (People)</b>	-
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b> -
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b> -

<b>Notes</b>	See HAZOP Recommendation N 13: Add closure of LV-151 among actions initiated by PAHH-282
<b>S selection</b>	S2 selected considering low operating pressure and not hazardous materials presence
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-271 sized including this scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	S2011		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	More		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 84.1, 87.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LAHH-279</b>	#	9
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 3	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LSHH-279	
<b>Logic Solver</b>	-	
<b>Final elements</b>	FV-204, LV-151	activate closure of FV-204 and closure of LV-151

Scenario description	
<b>Initiating events</b>	1) Failure of pump P2012A/B 2) Malfunction of LIC-202 leading to unexpected opening of LV-291 on demi water supply to S2011
<b>Consequences</b>	Level build up in S2011 leading to possible overflowing resulting in HW2010 flooding, loss of condensation and pressure build up on TW2008 and S2011 (DP=2barg) leading to potential overpressurization overtime, damage and injuries to personnel

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S2 - Injuries with reversible effects	2	<b>SIL (People)</b>	a	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	a
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	a

<b>Notes</b>	Same action is initiated by PAHH-282
	See Recommendation N 15: Add closure of LV-151 among actions initiated by LAHH-279
<b>S selection</b>	S2 selected considering low operating pressure and not hazardous materials presence
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-271 sized including this scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	TW2008		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 86.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH</b>	<b>#</b>	<b>10</b>
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 3	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-138	activate closure HV-138

Scenario description	
<b>Initiating events</b>	Failure of pump P2005A/B Loss of power supply
<b>Consequences</b>	Possible natural gas reverse flow from TW1002 (44barg) to TW2008 (DP=2barg) leading to pressure build up in stripping column, mechanical damage and potential for injuries to personnel including fire/explosion hazard

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	1

<b>Notes</b>	New SIF from HAZOP Recommendation N 16: Add dedicated interlock to shut down HV-138 in case of back flow due to both P2005A/B not running (e.g. high high pressure detected on common pump suction line)
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W2 selected considering auto start of spare pump P2005A/B (Discrepancy signal from on duty P2005A/B starting stand-by pump)
<b>IPL</b>	IPL=10 taking into account HAZOP Recommendation N 17. Add additional check valve dissimilar type at lean amine injection line in TW1002
<b>Selected SIL</b>	

<b>Action</b>	1	Effectiveness of PSV-271 in case of back flow from TW1002 to TW2008 shall be verified considering presence of 2 check valves dissimilar type (reduced required discharge capacity according to reference standard API 521, chapter 4.4.9.3.3). If PSV is adequate, required SIL ca be derated by 1 level ensuring periodical testing on check valves. For this purpose it is suggested to install second dissimilar check valve on dedicated discharge line of each P2005A/B
---------------	---	--



<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	H2001		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 89.6		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH-211</b>	<b>#</b>	<b>11</b>
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 3	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-211	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	H2001	activate trip of heater H2001

Scenario description	
<b>Initiating events</b>	Blocked outlet condition for CO2 vent gas stream (PV275 closure)
<b>Consequences</b>	Possible overheating of H2001 and piping (DT = 90°C) with potential mechanical damage and loss of containment of hot product with personnel injuries

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S2 - Injuries with reversible effects	2	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	F2001/2/3		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 91.4		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-289</b>	#	<b>12</b>
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 3	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-289	
<b>Logic Solver</b>	-	
<b>Final elements</b>	P-2005A/B	
	activate trip of P-2005A/B	

Scenario description	
<b>Initiating events</b>	Malfunction of PCV-229 (fully open)
<b>Consequences</b>	Lean amine at 44 barg sent to F2001, F2002 and F2003 (DP = 8 barg) resulting in possible overpressurization, mechanical damage and injuries to personnel

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>1</b>	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	<b>1</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	<b>1</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-203 sized for this scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	V3004		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 96.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LAHH-305</b>	<b>#</b>	<b>13</b>
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 4	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LT-305	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	P3002	activate trip of pump P3002 (used for equipment drainage)

Scenario description	
<b>Initiating events</b>	Operator mistake starting simultaneous drainage of different equipment
<b>Consequences</b>	Possible level increase in V3004 leading to possible overfilling and amine release from vent line with possible injuries to personnel/soil contamination

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S1 - Minor injuries	1	<b>SIL (People)</b>	-	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	-
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	-

Notes	
<b>S selection</b>	S1 selected considering HAZOP Recommendation N 18. Provide overflow line for V3004 discharging to ground (located below inlet nozzle of PSV header)
<b>E selection</b>	Curbed and paved area, material selection is adequate to avoid soil contamination
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	

Action	

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	MDL5000		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 120.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-528</b>	#	<b>14</b>
<b>P&amp;Id n.</b>	I20784 Sh 36	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-528	
<b>Logic Solver</b>	-	
<b>Final elements</b>	PV-527	
	activate closure of PV-527 (for depressurization circuit)	

Scenario description	
<b>Initiating events</b>	Wrong position for any KV in the position between high pressure stream and low pressure stream
<b>Consequences</b>	Natural gas in operating mode (44 barg, 20 °C) routed to NG regeneration module (16 barg) resulting in possible overpressurization, mechanical damage and natural gas leak (possible fire/explosion)

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>a</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>

<b>Notes</b>	Same considerations for PAHH-531 to active closure of PV-527 (for regeneration circuit)
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-530 sized including this scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	H4006		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 128.1, 129.1, 131.1, 131.3, 137.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH-466</b>	#	<b>15</b>
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 5	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-466	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	H4006	activate trip of heater H4006

Scenario description	
<b>Initiating events</b>	1) FIC-461 malfunction closing FV-461 or closure of any KV on regeneration gas loop 2) Unexpected closure of TV-530A 3) Unexpected closure of HV-500 4) Unexpected compressor stop (any cause) 5) Failure of TI-483 leading to higher heat input in H4006
<b>Consequences</b>	Possible overheating of H4006 and piping (DT = 350°C) with potential mechanical damage and loss of containment of natural gas product with personnel injuries/fire/explosion hazard

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>1</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b> <b>1</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b> <b>1</b>

<b>Notes</b>	Same consideration applicable to TAHH-467 and TAHH-469
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W2 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage
<b>IPL</b>	Independent temperature transmitter with high temperature alarm as per following action
<b>Selected SIL</b>	

<b>Action</b>	2	Provide an additional independent temperature transmitter at H4006 outlet with high temperature alarm
---------------	---	---

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	H4006		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Differential pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 128.1, 129.1, 131.1, 131.3		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PDALL-481</b>	#	<b>16</b>
<b>P&amp;Id n.</b>	2220698-0C-10-001 Sh 5	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PDT-481	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	H4006	activate trip of heater H4006

Scenario description	
<b>Initiating events</b>	1) FIC-461 malfunction closing FV-461 or closure of any KV on regeneration gas loop 2) Unexpected closure of TV-530A 3) Unexpected closure of HV-500 4) Unexpected compressor stop (any cause)
<b>Consequences</b>	Possible overheating of H4006 and piping (DT = 350°C) with potential mechanical damage and loss of containment of natural gas product with personnel injuries/fire explosion hazard

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S0 - No consequences	0	<b>SIL (People)</b>	-	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	-
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	-

Notes	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	Since overheating protection for H4006 is ensured by TAHH-466, TAHH-467 and TAHH-469, SIL Allocation for this function has not been performed

Action	

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	C5500		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 132.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-511</b>	#	<b>17</b>
<b>P&amp;Id n.</b>	I20784 Sh 37B	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-511	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	C5500	activate trip of compressor

Scenario description	
<b>Initiating events</b>	Unexpected closure of HV-504
<b>Consequences</b>	Pressure build up on compressor discharge system (DP=49 barg) and possible overpressurization leading to mechanical damage, loss of containment, potential for fire/explosion, injuries to personnel

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>a</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b> <b>a</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 1000	1000		<b>Selected</b> <b>a</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PIC-504 to open PV-505 (RRF = 10) PSV-503 (RRF = 100)
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	EW5000 NG line		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 135.4		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH-535</b>	<b>#</b>	<b>18</b>
<b>P&amp;Id n.</b>	I20784 Sh 37	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-535	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	TV-530B	activate closure of TV-530B

Scenario description	
<b>Initiating events</b>	Unexpected opening of TV-530B
<b>Consequences</b>	During dryer heating mode, higher temperature of natural gas to downstream section (220°C instead of 10°C) due to by-pass of HW5000, with possible overheating (DT=65°C for EW5000) resulting in mechanical damage and possible leak of natural gas with possible fire

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>a</b>	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	<b>a</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	<b>a</b>

<b>Notes</b>	New SIF from HAZOP Recommendation 30. Add a high high temperature interlock initiated by TI-535 to close TV-530B	
<b>S selection</b>		
<b>E selection</b>		
<b>F selection</b>		
<b>P selection</b>		
<b>W selection</b>	W1 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage	
<b>IPL</b>	Additional independent high temperature alarm considered implemented as per following action	
<b>Selected SIL</b>		

<b>Action</b>	3	Provide an additional independent temperature transmitter on NG line upstream EW5000 including high temperature alarm
---------------	---	---



<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	HW5000 outlet		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 137.5		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH-532</b>	<b>#</b>	<b>19</b>
<b>P&amp;Id n.</b>	I20784 Sh 36	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-532	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	TV-530A	activate closure of TV-530A

Scenario description	
<b>Initiating events</b>	Loss of chilled water supply to HW5000
<b>Consequences</b>	During dryer heating mode, higher temperature of natural gas to downstream section (220°C instead of 10°C) with possible overheating (DT=65°C for EW5000) resulting in mechanical damage and possible leak of natural gas with possible fire

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>a</b>	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	<b>a</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	<b>a</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W1 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage
<b>IPL</b>	TAH535 and operator response
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	HW5503 outlet		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 137.9		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH</b>	<b>#</b>	<b>20</b>
<b>P&amp;Id n.</b>	I20784 Sh 37B	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT downstream HW5503	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	C5500	trip of compressor

Scenario description	
<b>Initiating events</b>	Loss of cooling water to HW5503
<b>Consequences</b>	Higher temperature of natural gas (estimated approximately 137°C) on equipment and piping on third stage discharge downstream aftercooler (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	1

<b>Notes</b>	New SIF from HAZOP Recommendation 34. Add a high high temperature interlock downstream HW5503 to activate trip of compressor
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W1 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage
<b>IPL</b>	
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	ST5501		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 140.4		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LALL-501B</b>	#	<b>21</b>
<b>P&amp;Id n.</b>	I20784 Sh 37A	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LT-501B	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-515	activate closure of HV-515

Scenario description	
<b>Initiating events</b>	Malfunction of LIC-501A not closing DV-501 on demand
<b>Consequences</b>	Natural gas at 4.9 barg routed to S2011 (DP=2 barg) with pressure build up, potential overpressurization resulting in mechanical damage and possible leak of natural gas with possible fire

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	2	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	2
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	2

<b>Notes</b>	See HAZOP Recommendation N 35 Investigate additional safeguard to prevent overpressurization in S2011 in case of gas breakthrough from compressor separators (e.g. PSV routed to cold flare located downstream HV-515, additional PAHH on drain line to S2011 acting on additional on/off valve etc..)
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	Proposed solution for implementation of HAZOP Recommendation N 35 is to add an additional ON/OFF valve on the condensate connection line at the inlet of separator S2011 (CD-201-1/2"-A29-I) initiated by high high pressure detected by PI-282. By implementing this solution SIL can be derated from 2 to 1

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	ST5502		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 140.5		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LALL-502B</b>	#	<b>22</b>
<b>P&amp;Id n.</b>	I20784 Sh 37A	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LT-502B	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-515	activate closure of HV-515

Scenario description	
<b>Initiating events</b>	Malfunction of LIC-502A not closing DV-502 on demand
<b>Consequences</b>	Natural gas at 15 barg routed to S2011 (DP=2 barg) with pressure build up, potential overpressurization resulting in mechanical damage and possible leak of natural gas with possible fire

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	2	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	2
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	2

<b>Notes</b>	See HAZOP Recommendation N 35 Investigate additional safeguard to prevent overpressurization in S2011 in case of gas breakthrough from compressor separators (e.g. PSV routed to cold flare located downstream HV-515, additional PAHH on drain line to S2011 acting on additional on/off valve etc..)
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	Proposed solution for implementation of HAZOP Recommendation N 35 is to add an additional ON/OFF valve on the condensate connection line at the inlet of separator S2011 (CD-201-1/2"-A29-I) initiated by high high pressure detected by PI-282. By implementing this solution SIL can be derated from 2 to 1

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	ST5503		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 140.6		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LALL-503B</b>	#	<b>23</b>
<b>P&amp;Id n.</b>	I20784 Sh 37B	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LT-503B	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-515	activate closure of HV-515

Scenario description	
<b>Initiating events</b>	Malfunction of LIC-503A not closing DV-503 on demand
<b>Consequences</b>	Natural gas at 43 barg routed to S2011 (DP=2 barg) with pressure build up, potential overpressurization resulting in mechanical damage and possible leak of natural gas with possible fire

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	2	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	2
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	2

<b>Notes</b>	See HAZOP Recommendation N 35 Investigate additional safeguard to prevent overpressurization in S2011 in case of gas breakthrough from compressor separators (e.g. PSV routed to cold flare located downstream HV-515, additional PAHH on drain line to S2011 acting on additional on/off valve etc..)
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	Proposed solution for implementation of HAZOP Recommendation N 35 is to add an additional ON/OFF valve on the condensate connection line at the inlet of separator S2011 (CD-201-1/2"-A29-I) initiated by high high pressure detected by PI-282. By implementing this solution SIL can be derated from 2 to 1

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	S7003		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 144.4, 151.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-717</b>	#	<b>24</b>
<b>P&amp;Id n.</b>	I20784 Sh 23	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-717	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-700	activate closure of HV-700

Scenario description	
<b>Initiating events</b>	1) Malfunction of PIC-715A closing PV-715 2) Malfunction of PIC-703 fully opening PV-703
<b>Consequences</b>	Pressure build up up to max 43 barg in LNG separator S7003 (DP=16 barg) leading to potential overpressurization, mechanical damage and potential for LNG leakages inside the cold box with potential cold box overpressurization, mechanical damage and injuries to personnel (fire/explosion hazard)

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-705 sized including this scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	S7003		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 144.5		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LAHH-716</b>	#	<b>25a</b>
<b>P&amp;Id n.</b>	I20784 Sh 23	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LT-716	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-700	activate closure of HV-700

Scenario description	
<b>Initiating events</b>	Malfunction of LIC-715A closing LV-715 or unexpected closure of HV-717 or HV1913A/B
<b>Consequences</b>	Level build up in LNG separator S7003 resulting in possible overfilling and LNG carry over to EW9000 with possible embrittlement of downstream piping leading to mechanical damage and loss of containment

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W2 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage
<b>IPL</b>	TALL-915 activate closure HV-721 (not rated, RRF=10)
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	S7003		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 144.5		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LAHH-716</b>	#	<b>25b</b>
<b>P&amp;Id n.</b>	I20784 Sh 23	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LT-716	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-700	activate closure of HV-700

Scenario description	
<b>Initiating events</b>	Malfunction of LIC-715A closing LV-715 or unexpected closure of HV-717 or HV1913A/B
<b>Consequences</b>	Level build up in LNG separator S7003 resulting in possible overflowing and LNG carry over to EW9000 with consequent vaporization resulting in pressure build up in EW9000 and associated piping (DP=16 barg) leading to potential overpressurization, mechanical damage and potential for LNG leakages with possible injuries to personnel (fire/explosion hazard)

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>a</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b> <b>a</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 1000	1000		<b>Selected</b> <b>1</b>

<b>Notes</b>	Same actions activated by PAHH-717
	See HAZOP Recommendation 36 - PSV-914 shall be verified for LNG vaporization in EW9000
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSH-715A activate opening HV-715 to cold flare KO drum V16000 (RRF =10); PSV-914 considered verified for LNG vaporization in EW9000 as per HAZOP recommendation N 36 (RRF =100)
<b>Selected SIL</b>	Selected SIL 1 according to worksheet SIF#25a

<b>Action</b>	
---------------	--



<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	V16000		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 147.3		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LAHH</b>	#	<b>26</b>
<b>P&amp;Id n.</b>	I20784 Sh 39A	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LT	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-700	activate closure of HV-700

Scenario description	
<b>Initiating events</b>	Unexpected opening of HV-711
<b>Consequences</b>	LNG routed to cold flare KO drum V16000 resulting in KO drum overfilling and possible liquid carry over to cold flare resulting in LNG outflow from flare tips with potential injuries to personnel

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S2 - Injuries with reversible effects	2	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	1

<b>Notes</b>	New SIF from HAZOP Recommendation N 39: Add a high high level interlock on V16000 to activate closure of HV-700 (relevant set point to be defined to allow adequate residual volume preventing overfilling after HV-700 closure)
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	Discrepancy alarm on HVs
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	TL19000 (Truck loading bay)		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 169.6, 170.1, 171.1, 175.4		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-1960A</b>	#	<b>27</b>
<b>P&amp;Id n.</b>	I20784 Sh 34	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-1960A	
<b>Logic Solver</b>	-	
<b>Final elements</b>	SY1950AA, HV-1952A	
ESD PAHH-1960A activate closure of on/off pneumatic valve on truck inlet by means of SY1950AA and closure HV-1952A		

Scenario description	
<b>Initiating events</b>	1) Unexpected closure of HV-1957A, PV-1958A, HV1956A (when BOG is routed back to tank) or Unexpected closure of PV-1959A, HV-1958A (when BOG from road tanker is routed to BOG compressor) 2) Malfunction of FIC-1950A opening more than required FV1950A at the beginning of loading operation 3) Malfunction of WQ1900A leading to higher amount of LNG loaded on road tanker 4) Inadequate cooling of LNG line (HV-1950 not opening on demand including TSL-1951 malfunction)
<b>Consequences</b>	Pressure build up in road tanker up and potential overpressurization leading to mechanical damage, LNG leakage and possible fire/explosion hazard and injuries to personnel

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>2</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F2 - Frequent to permanent exposure	2	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b> <b>2</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b> <b>2</b>

<b>Notes</b>	Same actions initiated also by PAHH-1961A, not effective only in case of blocked outlet on gas return line inside road tanker
	See HAZOP recommendation N 45: Set point of PAHH-1960A and PAHH-1961A shall be defined taking into account lowest design pressure for road tankers (design pressure of road tankers to be checked by OGE, currently available value is 7 barg)
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	F2 selected considering continuous presence of operator/driver during transfer
<b>P selection</b>	
<b>W selection</b>	W2 selected taking into account operating factor for truck loading
<b>IPL</b>	Action 4 assumed as implemented providing RRF = 10
<b>Selected SIL</b>	

<b>Action</b>	4	Provide an independent function (additional pressure transmitter) to trip P19000 and to close HV-1902A in case of high pressure (set point lower than PAHH-1960A)
---------------	---	---

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	Truck loading station		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 182.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PALL-1960A</b>	#	<b>28</b>
<b>P&amp;Id n.</b>	I20784 Sh 34	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-1960A	
<b>Logic Solver</b>	-	
<b>Final elements</b>	P19000, HV-1952A, SY-1950AA	
	activate trip of pump P19000, close HV-1952A and SY-1950AA	

Scenario description	
<b>Initiating events</b>	Hose failure
<b>Consequences</b>	Release of LNG on loading area with possible fire/explosion hazard

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F2 - Frequent to permanent exposure	2	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	1

<b>Notes</b>	Same actions initiated also by PALL-1961A	
<b>S selection</b>		
<b>E selection</b>		
<b>F selection</b>	F2 selected considering continuous presence of operator/driver during transfer	
<b>P selection</b>	P1 selected considering event detectable	
<b>W selection</b>		
<b>IPL</b>		
<b>Selected SIL</b>		

<b>Action</b>	5	Intervention of PALL-1961A shall also close HV-1957A and HV-1958A
---------------	---	---

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	EW9000 BOG line		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 171.1, 173.4, 174.3		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TALL-914</b>	#	<b>29</b>
<b>P&amp;Id n.</b>	I20784 Sh 38	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-914	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-1958A/B	activate closure HV-1958A/B

Scenario description	
<b>Initiating events</b>	1) Malfunction of WQ-1900A leading to higher amount of LNG loaded on road tanker 2) HV-1953A stuck in open position after hose drain 3) Loss of LP steam in EW9000 including malfunction of TIC-952 closing TV-952
<b>Consequences</b>	1) Possible overfilling of road tanker with consequent liquid carry over to BOG line back to heater EW9000 with possible embrittlement of downstream piping leading to mechanical damage and loss of containment 2) During next loading operation, LNG partially routed to BOG line with consequent liquid carry over to heater EW9000 with possible embrittlement of downstream piping leading to mechanical damage and loss of containment 3) BOG routed to BOG compressor inlet line at -168°C instead of 20°C with possible embrittlement of piping resulting in mechanical and injuries to personnel (fire/explosion hazard)

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>1</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b> <b>1</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b> <b>1</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W2 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage
<b>IPL</b>	Independent temperature transmitter with low temperature alarm as per following action
<b>Selected SIL</b>	

<b>Action</b>	6	Provide an additional independent temperature transmitter at EW9000 outlet (road tanker BOG line) with low temperature alarm
---------------	---	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	VT19000		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Level		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 179.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>LAHH-1900A</b>	<b>#</b>	<b>30</b>
<b>P&amp;Id n.</b>	I20784 Sh 30	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	LIT-1900A	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-1913A	activate closure of HV-1913A (after closure of HV-1913A all LNG production will be diverted to VT19001)

Scenario description	
<b>Initiating events</b>	Inadequate monitoring of tank level including LI-1900A or LI-1901A malfunction
<b>Consequences</b>	Level build up in VT19000 and consequent overflowing leading to blocked outlet condition for LNG separator bottom line resulting in level build up in S7003 (see no/less flow in node #11). Possible liquid carry over to EW9000.

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S0 - No consequences	0	<b>SIL (People)</b>	-	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	-
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	-

<b>Notes</b>	Same consideration for LAHH1901A
	Scenario already protected by LAHH-716 (rated SIL1) on S7003
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	C5500		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 135.8		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-510</b>	#	<b>31</b>
<b>P&amp;Id n.</b>	I20784 Sh 37A	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-510	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	C5500	activate trip of compressor C5500

Scenario description	
<b>Initiating events</b>	Malfunction of PIC-500/PIC-504 opening PV-505 when not required
<b>Consequences</b>	Pressure build up on C5500 suction (DP=10 barg) resulting in possible overpressurization leading to mechanical damage, loss of containment, potential for fire/explosion, injuries to personnel

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>a</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-501, PSV-530
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	C9100		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 157.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-911</b>	#	<b>32</b>
<b>P&amp;Id n.</b>	I20784 Sh 38B	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-911	
<b>Logic Solver</b>	-	
<b>Final elements</b>	C9100	activate trip of compressor

Scenario description	
<b>Initiating events</b>	Unexpected closure of HV-904
<b>Consequences</b>	Pressure build up on compressor discharge system (DP=49 barg) and possible overpressurization leading to mechanical damage, loss of containment, potential for fire/explosion, injuries to personnel

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>1</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b> <b>1</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b> <b>1</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-903
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	EW9000 NG line (from tank)		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 160.1, 161.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TALL-913</b>	#	<b>33</b>
<b>P&amp;Id n.</b>	I20784 Sh 38	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-913	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-939	activate closure of HV-939

Scenario description	
<b>Initiating events</b>	1) PV-1910A stuck in open position during compressor in operation (PV-1910B opened) 2) Loss of duty in EW9000 (loss of LP steam supply including malfunction of TIC-952)
<b>Consequences</b>	Lower temperature on downstream EW9000 coil and consequent lower temperature on downstream piping with possible embrittlement of piping leading to mechanical damage and loss of containment with possible fire/explosion hazard

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>1</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b> <b>1</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b> <b>1</b>

<b>Notes</b>	Same function is also initiated by TALL-953
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W2 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage
<b>IPL</b>	Independent temperature transmitter with low temperature alarm as per following action
<b>Selected SIL</b>	

<b>Action</b>	7	Provide an additional independent temperature transmitter at EW9000 outlet (storage tank BOG line) with low temperature alarm
---------------	---	---



<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	EW9000 NG line		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 148.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TALL-915</b>	<b>#</b>	<b>34</b>
<b>P&amp;Id n.</b>	I20784 Sh 38	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-915	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-721	activate closure HV-721

Scenario description	
<b>Initiating events</b>	Loss of LP steam in EW9000 including malfunction of TIC-952 closing TV-952
<b>Consequences</b>	Natural gas routed to thermal oxidizer inlet line at -168°C instead of 20°C with possible embrittlement of piping resulting in mechanical and injuries to personnel (fire/explosion hazard)

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W2 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage
<b>IPL</b>	Independent temperature transmitter with low temperature alarm as per following action
<b>Selected SIL</b>	

<b>Action</b>	8	Provide an additional independent temperature transmitter at EW9000 outlet (NG line) with low temperature alarm
---------------	---	---

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	HW9103 downstream line		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 162.4		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH</b>	<b>#</b>	<b>35</b>
<b>P&amp;Id n.</b>		rev.					

Safety Instrumented Function Description		
<b>Initiator</b>	TT	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	C9100	trip of BOG compressor C9100

Scenario description	
<b>Initiating events</b>	Loss of cooling water to HW9103
<b>Consequences</b>	Higher temperature of BOG recovery gas (estimated approximately 175°C) on equipment and piping on third stage discharge downstream aftercooler (DT=65°C) resulting in mechanical damage and possible leak of natural gas with possible fire

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	1

<b>Notes</b>	New SIF from HAZOP Recommendation N 42 Add a high high temperature interlock downstream HW9103 to activate trip of BOG compressor C9100
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	W1 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage
<b>IPL</b>	
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	C7500/7600		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 220.4, 223.1, 223.6		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PALL-750</b>	#	<b>36</b>
<b>P&amp;Id n.</b>	I20784 Sh 26	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-750	
<b>Logic Solver</b>	-	
<b>Final elements</b>	HV-710/712, UV-760	
	ESD	
	activate shut-down of turbines T7500/T7600 and relevant boosters (through closure of HV-710/712 and opening UV-760)	

Scenario description	
<b>Initiating events</b>	1) Compressor failure/stop (any cause) 2) Malfunction of PIC-740B opening PV-740B when not required 3) Unexpected opening of UV-763
<b>Consequences</b>	Lower suction pressure/flowrate for C7500/C7600 turbines boosters resulting in potential surge condition leading to turbines boosters damage and consequent extensive damage. Possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>1</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1		
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b> <b>1</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b> <b>1</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	P1 selected considering presence of Oxygen monitoring inside building to give alarm (inside horn and outside light)
<b>W selection</b>	
<b>IPL</b>	Anti surge control system opening UV-760
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	SC7001		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 231.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-722</b>	#	<b>37</b>
<b>P&amp;Id n.</b>	I20784 Sh 23	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-722	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-700	activate closure of HV-700

Scenario description	
<b>Initiating events</b>	Malfunction of PIC-719 closing PV-719
<b>Consequences</b>	Pressure build up in SC7001 leading to potential overpressurization (DP=8 barg) with mechanical damage and consequent leakage of liquefied nitrogen inside cold box leading to vaporization and potential overpressurization of cold box with mechanical damage (injuries to personnel)

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-718 sized including this scenario
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	C7400		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 225.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH-749</b>	<b>#</b>	<b>38</b>
<b>P&amp;Id n.</b>	I20784 Sh 25	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-749	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	C7400	activate trip of compressor

Scenario description	
<b>Initiating events</b>	Malfunction of TIC-747 or TIC-748 reducing speed of fan E7400/E7401 or air coolers E7400/E7401 failure
<b>Consequences</b>	Higher temperature of nitrogen sent to downstream sections (DT = 65°C) with possible mechanical damage of piping overtime leading to loss of containment resulting in possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)/possible injuries due to contact with hot product

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	P1 selected considering presence of Oxygen monitoring inside building to give alarm (inside horn and outside light)
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	LNG to HX7000		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 225.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH-708</b>	#	<b>39</b>
<b>P&amp;Id n.</b>	I20784 Sh 22	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-708	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	C7400	activate trip of compressor

Scenario description	
<b>Initiating events</b>	Malfunction of TIC-747 or TIC-748 reducing speed of fan E7400/E7401 or air coolers E7400/E7401 failure
<b>Consequences</b>	Higher temperature of stream routed to primary heat exchanger (DT=65°C) resulting in possible mechanical damage due to overheating leading to possible leakages of pressurized nitrogen inside cold box with potential overpressurization and mechanical damage (injuries to personnel)

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	<b>1</b>	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	<b>1</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	<b>1</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	Overpressure hatch provided on cold box
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	HPN to HX7000		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 225.3		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH-709</b>	<b>#</b>	<b>40</b>
<b>P&amp;Id n.</b>	I20784 Sh 22	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-709	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-710/712	activate closure of HV-710/712

Scenario description	
<b>Initiating events</b>	Malfunction of TIC-754 or TIC-764 reducing speed of fan E7500/E7600 or air coolers E7500/E7600 failure
<b>Consequences</b>	Higher temperature of stream routed to primary heat exchanger (DT=65°C) resulting in possible mechanical damage due to overheating leading to possible leakages of pressurized nitrogen inside cold box with potential overpressurization and mechanical damage (injuries to personnel)

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	Overpressure hatch provided on cold box
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	H17000 upstream line		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 247.1		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TALL-1707</b>	<b>#</b>	<b>41</b>
<b>P&amp;Id n.</b>	I20784 Sh 42	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-1707	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-1700	activate closure of HV-1700

Scenario description	
<b>Initiating events</b>	Higher LIN demand rate during maintenance (cold box defrosting)
<b>Consequences</b>	Lower temperature of nitrogen downstream vaporizer E17002A/B with possible damage of piping downstream TV-1702 and TV-1705 due to embrittlement with possible injuries to personnel

SIL Allocation					
<b>Consequences to People</b>	<b>S</b>	S2 - Injuries with reversible effects	2	<b>SIL (People)</b>	<b>a</b>
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0		
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2		
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b> <b>a</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b> <b>a</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	During defrosting operation, continuous personnel presence is not expected
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--



<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	H17000 downstream line		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	Low		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 247.2		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TALL-1704</b>	#	<b>42</b>
<b>P&amp;Id n.</b>	I20784 Sh 22	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-1704	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	TV-1702 / TV-1705	activate closure of TV-1702 and TV-1705

Scenario description	
<b>Initiating events</b>	Failure of H17000 including TIC-1703 malfunction reducing heat input to H17000
<b>Consequences</b>	Lower temperature of nitrogen downstream heater H17000 with possible damage of piping downstream TV-1702 and TV-1705 due to embrittlement with possible injuries to personnel

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S2 - Injuries with reversible effects	2	<b>SIL (People)</b>	<b>a</b>	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	<b>-</b>	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	<b>a</b>
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	<b>a</b>

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	Event expected only in emergency scenario (need for nitrogen back up) during winter time
<b>IPL</b>	
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	V16200		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Pressure		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 183.4		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>PAHH-1640</b>	#	<b>43</b>
<b>P&amp;Id n.</b>	I20784 Sh 70	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	PT-1640	
<b>Logic Solver</b>	-	
<b>Final elements</b>	HV-721, H16200/H16201, HV-1646	
	activate closure of HV-721 and HV-1646 and trip H16200/H16201	

Scenario description	
<b>Initiating events</b>	Unexpected closure of HV-1645
<b>Consequences</b>	Pressure build up in V16200 due to vaporization of liquid and possible overpressurization resulting in possible mechanical damage leading to injuries to personnel/leakages and fire hazard

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 100	100		<b>Selected</b>	1

<b>Notes</b>	See HAZOP Recommendation N 51 PAHH-1640 shall also close HV-721 and trip H16200/H16201
	See HAZOP Recommendation N 50 PSV-914 shall be verified for blocked outlet condition on V16200
	See HAZOP Recommendation N 49 PAHH-1640 shall also close HV-1646 to segregate stripper condensate separator S2011 from heavy HC KO drum V16200
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	PSV-914 (considering implemented HAZOP recommendation N 50)
<b>Selected SIL</b>	

<b>Action</b>	9	Ensure adequate set point for PAHH-1640 to prevent overpressurization on upstream S2011 (DP=2 barg)
---------------	---	---

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	C7400		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>			
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>			
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	causes 220.5, 220.7, 220.9, 223.5		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>USPM</b>	#	<b>44</b>
<b>P&amp;Id n.</b>		rev.					

Safety Instrumented Function Description		
<b>Initiator</b>	PT/TT	antisurge protection
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	C7400	trip of compressor

Scenario description	
<b>Initiating events</b>	1) Malfunction of compressor capacity control system leading to closure of compressor IGV 2) Unexpected closure of UV-761 3) Unexpected closure of HV-712 or HV-710 (quick closing valves)
<b>Consequences</b>	Potential surge condition leading to compressor damage and consequent extensive damage (major economical losses including operation disruption)/possible impact on personnel in case of nitrogen leakage into the building (asphyxiation hazard)

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P1 - Hazardous situation can be avoided	1			
<b>Demand rate</b>	<b>W</b>	W3 - Demand rate between 1 D and 10 D per year	3	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL = 10	10		<b>Selected</b>	1

<b>Notes</b>	
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	P1 selected considering presence of Oxygen monitoring inside building to give alarm (inside horn and outside light)
<b>W selection</b>	
<b>IPL</b>	Anti surge control system to open compressor by-pass valve (PCV)
<b>Selected SIL</b>	

<b>Action</b>	
---------------	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	WB41/WB42		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 7.2		
<b>C&amp;Ed n.</b>	520REZH433004000SRI00101	rev.	0E	<b>SIF</b>	<b>TAHH</b>	<b>#</b>	<b>45</b>
<b>P&amp;Id n.</b>		rev.					

Safety Instrumented Function Description		
<b>Initiator</b>	TT	independent temperature transmitter at WB41/WB42 outlet
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	WB41/WB42	to trip heater WB41/WB42

Scenario description	
<b>Initiating events</b>	Higher heat input from heater W-B41 due to failure of relevant temperature control system (TT-B40621)
<b>Consequences</b>	Increase of natural gas temperature and potential overheating of downstream piping (DT=80°C) with potential mechanical damage and loss of containment (possible fire/explosion)

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S3 - Severe injuries/single fatality	3	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W1 - Demand rate less than 0,1 D per year	1	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	1

<b>Notes</b>	Function required by HAZOP recommendation N 4 - Ensure provision for internal independent high high temperature interlock provided for heater W-B41 to protect heater itself and downstream piping from overheating scenario	
<b>S selection</b>		
<b>E selection</b>		
<b>F selection</b>		
<b>P selection</b>		
<b>W selection</b>	W1 selected since scenario with Severity S3 is expected only in case of ignition of gas leakage	
<b>IPL</b>		
<b>Selected SIL</b>		

<b>Action</b>	10	Investigate availability of other IPL to prevent piping overheating downstream WB41/WB42
---------------	----	--

<b>Study</b>	SIL Allocation			<b>Project</b>	LNG liquefaction plant		
<b>Client</b>	SIAD / OGE / BIOPLUS GmbH			<b>Item</b>	C7400		
<b>Session/Date</b>	#2/17/04/23			<b>Parameter</b>	Temperature		
<b>SIL Facilitator/Scribe</b>	Fabrizio Bucci/Debora D'Ostilio			<b>Deviation</b>	High		
<b>Team</b>	Refer to SIL Attendance List			<b>HAZOP Reference</b>	cause 225.3		
<b>C&amp;Ed n.</b>	140REZH690010001PFS00101	rev.	0C	<b>SIF</b>	<b>TAHH-752</b>	<b>#</b>	<b>46</b>
<b>P&amp;Id n.</b>	I20784 Sh 26	rev.	0C				

Safety Instrumented Function Description		
<b>Initiator</b>	TT-752	
<b>Logic Solver</b>	-	ESD
<b>Final elements</b>	HV-710/712	activate closure of HV-710/712

Scenario description	
<b>Initiating events</b>	Malfunction of TIC-754 reducing speed of fan E7500 or air coolers E7500 failure
<b>Consequences</b>	Higher temperature of stream routed to downstream systems leading to possible overheating on downstream sections leading to loss of containment resulting in possible injuries due to contact with hot product (piping outside building)

SIL Allocation						
<b>Consequences to People</b>	<b>S</b>	S2 - Injuries with reversible effects	2	<b>SIL (People)</b>	1	
<b>Consequences to Environment</b>	<b>E</b>	E0 - No impact	0			
<b>Occupancy</b>	<b>F</b>	F1 - Rare to more frequent exposure. Occupancy less than 0,1	1	<b>SIL (Environmental)</b>	-	
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	P2 - Hazardous situation cannot be avoided	2			
<b>Demand rate</b>	<b>W</b>	W2 - Demand rate between 0,1 D and 1 D per year	2	<b>SIL</b>	<b>Calculated (max)</b>	1
<b>Independent Protection Layer</b>	<b>IPL</b>	IPL Not available	0		<b>Selected</b>	1

<b>Notes</b>	This allocation is also representative for TAHH-762
	See HAZOP Recommendation N 63 (Relocate TAHH-752 downstream E7500 and TAHH-762 downstream E7600)
<b>S selection</b>	
<b>E selection</b>	
<b>F selection</b>	
<b>P selection</b>	
<b>W selection</b>	
<b>IPL</b>	
<b>Selected SIL</b>	By implementing HAZOP Recommendation N 64 (Consider to review DT of piping downstream aircoolers E7400/7401/7500/7600 taking into account air cooler failure scenario) this SIF will not be rated

<b>Action</b>	
---------------	--

**LNG liquefaction plant**

HAZOP and SIL Allocation Report

PROJECT  
23123I


DATE  
April 2023

PAGE  
6 di 7

**ATTACHMENT 6**

SIFs List

## SIF List

SIF List											
Study		SIL Allocation						  			
Client		SIAD / BIOPLUS GmbH / OGE									
Project		LNG liquefaction plant, Renzenhof (Germany)									
n.	SIF	Item	Deviation	Scenario	Category	Initiator TAG	Logic solver TAG	Final Elements	Actions	SIL rated	Notes
1	<b>PDAH-105</b>	S1001	Flow Misdirect	Natural gas sent to cold flare	E	PDT-105	-	HV-105, HV-106	activate closure of HV-105, HV-106 in case of high high DP	a	
2	<b>LALL-144</b>	TW1002	Level Low	Gas breakthrough to flash vessel and overpressurization of S1003	S	LSLL-144	-	LV-146	activate closure of LV-146	a	
3	<b>PAHH-601</b>	MDL6000	Pressure High	Overpressurization of feed gas module	S	PT-601	-	HV-600	activate closure of HV-600	a	
4	<b>PAHH-172</b>	S1003	Pressure High	Overpressurization of flash vessel S1003	S	PSHH-172	-	LV-146	activate closure of LV-146	1	
5	<b>LALL-209</b>	TW2008	Level Low	Damage of P-2005A/B and NG leakage due to backflow from TW1002	S	LT-209	-	P-2005A/B	activate trip of pump P-2005A/B	a	
6	<b>LALL-164</b>	S1003	Level Low	breakthrough to stripping column TW2008 and overpressurization	S	LSLL-164	-	LV-151	activate closure of LV-151	1	
7	<b>LALL-472</b>	ST4001	Level Low	breakthrough to flash vessel S1003 and overpressurization	S	LSLL-472	-	LV-413	activate closure of LV-413	a	
8	<b>PAHH-282</b>	S2011	Pressure High	ovepressurization of TW2008 and S2011	S	PT-282	-	FV-204, LV-151	activate closure of FV-204 and closure of LV-151	-	From HAZOP Recommendation N 14: Add closure of LV-151 among actions initiated by PAHH-282
9	<b>LAHH-279</b>	S2011	Level More	ovepressurization of TW2008 and S2011	S	LSHH-279	-	FV-204, LV-151	activate closure of FV-204 and closure of LV-151	a	From HAZOP Recommendation 16: Add closure of LV-151 among actions initiated by LAHH-279
10	<b>PAHH</b>	TW2008	Pressure High	ovepressurization of TW2008	S	PT	-	HV-138	activate closure HV-138	1	New SIF from HAZOP Recommendation N 16: Add dedicated interlock to shut down HV-138 in case of back flow due to both P2005A/B not running (e.g. high high pressure detected on common pump suction line)
11	<b>TAHH-211</b>	H2001	Temperature High	ovepressurization of H2001	S	TT-211	-	H2001	activate trip of heater H2001	1	
12	<b>PAHH-289</b>	F2001/2/3	Pressure High	overpressurization of F2001, F2002 and F2003	S	PT-289	-	P-2005A/B	activate trip of P-2005A/B	1	
13	<b>LAHH-305</b>	V3004	Level High	overflowing of V3004	S, E	LT-305	-	P3002	activate trip of pump P3002 (used for equipment drainage)	-	




## SIF List

n.	SIF	Item	Deviation	Scenario	Category	Initiator TAG	Logic solver TAG	Final Elements	Actions	SIL rated	Notes
14	PAHH-528	MDL5000	Pressure High	NG regeneration module overpressurization	S	PT-528	-	PV-527	activate closure of PV-527 (for depressurization circuit)	a	
15	TAHH-466	H4006	Temperature High	overheating of H4006	S	TT-466	-	H4006	activate trip of heater H4006	1	Same allocation applies to TAHH-469 and TAHH-467
16	PDALL-481	H4006	Differential pressure Low	overheating of H4006	S	PDT-481	-	H4006	activate trip of heater H4006	-	Since overheating protection for H4006 is ensured by TAHH-466, TAHH-467 and TAHH-469, SIL Allocation for this function has not been performed
17	PAHH-511	C5500	Pressure High	compressor discharge overpressurization	S	PT-511	-	C5500	activate trip of compressor	a	
18	TAHH-535	EW5000 NG line	Temperature High	overheating of natural gas to EW5000 downstream	S	TT-535	-	TV-530B	activate closure of TV-530B	a	
19	TAHH-532	HW5000 outlet	Temperature High	overheating of natural gas to EW5000 downstream	S	TT-532	-	TV-530A	activate closure of TV-530A	a	
20	TAHH	HW5503 outlet	Temperature High	overheating of natural gas on equipment and piping on third stage discharge	S	TT downstream HW5503	-	C5500	trip of compressor	1	New SIF from HAZOP Recommendation 34. Add a high high temperature interlock downstream HW5503 to activate trip of compressor
21	LALL-501B	ST5501	Level Low	overpressurization of S2011	S	LT-501B	-	HV-515	activate closure of HV-515	2	Proposed solution for implementation of HAZOP Recommendation N 35 is to add an additional ON/OFF valve on the condensate connection line at the inlet of separator S2011 (CD-201-1/2"-A29-I) initiated by high high pressure detected by PI-282. By implementing this solution SIL can be derated from 2 to 1





## SIF List

SIF List											
Study		SIL Allocation						  			
Client		SIAD / BIOPLUS GmbH / OGE									
Project		LNG liquefaction plant, Renzenhof (Germany)									
n.	SIF	Item	Deviation	Scenario	Category	Initiator TAG	Logic solver TAG	Final Elements	Actions	SIL rated	Notes
22	<b>LALL-502B</b>	ST5502	Level Low	overpressurization of S2011	S	LT-502B	-	HV-515	activate closure of HV-515	2	Proposed solution for implementation of HAZOP Recommendation N 35 is to add an additional ON/OFF valve on the condensate connection line at the inlet of separator S2011 (CD-201-1/2"-A29-I) initiated by high high pressure detected by PI-282. By implementing this solution SIL can be derated from 2 to 1
23	<b>LALL-503B</b>	ST5503	Level Low	overpressurization of S2011	S	LT-503B	-	HV-515	activate closure of HV-515	2	Proposed solution for implementation of HAZOP Recommendation N 35 is to add an additional ON/OFF valve on the condensate connection line at the inlet of separator S2011 (CD-201-1/2"-A29-I) initiated by high high pressure detected by PI-282. By implementing this solution SIL can be derated from 2 to 1
24	<b>PAHH-717</b>	S7003	Pressure High	overpressure of S7003	S	PT-717	-	HV-700	activate closure of HV-700	1	
25a	<b>LAHH-716</b>	S7003	Level High	overfilling of S7003 (embrittlement of downstream piping)	S	LT-716	-	HV-700	activate closure of HV-700	1	
25b				overfilling of S7003 (pressure build up in S7003 / EW9000)	S						
26	<b>LAHH on V16000</b>	V16000	Level High	overfilling of V16000	S	LT	-	HV-700	activate closure of HV-700	1	New SIF from HAZOP Recommendation N 39: Add a high high level interlock on V16000 to activate closure of HV-700 (relevant set point to be defined to allow adequate residual volume preventing overfilling after HV-700 closure)
27	<b>PAHH-1960A</b>	TL19000 (Truck loading bay)	Pressure High	overpressure in road tanker	S	PT-1960A	-	SY1950AA, HV-1952A	PAHH-1960A activate closure of on/off pneumatic valve on truck inlet by means of SY1950AA and closure HV-1952A	2	Same actions initiated also by PAHH-1961A, not effective only in case of blocked outlet on gas return line inside road tanker
28	<b>PALL-1960A</b>	Truck loading station	Pressure	fire/explosion hazard in loading area	S	PT-1960A	-	P19000, HV-1952A, SY-1950AA	activate trip of pump P19000, close HV-1952A and SY-1950AA	1	

## SIF List

n.	SIF	Item	Deviation	Scenario	Category	Initiator TAG	Logic solver TAG	Final Elements	Actions	SIL rated	Notes
29	TALL-914	EW9000 BOG line	Temperature Low	overheating of BOG from EW9000	S	TT-914	-	HV-1958A/B	activate closure HV-1958A/B	1	
30	LAHH-1900A	VT19000	Level High	overflowing of VT19000	S	LIT-1900A	-	HV-1913A	activate closure of HV-1913A (after closure of HV-1913A all LNG production will be diverted to VT19001)	-	Same allocation applies to LAHH1901A
31	PAHH-510	C5500	Pressure High	Pressure build up on C5500 suction	S	PT-510	-	C5500	activate trip of compressor C5500	a	
32	PAHH-911	C9100	Pressure High	Pressure build up on compressor discharge	S	PT-911	-	C9100	activate trip of compressor	1	
33	TALL-913	EW9000 NG line (from tank)	Temperature Low	overheating of NG from EW9000	S	TT-913	-	HV-939	activate closure of HV-939	1	Same allocation applies to TALL-953
34	TALL-915	EW9000 NG line	Temperature Low	low low temperature on thermal oxidizer	S	TT-915	-	HV-721	activate closure HV-721	1	
35	TAHH	HW9103 downstream line	Temperature High	overheating of HW9103 downstream line	S	TT	-	C9100	trip of BOG compressor C9100	1	New SIF from HAZOP Recommendation N 42 Add a high high temperature interlock downstream HW9103 to activate trip of BOG compressor C9100
36	PALL-750	C7500/7600	Pressure Low	turbines boosters damage	S	PT-750	-	HV-710/712, UV-760	activate shut-down of turbines T7500/T7600 and relevant boosters (through closure of HV-710/712 and opening UV-760)	1	
37	PAHH-722	SC7001	Pressure High	overpressurization of SC7001	S	PT-722	-	HV-700	activate closure of HV-700	1	
38	TAHH-749	C7400	Temperature High	overheating of piping downstream E7400/E7401	S	TT-749	-	C7400	activate trip of compressor	1	
39	TAHH-708	LNG to HX7000	Temperature High	overheating of stream routed to primary heat exchanger	S	TT-708	-	C7400	activate trip of compressor	1	
40	TAHH-709	HPN to HX7000	Temperature High	overheating of stream routed to primary heat exchanger	S	TT-709	-	HV-710/712	activate closure of HV-710/712	1	
41	TALL-1707	H17000 upstream line	Temperature Low	lower temperature of nitrogen downstream vaporizer E17002A/B	S	TT-1707	-	HV-1700	activate closure of HV-1700	a	
42	TALL-1704	H17000 downstream line	Temperature Low	lower temperature of nitrogen downstream heater H17000	S	TT-1704	-	TV-1702 / TV-1705	activate closure of TV-1702 and TV-1705	a	
43	PAHH-1640	V16200	Pressure High	V16200 mechanical damage	S	PT-1640	-	HV-721, H16200/H16201, HV-1646	activate closure of HV-721 and HV-1646 and trip H16200/H16201	1	New actions initiated by SIF PAHH-1640 from HAZOP Recommendation N 51
44	USPM	C7400	--	compressor C7400 surge condition	S	PT/TT	-	C7400	trip of compressor	1	



SIF List

n.	SIF	Item	Deviation	Scenario	Category	Initiator TAG	Logic solver TAG	Final Elements	Actions	SIL rated	Notes
45	TAHH	WB41/WB42	Temperature High	overheating of WB41/42 downstream piping	S	TT	-	WB41/WB42	to trip heater WB41/WB42	1	Function required by HAZOP recommendation N 4 - Ensure provision for internal independent high high temperature interlock provided for heater W-B41 to protect heater itself and downstream piping from overheating scenario
46	TAHH-752	TAHH-752	Temperature High	overheating on C7400 downstream sections	S	TT-752	-	HV-710/712	activate closure of HV-710/712	1	Same allocation applies to TAHH-762



**LNG liquefaction plant**

HAZOP and SIL Allocation Report

PROJECT  
23123I

DATE  
April 2023

PAGE  
7 di 7

**ATTACHMENT 7**

Reference HAZOP/SIL Procedures

# ICARO

GUIDE LINES

## HAZard and OPerability study (HAZOP)



PROPOSED	CHECKED	APPROVED	REV.	DATE	DESCRIPTION
F.Bucci	N.Manning	B.Frattini	04	31/01/2018	Updated
F.Bucci	N.Manning	M.G.Ruffi	03	06/07/2017	Updated
F.Bucci	N.Manning	M.G.Ruffi	02	10/11/2014	Updated
F.Bucci	N.Manning	M.G.Ruffi	01	20/02/2014	Updated
F.Bucci	N.Manning	M.G.Ruffi	00	23/08/2013	New edition

## INDEX

<b>1. SCOPE</b> .....	<b>3</b>
<b>2. REFERENCES (LATEST EDITION)</b> .....	<b>3</b>
<b>3. DEFINITIONS AND ACRONYMS</b> .....	<b>3</b>
3.1 DEFINITIONS.....	3
3.2 ACRONYMS .....	4
<b>4. CONTENTS</b> .....	<b>4</b>
4.1 HAZOP PURPOSE AND GENERAL DESCRIPTION .....	4
4.2 METHODOLOGY .....	5
4.2.2 Nodes Identification.....	6
4.2.3 Reference Parameters and Guidewords .....	7
4.2.3.1 Main parameters and guidewords.....	7
4.2.3.2 Specific parameters and guidewords for discontinuous / batch process .....	9
4.2.4 Description and Design intent definition .....	9
4.2.5 Basic assumptions.....	10
4.2.6 Recording of HAZOP review’s outcomes .....	10
4.2.6.1 General aspects.....	10
4.2.6.2 Causes .....	10
4.2.6.3 Consequences .....	11
4.2.6.4 Safeguards.....	12
4.2.6.5 Recording Summary.....	13
4.2.7 Recommendations .....	14
4.2.8 Selection of proper type of HAZOP .....	15
4.3 DESCRIPTION OF HAZOP STUDY OPERATING PHASES .....	16
4.3.1 Main phases of HAZOP study.....	16
4.3.2 Phase 1 – Study preparation.....	16
4.3.2.1 Documentation .....	16
4.3.2.2 Nodes identification.....	17
4.3.2.3 HAZOP team.....	17
4.3.2.4 HAZOP schedule.....	18
4.3.3 Phase 2 – HAZOP sessions.....	19
4.3.3.1 Logistics.....	19
4.3.3.2 Attendance list .....	19
4.3.3.3 P&IDs Master Copy .....	19
4.3.3.4 Wrap-up meeting.....	19
4.3.4 Phase 3 – Reporting .....	19
4.3.5 Phase 4 – Follow-up .....	20
<b>ATTACHMENT 1 – HAZOP WORKSHEET</b> .....	<b>21</b>
<b>ATTACHMENT 2 – SOME CRITERIA FOR EVALUATION OF CONSEQUENCES</b> .....	<b>22</b>

## 1. SCOPE

This procedure defines modalities and methodologies to be followed in developing the Hazard and Operability - HAZOP - study.

## 2. REFERENCES (LATEST EDITION)

- IEC-61882 "Hazard and operability studies (HAZOP studies) – Application guide, 2016.
- "HAZOP and multistage hazard study", Institution of Chemical Engineers, 1999.
- "Guidelines for Hazard Evaluation Procedures", 2nd Edition, CCPS and AIChE, 1992.
- "A Guide to Hazard and Operability Studies", Chemical Industries Association, 1990.

## 3. DEFINITIONS AND ACRONYMS

### 3.1 DEFINITIONS

<b>CHARACTERISTIC</b>	Qualitative or quantitative property of an element (e.g. pressure, temperature, etc.), also identified as PARAMETER.
<b>DESIGN INTENT</b>	Describes the designer's desired or specific range of behaviour for elements and characteristics (operating conditions); also identified as "INTENTION".
<b>PARAMETERS</b>	The team generates possible deviations applying guidewords to various process parameters such as 'Flow', 'Level' and 'Pressure'. The selection of parameters is an important task for each team to devise for each individual system.
<b>GUIDEWORDS</b>	Simple words which are used to qualify each intention in order to guide and stimulate the creative thinking process and discover deviations.
<b>DEVIATION</b>	Departure from design intent. The variations from the intention are systematically identified by applying the "guidewords"
<b>CAUSE</b>	Reason the occurrence of deviation. Once a deviation can be shown to have a conceivable or realistic cause, then it becomes meaningful. Only single jeopardy together with all relevant effects shall be considered during HAZOP. Deviation is meaningful only if it is physically possible.
<b>CONSEQUENCES</b>	Results of the deviations.
<b>HAZARD</b>	Consequence which have the potential to cause damage, injury or loss
<b>SAFEGUARDS</b>	Protection, detection and indication mechanisms for the deviation and relevant consequences, which may be included within the selected part or form a portion of the design intentions of other parts
<b>RECOMMENDATION</b>	Additional safety measure identified by process team, intended to reduce the risk connected to a specific deviation (also identified as "ACTION").

## 3.2 ACRONYMS

<b>ALARP</b>	As Low As Reasonably Practicable
<b>EPC</b>	Engineering, Procurement and Construction
<b>ESD</b>	Emergency Shutdown
<b>FEED</b>	Front End Engineering Design
<b>FTA</b>	Fault Tree Analysis
<b>HAZOP</b>	Hazard and Operability Analysis
<b>HSE</b>	Health, Safety & Environment
<b>IPL</b>	Independent Protection Layer
<b>LOPA</b>	Layer Of Protection analysis
<b>MOC</b>	Management of Change
<b>PFD</b>	Process Flow Diagram
<b>P&amp;ID</b>	Piping and Instrumentation Diagram
<b>PSV</b>	Pressure Safety Valve
<b>QRA</b>	Quantitative Risk Analysis
<b>SIL</b>	Safety integrity level
<b>UFD</b>	Utility Flow Diagram

## 4. CONTENTS

### 4.1 HAZOP PURPOSE AND GENERAL DESCRIPTION

A HAZOP study (also named “HAZOP review” hereinafter) is a systematic approach for identifying process hazards and operability problems of process systems and it is conducted by a multi-disciplinary team of individuals led by a Chairperson knowledgeable and experienced with the HAZOP technique.

The HAZOP study covers all the process lines and equipment that are part of, or may be affected by system/unit/plant involved in the study itself. This may include existing upstream and downstream facilities that may be affected by the process under review. Both existing system and projects can be processes by HAZOP review.

Key aspect of the HAZOP study shall be to assess if deviations from the design intention could occur and, if so, whether such deviations are likely to be hazardous or not.

The HAZOP study is primarily focused on the identification of major hazards capable to produce significant damages on people, environment and equipment. The Chairperson shall lead the team through the review focusing the attention on major aspects.

During the review attention will be also paid to environmental issues and plant operation (e.g. production quality; loss of production, etc.), even if with minor emphasis than safety.

Consequences that will be recognized secondary by the whole team will not be further investigated.

A set of guidewords is used by the team to ensure the thoroughness and structured approach of the Study. The guidewords are combined with process parameters to develop deviations.

The technique is based on the premise that a hazard will not occur if the process does not deviate from the design intent. The team determines if the deviation could realistically occur and, if so, makes an assessment on whether the consequences constitute a hazard or an operability problem. The team then evaluates if safeguards, intended as hardware or procedures, are adequate considering the causes and consequences of



the deviation. If necessary, the team raises recommendation in order to enhance the design and mitigate possible risks. It is to highlight that:

- HAZOP is NOT a design check (it shall not provide design alternatives), nor an optimization study;
- HAZOP is NOT a tool addressed to find (detailed) solutions. The purpose is to highlight problems; relevant solutions may be proposed but will not be finalized during the session (shall be discussed in a separate session).

## 4.2 METHODOLOGY

### 4.2.1 Review workflow

The process/utility unit under analysis is divided into a set of sub units, composed by equipment, instrumentation and connecting lines. Each of these sub-units is named “node” and is characterized by specific process conditions.

The technique applies several guide words in order to identify the possible deviations from the process intents.

The analysis is performed in a systematic way, applying the following steps:

1. Identification of nodes;
2. Selection of node to be analysed;
3. Definition of the relevant design intent;
4. Application of a guideword;
5. Identification of relevant deviation;
6. Analysis of the possible causes, consequences, available protective measures and, If necessary, identification of specific recommendations with the aim of risk mitigation;
7. Identification of other deviations connected to the guide word and development of step 6;
8. Application of another guide word and development of steps 5 and 6;
9. Selection of another node and development of steps 3, 4, 5 and 6.

The above listed main steps of HAZOP review are summarized in the following scheme.




Figure 1 – HAZOP Workflow

Procedure is followed systematically until all P&IDs are analysed.

#### 4.2.2 Nodes Identification

A node is a manageable segment of system which has distinct design intent.

The node, typically comprise one major equipment (vessels, etc.), associated minor equipment (pumps, valves, etc.), instrumentation, and other ancillary equipment. Normally, the selection of node should follow the process flow and starts at an isolation point. Node size shall be properly defined taking into account that very small nodes, such as a single process line, often lead to longer study times as each guide word combination should be recorded more times, but, on the other hand large nodes, such as multiple process lines and equipment items, confuse the application of the guidewords and if not properly managed, could lead to overlooking hazards.

The following criteria should be considered in selecting the appropriate transition to the next node:

- Change in design intent;
- Change in state (e.g., from liquid to vapour);
- Major pieces of equipment;
- Position of isolation device.

For discontinuous / batch processes, a node can be represented by a single step/sequence (defined in terms of time and operating conditions). Some nodes can involve, in different steps, the same equipment/lines.

For example, a CSTR reactor is a single equipment, but can be operated in different steps (e.g. chemicals and solvent injection, reaction, crystallization, solvent distillation, etc).

A tank farm can be considered as a “hybrid” system, since some system can be used for both dedicated and multiple operations, thus it is suggested to use a different approach in nodes identification, or rather, “by operation” (e.g. gasoline discharge from ship, tank, gasoil transfer from tank to tank, gantry bottom loading for road tanker, etc.).

### 4.2.3 Reference Parameters and Guidewords

#### 4.2.3.1 Main parameters and guidewords

Main reference parameters are listed below:

- Flow;
- Level;
- Temperature;
- Pressure;
- Composition.

Additional parameter may be added case by case taking into account the characteristics of the process to be reviewed by HAZOP (e.g. pH, sequence, viscosity, amount, etc.). Additional parameter, if required, shall be defined and agreed by the team before the starting of the session.

The role of the guide word is to stimulate imaginative thinking, to focus the study and elicit ideas and discussion, thereby maximizing the chances of study completeness. Basic guidewords and their meanings are given in following table.

GUIDEWORDS	MEANING
NO or NOT	Complete negation of the design intent
MORE	Quantitative increase
LESS	Quantitative decrease
AS WELL AS	Qualitative modification / increase
PART OF	Qualitative modification / decrease
REVERSE	Logical opposite to the design intent
OTHER THAN	Complete substitution

**Table 1 – Basic HAZOP Guidewords**

Additional guidewords may be added case by case taking into account the characteristics of the process to be reviewed by HAZOP. If required, additional guidewords shall be defined and agreed by the team before the starting of the session.

The basic set of combination of parameters and relevant guidewords to be applied is reported on the following table.

PARAMETER	RELEVANT GUIDEWORDS			
Flow	No / Less	More	Reverse	Other than (misdirected)
Temperature	More	Less		
Pressure	More	Less/Vacuum		

Level	More	Less/No		
Composition	Other than			
Other than	Lack of utilities	Start/up - Shutdown	Corrosion / erosion	Other

**Table 2 – Combination of Basic Parameters and relevant Guidewords**

### 4.2.3.2 Specific parameters and guidewords for discontinuous / batch process

Proper parameter and guidewords shall be selected in case of discontinuous mode of operation either for automatic system or manned operations (“procedural HAZOP”).

In such cases, the following main parameter can be used in addition or to replace to the ones used for continuous processes:

- Amount;
- Sequence / Action;
- (clock) Time;
- Mixing;
- Reaction.

Supplementary guidewords are listed in the following table.

GUIDEWORDS	MEANING
TOO EARLY	The order of sequence has been respected, but not the execution time. The operation is carried out too early
TOO LATE	The order of sequence has been respected, but not the execution time. The operation is carried out too late
TOO FAST	The duration of the operation/sequence is shorter than what is normally planned
TOO SLOW	The duration of the operation/sequence is longer than what is normally planned
BEFORE	The order of sequence has not been respected
AFTER	The order of sequence has not been respected

**Table 3 – Supplementary HAZOP Guidewords**

An example of combination of additional parameter and relevant guidewords to be applied for discontinuous process is reported on the following table.

PARAMETER	RELEVANT GUIDEWORDS						
AMOUNT	No/less	More					
SEQUENCE / ACTION	Too early	Too late	Too fast	Too slow	Before	After	Other than
TIME	Less	More					
MIXING	No/less	More					
REACTION	No/less	More	Other than				

**Table 4 – Combination of Additional Parameters and relevant Guidewords**

### 4.2.4 Description and Design intent definition

An adequate representation of the system to be investigated is a mandatory initial step on HAZOP review. Process characteristics, control philosophy, safeguarding philosophy shall be properly identified and described, as well as the reference design intent. In particular, an overall representation of the system shall be performed and detailed description of single nodes shall be described is required.

#### 4.2.5 Basic assumptions

The following assumptions are adopted.

- Qualitative assessment of consequences does not take into account the availability and the effectiveness of relevant safeguard, unless the system is inherently safe.
- It is assumed that two or more concurrent failures of the same system / equipment will not occur, unless there is a common mode failure.
- When identical systems operate in parallel, study was done on one and the observations and findings are applicable to others.
- Only alarms and shutdown functions fully independent from control systems are considered as safeguards. In some cases, where highlighted consequences are associated only to operational problems also the presence of indicators (to DCS or in field) are considered as potential safeguards.
- Manual intervention is considered as a safeguard only if activated by dedicated independent alarms of the specific deviation, provided sufficient time and means are available for the operator to take actions and to bring the process to a safe state (at least 15-20 minutes). However, minimization of unnecessary alarms is followed as a general philosophy.
- The sentence: “Failure open (or failure close) of PIC (TIC, LIC, FIC, etc.)” implies the failure of any element of the control loop (sensor/transmitter, controller, transducer, control valve) that leads to a valve position which is different from the position required by design intention.
- In case of blinded line, the deviation "misdirect flow" is not analysed, either in case of misoperation and valve passing (internal leakage).

Other ground rules and assumption shall be defined case by case at the beginning of the study, taking into account client’s procedure, national regulations, international standards adopted and project basis.

#### 4.2.6 Recording of HAZOP review’s outcomes

##### 4.2.6.1 General aspects

HAZOP meeting will be recorded in “full recording” mode, to take evidence that all parameters and relevant guidewords have been processed for each node. Phrases such as “not applicable” or “no causes identified” will be applied in case parameter / guidewords are not relevant to the node.

If a deviation may occur and relevant consequences do not affect safety or environment, the expected scenario shall be, however, properly described (e.g.: loss of production, operational upset, product off-spec, etc.).

Recording will be performed by means of proper tool, such as PHA-works software by Primatech, or by other formats. HAZOP worksheet is included in **Attachment 1**.

Proper and detailed recording of cause, consequences and safeguards is also useful for possible further activities connected to HAZOP (e.g. LOPA, SIL Classification, FTA, QRA, etc.).

##### 4.2.6.2 Causes

Process Causes shall be properly described by identifying the involved equipment/machine/instrument and the relevant unexpected mode of failure or what kind of human error has been performed. Nevertheless, it is not necessary to go too much in detail; for example, if a cause is related to a pump failure it is sufficient to write “pump failure” including the relevant tag (“P-1 failure” or “P-1 fails to start when required”); it is to avoid to identify all the possible mode of failure of the pump (electrical failure, gearbox failure, shaft or coupling mechanical damage, etc.). The same for a control loop failure; the general statement involves the

whole control loop (and not the failure of each single element included in the loop itself), including the proper description of the failure mode. (e.g. “malfunction of FIC-001 that closes the relevant control valve FV-001”).

Cause can be grouped in the following four main categories:

- Instrumentation failure (control loop failures, spurious intervention of shut-down valves, etc.);
- Machinery failure (pumps, compressor, mixers, etc.);
- Human errors (inadvertent closure of opening of manual valve, improper input of set-point, etc.);
- Causes external to the system (e.g. general black-out, loss of supply from upstream units, etc.).

It is worthy to highlight that:

- it is assumed that two or more concurrent failures of the same system / equipment (“double jeopardy”) will not occur, unless there is a common mode failure (e.g. general power failure);
- a single cause of a deviation may lead to multiple consequences.

In order to have a clear approach to define all the possible hazardous scenario and, at the same time, to ensure that all the available safeguards are listed, the best solution is to adopt the following rule:

- Causes are identified within the node under investigation only (except for “external causes”); the relevant consequences can be in the node itself or everywhere else but will be recorded in the node where the deviation is generated.

Some exceptions can be applied in the following cases:

- Nodes at interface with other system not included in scope of work for the analysis;
- HAZOP on revamped unit (analysis on modified / new system only).

#### 4.2.6.3 Consequences

Following main rules shall be followed during evaluation of the consequences associated to each cause of deviation:

- assessment of consequences is performed by a qualitative approach;
- availability and effectiveness of safeguards in place are not taken into account.

Different consequences can be caused by the same initiating cause (e.g. inadvertent closure of a manual valve on the discharge on the pump may lead to: pressure increase in the discharge, loss of feed to the next system, level increase on upstream equipment, damage to the pump due to overheating, etc.

Each one of them shall be properly recorded, taking into account the target of the study defined at the beginning.

As already mentioned in the previous paragraph relevant to causes, each cause is identified within the node under investigation but the relevant consequence(s) shall be investigated up to the end point (either the nose itself or different nodes). By using this approach will be possible to list the complete set of safeguards available

Each consequence scenario and relevant dynamics shall be properly described. If overpressurization may occur, the simple sentence “Possible overpressurization of V-1” is not sufficient to proper understand which would be the impact level, even though such evaluation is carried out in a qualitative manner only. The mentioned scenario shall be described as follows: “*pressure increase in V-1 (dP = 3,5 barg) leading to possible overpressurization up to 8 barg, resulting in mechanical damage an loss of containment of flammable gas, with potential for fire/explosion*”.

When a system is inherently safe, it has to be considered during consequences evaluation. Taking into account the previous example, if the dP of V-1 was 9 bar, the consequences of pressure increase shall be as follow: “*pressure increase in V-1 (dP = 9 barg). No impact on mechanical integrity is expected since the max pressure that can be reached is 8 barg*”.

It is suggested to avoid cross links between deviations, to have a clear and faster recording. If we are investigating a no/less flow deviation on a pump discharge, one of the relevant consequences is the pressure build-up. Assuming that in the list of parameters flow came earlier than pressure, this scenario can be directly analysed up to the end point on no/less flow deviation, instead of writing a reference such “see pressure more” in flow deviations. When, later on, pressure deviation will be discussed, a brief reference to flow will be done for the above mentioned scenario, with no further investigations.

Some general criteria for qualitative assessment of consequences are reported on **Attachment 2**.

An additional column can be added to allocate each consequence scenario in the proper category simply using a letter for a better understating of the category of the expected impact (e.g.: S = safety, scenario that can affect personnel, E = environment; scenario that can lead to environmental pollution, F = financial or O = operational or A = asset for scenario having economic impact due to loss of production, loss of equipment, upsets, need for maintenance and relative repair cost).

#### 4.2.6.4 Safeguards

Safeguards shall be listed according to the sequence of intervention related to progressive layer of protection philosophy (e.g. alarm and human response, interlock, mechanical devices, etc.) and properly described (e.g. for interlocks, initiators, logic solver and final element shall be mentioned).

Proper and effective safeguards shall be listed for each single consequences scenario, taking into account that the following requirements shall be met:

- independency from the cause of the deviation and from other previously mentioned safeguards (e.g., an alarm associated to a control loop is not considered effective if the deviation is cause by a malfunction of the control loop itself);
- effectiveness in preventing the deviation or the relevant consequences (e.g. alarms are effective only if operator response is allowed, including adequate time to evaluate and react, proper action can be taken and in front of adequate training, adequacy of PSVs shall be verified for each cause of overpressure, etc. In order to ensure the complete effectiveness of safeguards, it is worthy to take into account and to investigate procedures to ensure that the functionality is not affected by lack of training, inadequate maintenance, operator mistake, failures, etc...),

Once adequacy of safeguards has been demonstrated, typical representation, taking a potential overpressurization case as an example, is shown here below:

- PI-1 provided with PAH and human response;
- PSHH-2 to activate logic I-1 closing XV-1;
- PSV-1.



#### 4.2.6.5 Recording Summary

In the following table, a summary of the main rules to be followed during HAZOP review and relevant recording.

1	Define the “battery limits” for cause and consequences.
2	Identify all the possible consequences associated to each cause, taking into account the objective of the analysis.
3	Consequences and relevant dynamics shall be properly described, including final scenarios.
4	Please avoid cross references between deviation; describe the scenario as soon as the it can be highlighted and don't remind to next deviations. Only in the following deviation it can be mentioned, making reference to previous deviations.
5	List all the available safeguards according to layer of protection approach, starting from alarm and human response, then interlocks and at the end mechanical and passive protections (following the dynamics of the scenario).
6	Remember that we can take credit on safeguards when they completely fulfil the following requirements: independency and effectiveness.
7	Full recording shall be adopted, if not otherwise clearly specified.

**Table 5 – HAZOP main rules**

#### 4.2.7 Recommendations

Where a potential hazard is identified, remedial action (recommendations) may be required depending on several factors, such as the likelihood of the event and the relevant magnitude of consequence, the poor availability / effectiveness of existing safeguard, etc. The recommendation is identified univocally by means of a code number shown on worksheet and need to be implemented in the revision of the drawings or addressed to additional studies and/or calculations (follow-up step).

As a general rule, the recommendations are worded in the following way:

- the words “Provide” or “Add” or “Change” or “Relocate” are used when the need for the required action are fully agreed within the Team, based on the available information;
- the word “Evaluate” are used when further consideration is required to the current design for any reason;
- the words “Verify” or “Ensure” are used to request further verification of specific items/features or consequences.

Recommendation shall be collected and included in the HAZOP report in a dedicated “action list”, where will be specified who is in charge for each action (“owner”).

In case further improvement / additional safeguards are required, if an immediate solution is available and acceptable to the team, it shall be recorded in the worksheet. On the contrary, where solutions are unlikely to be derived, without a technical evaluation, the Chairperson shall refer the problem for a separate assessment.

Discussion of problems/technical improvements out of the scope of the meeting and not under evaluation shall be kept to a minimum, together with re-design of the systems, which shall be avoided.

If required by Clients, agreed safety changes, including all queries, might be marked in red on the HAZOP Master P&IDs and possibly identified by a unique reference number.

If HAZOP is performed on existing plant, having the purpose to lower the risk level, prioritization of recommendation would be necessary to prepare a schedule associated to risk reduction plan for implementation of recommended actions.

#### 4.2.8 Selection of proper type of HAZOP

Level of detail, accuracy and objectives of a HAZOP study are related to the stage in the life-cycle of the project; depending on it, proper approach shall be adopted, as shown in the following table:

Type of HAZOP	COARSE HAZOP	MAIN HAZOP	FINAL HAZOP	HAZOP FOR R.A.
<b>Project life-cycle stage</b>	Project conceptual design	FEED	EPC / Execution phase	Existing plant
<b>Objective</b>	Highlight major hazards and possibility to change the design (including inherently safe design criteria)	Highlight process hazards (to verify if the unit will operate in safe manner); to analyse relationship with other units and to highlight possible major operational upsets.  No changes on design are expected as an outcome of the HAZOP review.	Analysis of packages provided by Vendors  To confirm proper close out of recommendation arisen from Main HAZOP  Procedural HAZOP	Analysis related to process risks including those related to operations
<b>Documentation</b>	PFDs Preliminary P&IDs (if available)	PFDs / H&MBs P&IDs and defined equipment / lines / instrumentation / PSVs data sheets	PFDs / H&MBs P&IDs issued for construction, C&E matrix, Data sheets	PFDs / H&MBs P&ID as built C&E matrix, Data sheets Operating procedures
<b>Notes</b>		Any further change in documentation to be managed by proper MOC procedure  May be required for changes / modification to existing units or to review procedures	Unit ready for construction / operation after final HAZOP	Existing unit
<b>Parameters and Guidewords</b>	Main	Main and possible additional specific guidewords	Main and possible additional specific guidewords used in FEED	Main

**Table 6 – Level of detail, accuracy and objectives of a HAZOP**

### 4.3 DESCRIPTION OF HAZOP STUDY OPERATING PHASES

#### 4.3.1 Main phases of HAZOP study

The HAZOP review process flow can be represented as follow:




Figure 2 – HAZOP Workflow

#### 4.3.2 Phase 1 – Study preparation

During this preliminary phase the following activities are foreseen for a successful development of the next stages:

- Collection of reference documentation;
- Nodes identification;
- HAZOP team composition;
- Scheduling / planning.

##### 4.3.2.1 Documentation

Documentation strictly necessary for the development of the HAZOP study is reported:

- Process and Utilities Basis of Design;
- Process description;
- Process Flow Diagram – PFD (or PFS);
- Utility Flow Diagram – UFD (or UFS);
- Heat and Material Balance (HMB);
- Project P&ID (or PEFS);
- Plot Plan;
- Cause & Effect matrix;

- Control, shutdown and process safeguarding philosophy (ESD Philosophy);
- Blow down, flaring and venting philosophy;
- Equipment and machinery data sheets;
- Piping data sheets;
- Pressure relief devices data sheets.

The above mentioned documentation (in particular the ones from point 1 to 6) shall be received by the Chairperson at least one week before the starting of the sessions.

The following documents shall be available in case of need:

- MSDS (Material Safety Data Sheets) of dangerous substances;
- detailed thematic plot plans, e.g. active fire systems, smoke/fire/gas detectors location, sewer networks, etc.;
- operating, maintenance and emergency procedures /manuals, if available according to the stage of the project.

#### 4.3.2.2 Nodes identification

Before starting HAZOP session, HAZOP nodes will be identified by Chairperson on PFDs and UFDs by marking –up the drawings. Identified nodes shall be submitted to Client for approval.

Nodes will be marked-up on the relevant P&IDs during the HAZOP session.

#### 4.3.2.3 HAZOP team

The HAZOP sessions, shall include following experts:

- HAZOP Chairperson;
- HAZOP Scribe;
- Lead HSE Engineer / HAZOP focal point / co-ordinator;
- Lead Process Engineer;
- Process Engineer;
- Process/Operation Specialist;
- Instrument Engineer (on call);
- Mechanical / maintenance Engineer (on call).

The tasks of the HAZOP “key figures” and other team members are described here below:

- **Chairperson** is an experienced technical person, who is responsible for nodes identification, leading the study with appropriate guidewords, establishing the detailed work schedule together with HAZOP focal point, ensuring that procedure is followed and that notes and results of the study are properly recorded and distributed, resolving any conflict that may arise during the study, ensuring that the team works toward a common goal by utilising expertise of all team members, and checking on the progress of the study. Furthermore, the Chairperson is responsible to verify the work progress in accordance with the schedule: this include taking/suggesting any corrective action required to prevent unwanted delay.
- **Scribe** is responsible for preparing HAZOP worksheets, HAZOP action list and HAZOP report, and recording and filing all documents (including attendance list) used and generated during the study in accordance with instructions of the Chairperson. She/he is also responsible for distributing HAZOP worksheets to attendees and specialists concerned.
- **HAZOP focal point** is responsible to arrange the meeting and to select the members of the working team; and additional and primary task is to collect the documentation and to distribute it to the

members. She/he is also in charge for establishing the detailed work schedule together with HAZOP Chairperson and to ensure that from a logistic point of view everything is fine. In case of controversy related to the scope of work of the projects, is responsible for clarifying and fixing out the project's boundaries.

- **Other Team Members** are responsible for providing comments based on their knowledge and experience to assist the team in resolving issues emerging during the study.

#### 4.3.2.4 HAZOP schedule

HAZOP schedule is prepared by the HAZOP Chairperson in co-operation with the HAZOP focal point, mainly basing on the following parameter:

- number of nodes;
- complexity of nodes (the higher the number of items in the node and the complexity of the process, the longer the average duration of analysis on each node);
- stage of the project (e.g. HAZOP performed during early stage of the project, since detailed information and drawings are not available takes less time than an HAZOP performed on later stages).

Following general criteria can be followed to prepare the HAZOP schedule:

- 2 ÷ 4 nodes per day for continuous process units (with nodes previously identified on PFDs);
- 3 ÷ 5 nodes per day for batch operations (e.g. fuel terminal operations);
- 3 ÷ 4 P&ID per day assuming one P&ID relevant to single node/equipment or operation.

### 4.3.3 Phase 2 – HAZOP sessions

HAZOP session will be held according to methodology described on Chapter 4.2.

#### 4.3.3.1 Logistics

For successful development of HAZOP analysis sessions, the availability of a dedicated meeting room of suitable dimensions and windows, with large table and a video projection system for showing to all participants the worksheets in progress is strongly required.

It is also recommendable the availability of a suitable number of copies of P&IDs to be distributed to each participant (also in A3 format) plus one copy (in original size) to be used as master copy of the session, where nodes will be marked-up over and which will be preferably hung on the meeting room walls.

HAZOP meeting is normally scheduled with two distinct sessions (morning and afternoon) of maximum three hours each one and suitable breaks (coffee/tea break of 10-15 minutes for each session and a lunch break of at least one hour).

HAZOP Team has the responsibility to be focused on HAZOP objectives, avoiding inconclusive discussions, in order to cope with scheduling agreed.

#### 4.3.3.2 Attendance list

During the sessions, the list of participants to HAZOP session will be daily recorded on dedicated sheets according to ICARO MOD-CT01-01 format (or equivalent), including:

- Name;
- Company;
- Role/Discipline;
- Signature.

#### 4.3.3.3 P&IDs Master Copy

Nodes will be highlighted on large size P&IDs (preferably ISO A1 or ISO A2) during the sessions. Master copy should be signed-in by Chairperson and representative of the Companies involved at the end of HAZOP workshop.

After signature they will be scanned to be attached to the HAZOP report.

#### 4.3.3.4 Wrap-up meeting

At the end of the session, few hours shall be spent for a wrap-up meeting addressed to review the action arisen from HAZOP and the main topics. Following the wrap up, the list of recommendation shall be considered fully agreed by the team members.

### 4.3.4 Phase 3 – Reporting

A dedicated HAZOP report will be issued at the end of the sessions describing the following main topics:

- Scope of the study;
- Process descriptions;
- Methodology description;

- Table of deviations;
- Daily attendance list;
- Nodes list;
- Reference documentation;
- P&IDs used for the HAZOP sessions (marked-up “master copies”);
- HAZOP worksheets;
- Recommendations (actions) list.

A preliminary draft of the report is usually issued for comments one week after completion of the review. Since worksheets are supposed to be projected, in a manner that all participants can check, verify and agree what has been recorded, worksheet can be issued and distributed for information only. If required, worksheet can be printed out at the end of the session and signed by the key-figures.

#### 4.3.5 Phase 4 – Follow-up

Follow-up phase is the latest stage of an HAZOP review; during the phase the implementation of HAZOP recommendation is monitored (“follow-up” or “close-out” register) to ensure that all the action arisen from HAZOP will be included in the next stage of the project.

However, follow-up stage shall be considered a dedicated step, which will be managed separately by the Client.



### ATTACHMENT 1 – HAZOP WORKSHEET

<b>Study</b>		<b>Node</b>				
<b>Client</b>		<b>Node Intention</b>				
<b>Plant</b>						
<b>Session n° / date</b>		<b>Temperature</b>				
<b>Chairperson</b>		<b>Pressure</b>				
<b>Team</b>		<b>Flow rate / Capacity</b>				
		<b>Composition / other</b>				
		<b>Drawing n.</b>				
<b>Notes</b>						
<b>Parameter</b>	<b>Guideword</b>	<b>Causes</b>	<b>Consequences</b>	<b>Safeguards</b>	<b>Recommendations</b>	<b>By (Owner)</b>
<b>Flow</b>	None/Less					
	More					
	Less					
	Reverse					
	Misdirect					
<b>Temperature</b>	More					
	Less					
<b>Pressure</b>	More					
	Less/Vacuum					
<b>Level</b>	More					
	Less/No					
<b>Composition</b>	Other Than					
<b>Other</b>	Lack of utilities					
	Start-up/shut-down					
	Maintenance / isolation					
	Other					

## ATTACHMENT 2 – SOME CRITERIA FOR EVALUATION OF CONSEQUENCES

Here below some additional technical criteria to be used as a reference to evaluate the consequences. These criteria may vary or be reviewed and defined according to project specifications.

### HP/LP systems interface (“gas break-through”)

Shall be considered the maximum operating pressure on the HP system vs. design pressure of the LP system. If maximum operating pressure on the HP system cannot be defined, the relevant design pressure shall be considered. Same assumption to be applied in case of reverse flow (gas / vapour phase).

### Overfilling

In case of overfilling, shall be verified first if adequate inherently safe systems are in place to prevent overpressurization (e.g. open vent adequately sized to handle the incoming flow rate). If available, the relevant scenario shall be the outflow of the processed product. If not, overpressurization may be expected. The maximum operating pressure of the incoming product shall be considered vs. the design pressure of the potentially overfilled equipment; if the fluid is transferred by means of centrifugal pumps, the relevant shut-off pressure. For other cases the design pressure of the system upstream the equipment shall be considered. Same assumption will be applied in case of reverse flow (liquid phase).

### Blocked outlet

As reference pressure shall be considered the maximum operating pressure on the upstream system vs. design pressure of involved system. If the fluid is transferred by means of centrifugal machinery, the relevant shut-off pressure shall be considered. For other cases the design pressure of the system upstream the equipment shall be considered.

### Reverse flow

Over pressurization case cannot be excluded even though check valves are provided; as defined by API 521 std. and therefore PSV shall be verified also for this scenario (relief load for PSVs can be assumed as 10% of maximum theoretical flow-rate if two check valves, dissimilar type e periodically tested are provided, API 521, § 4.3.4.4).

### Tube rupture case (tube&shell heat exchangers)

Over pressurization case can be excluded when tube&shell heat exchangers are designed at list according to 10/13 ASME rule ore more stringent codes.

### External fire case

External fire case shall be always verified. Any exclusion for PSV requirement shall be justified.

For fixed roof atmospheric tanks this scenario shall be verified as well (according to std. API 2000 § 4.3.3) unless the tank is provided with frangible welding of the fixed roof (see std. API 650).



# ICARO

## GUIDE LINES

### Safety Integrity Level studies (SIL)



PROPOSED	CHECKED	APPROVED	REV.	DATE	DESCRIPTION
F. Bindi	N. Manning	B. Frattini	03	31/01/2018	Updating
F. Bindi	N. Manning	M. G. Ruffi	02	10/11/2014	Updating
F. Bindi	N. Manning	M. G. Ruffi	01	01/03/2014	Updating
G. Monanni	N. Manning	M. G. Ruffi	00	19/11/2007	First issue

## INDEX

<b>1. SCOPE .....</b>	<b>3</b>
<b>2. REFERENCES .....</b>	<b>3</b>
2.1 Reference guidelines .....	3
2.2 Reference documents.....	3
<b>3. DEFINITIONS AND ACRONYMS .....</b>	<b>4</b>
3.1 Definitions .....	4
3.2 Acronyms .....	6
<b>4. CONTENTS.....</b>	<b>7</b>
4.1 SIL methodology .....	7
4.1.1 Foreword .....	7
4.1.2 Logic scheme .....	8
4.1.3 Methodology .....	9
4.2 PHASE 1 – SAFETY REQUIREMENTS ALLOCATION .....	10
4.2.1 The Risk Graph method .....	10
4.2.2 The Risk Matrix method .....	13
4.3 PHASE 2 – VERIFICATION .....	17
4.3.1 Representation of SIFs Architectures .....	17
4.3.2 Reliability Data collection .....	18
4.3.4 Reference for the selected reliability values .....	19
4.3.5 Application of availability models in order to establish the overall PFD of the complete loop .....	19
4.3.6 PFD average requirement for Verification .....	20
4.3.7 Architectural requirements for Verification .....	21
<b>ATTACHMENT 1 – SIL ALLOCATION WORKSHEET .....</b>	<b>22</b>
<b>ATTACHMENT 2 – EXAMPLE OF SIF ARCHITECTURE .....</b>	<b>23</b>
<b>ATTACHMENT 3 – EXAMPLE OF PFD CALCULATION BY FTA .....</b>	<b>23</b>

## 1. SCOPE

This procedure defines modalities and methodologies to be followed in developing the Safety Integrity Level - SIL- studies, including Allocation Requirement and Verification phases.

Industrial risk is usually conceived as a measure of human injury, environmental damages or economic losses in combined terms of both the probability and the magnitude of injuries, damages and losses, following a major accident. A major industrial accident is generally caused by an initial a loss of containment and further release of material and/or energy in the environment, able to origin hazardous effects for humans, environment and properties. An accident may evolve in several forms (different scenarios). For example, a release of toxic and concurrently flammable substances may result in:

- fires (immediate ignition at the release);
- flash fire (delayed ignition of a limited quantity of vapours in air);
- vapour cloud explosion (delayed ignition of a significant amount of vapours);
- toxic cloud dispersion (no ignition).

For each scenario, the hazardous effects assume different characteristics, all endangering humans, environment and property as for instance:

- radiation waves, from fires and fireballs;
- pressure waves, from explosions, both confined and unconfined;
- toxic contaminations, in air, soil or water, capable to lead to immediate or delayed effects.

Consequences of hypothesized accidents are measured by the intensity/gravity of the effects in relation to the threshold vulnerability limits and to the extension/expositions of human beings, of the environmental components and of the properties affected. In order to minimise the probability of occurrence of accidents and to minimise the consequences in case an accident occurs, the Safety Integrity Level (SIL) analysis of emergency/trip functions is performed. The SIL analysis is a systematic activity that includes both allocation and verification to be performed to all emergency/trip functions. The technique uses a team of reviewers with expertise in several key areas. The Safety Integrity Level analysis developed in ICARO complies with international standards as well as with the EU regulations, descending by the first Seveso Directive and further amendments.

## 2. REFERENCES

### 2.1 Reference guidelines

- IEC 61508:2010 Part 1÷7 “Functional Safety of Electrical / Electronic / Programmable Electronic Safety-Related Systems”;
- IEC 61511:2016 Part 1÷3 “Functional safety – Safety Instrumented Systems for the Process Industry Sector.

### 2.2 Reference documents

Main reference documents to be made available during Hazop analysis are the following:

- Piping and Instrumentations diagrams (P&Ids);
- Emergency system design philosophy;
- Cause & Effects diagrams;
- Pressure safety valves data sheets;
- Process description;
- Piping general arrangement;
- Plant/unit blow down report.

Moreover, the following documents should be available in case of need:

- Equipment and piping data sheets;
- Operating, maintenance and emergency procedures/manuals;
- Process Flow Diagrams (PFD);
- Heat and Material Balance (H&MB);
- Plant plot plans;
- Detailed plot plans, e.g. active fire systems, smoke/fire/gas detectors location, sewer networks, etc.

### 3. DEFINITIONS AND ACRONYMS

#### 3.1 Definitions

<b>Basic Process Control System</b>	The system that responds to input signals from the process and generates output signals to maintain operation of the process in a desired state. The system does not perform functions assessed as SIL 1 or higher.
<b>Beta Factor</b>	The number of Common Mode Failures (of robust Initiators or Final Elements), expressed as a fraction of all possible Failures.
<b>Common Mode Failure</b>	A Failure having the potential to affect all duplicated components in a robust configuration by virtue of common or shared characteristics.
<b>Dangerous Failure</b>	A Failure that has the potential to place the SIL/IPF in a state in which it will fail to perform its function. Dangerous Failures are usually only safe when the system has to perform a certain action or through testing. Also known as unrevealed failure.
<b>Dangerous Failure Rate</b>	The number of Dangerous Failures per unit time.
<b>Dangerous Failure Robustness</b>	A configuration in which plant integrity is not jeopardised by the Dangerous Failure of a single SIL/IPF component. Also known as unrevealed failure robustness.
<b>Demand</b>	A process or equipment condition or event which requires an IPF / SIF to take action to prevent a Hazardous Situation.
<b>Demand Rate</b>	The frequency at which a Demand occurs, i.e., the number of Demands per unit time.
<b>Diagnostic Coverage Factor</b>	The number of Dangerous Failures that diagnostic features are capable of detecting, expressed as a fraction of all possible dangerous failures.  (NOTE: Diagnostic features may only be recognised as such if they can trip the process to a safe state or maintain safety by different means.)
<b>Failure</b>	An abnormal condition that may cause a reduction or loss of capability of the IPF to perform its intended function.
<b>Final Element</b>	A device, or combination of devices, that manipulate a process variable or attract the attention of the operator to achieve risk reduction. The Final Element includes output cards or output relays, solenoid valves and cabling. Examples are valves, switchgear (rotating equipment stop circuits) and alarms.
<b>Hazard or Hazardous Situation</b>	A situation with the potential to cause harm, including ill health and injury, damage to property, products or the environment, production losses or increased liabilities.
<b>Hazard Rate</b>	The frequency at which Hazardous Situations occur per unit time.  Hazard Rate = Demand rate x Probability of Failure on Demand.
<b>Initiator</b>	A device, or combination of devices, that indicates whether a process or equipment item is operating outside the operating envelope. The Initiator includes input cards and input relays. Examples are manual switches, position switches and measurement systems (including process connections, sensors, transmitters, cabling, trip amplifiers or input cards etc.).  In IEC 61508/61511 an Initiator is referred to as a Sensor.
<b>Independent Protection Layer</b>	IPL. Device, system, or action that is capable of preventing a postulated accident sequence from proceeding to a defined, undesirable endpoint. An IPL is (1) independent of the event that initiated the accident sequence and (2) independent of any other IPLs. IPLs are normally identified during layer of protection analyses.
<b>Inspection Time</b>	Time interval between proof tests

<b>Instrumented Protective Function</b>	<p>A function comprising one or more Initiators, a Logic Solver and one or more Final Elements whose purpose is to prevent or mitigate hazardous situations.</p> <p>An IPF is intended to achieve or maintain a safe state for the process, in respect of a specific hazardous event.</p> <p>In IEC 61508/61511 an IPF is referred to as a SIF.</p>
<b>Instrumented Protective System / Safety Instrumented System</b>	<p>The electromechanical, electronic and/or programmable electronic Logic Solver component of the Instrumented Protective Function, complete with input and output equipment. In IEC 61508/61511 an IPS or SIS are referred to as a 'Logic Solver'.</p>
<b>Logic Solver</b>	<p>The portion of an IPF / SIF that performs the application logic function. The Logic Solver excludes trip amplifiers, input cards and output cards. Examples are electromechanical relays, solid-state/magnetic-core logic and the CPU section of programmable electronic systems.</p>
<b>Mean Time To Restoration</b>	<p>Time interval to repair the failing component. Includes repair time, shipping and managing time</p>
<b>Mitigation</b>	<p>The action of making a consequence less severe or relieving consequences.</p>
<b>Partial Valve Stroke Test</b>	<p>Technique to test a percentage of the possible failure modes of a valve without the need to physically fully close the valve itself.</p>
<b>Probability of Failure on Demand</b>	<p>The probability (dimensionless) of the IPF or SIS failing to respond to a Demand.</p>
<b>Programmable electronics</b>	<p>Electronic component or device forming part of a PES and based on computer technology. The term encompasses both hardware and software and input and output units.</p> <p>(NOTE: This term covers micro-electronic devices based on one or more CPUs together with associated memories, etc. Examples of process sector programmable electronics include: smart sensors; final elements; and programmable electronic logic solvers, such as, programmable controllers, PLCs, DCS, loop controllers.)</p>
<b>Programmable Electronic System</b>	<p>System for control, protection or monitoring based on one or more programmable electronic devices, including all elements of the system such as power supplies, sensors and other input devices, data highways and other communication paths, actuators and other output devices. As an example, an IPS or SIS could be a PES.</p>
<b>Proof Test</b>	<p>A test carried out on IPF components against an approved procedure to confirm that all requirements of the IPF are met.</p>
<b>Proof Test Coverage Factor</b>	<p>The number of Dangerous Failures detected by the Proof Test expressed as a fraction of all possible dangerous failures.</p>
<b>Risk</b>	<p>The frequency at which a Hazardous Situation occurs multiplied by the consequence of the Hazardous Situation.</p>
<b>Risk Reduction Factor</b>	<p>Is the contribute on an IPL to reduce risk allocated.</p>
<b>Safe Failure</b>	<p>A Failure whose occurrence does not have the potential to place an IPF in a dangerous state. Also known as revealed failure.</p>
<b>Safe Failure Rate</b>	<p>The number of Safe Failures per unit time.</p>
<b>Safe Failure Fraction</b>	<p>The safe failure fraction (SFF) is the fraction of the overall failure rate of a device that results in either a safe fault or a diagnosed unsafe fault.</p>
<b>Safety Integrity Level</b>	<p>Dangerous failure class 1, 2, 3 or 4 derived from the consequences of failure on demand and the frequency of demand. The definition in IEC 61511: discrete level (one out of four) for specifying the safety integrity requirements of the IPF / SIF to be allocated to the SIS (trip systems). Safety integrity level 4 has the highest level of safety integrity; safety integrity level 1 has the lowest.</p>
<b>Trip</b>	<p>An Instrumented Protective Function action to bring the Final Element to a safe state.</p>
<b>Undetected Failure</b>	<p>A failure that is not detected by internal diagnostics</p>
<b>Validation</b>	<p>Confirmation that the system under consideration fully meets the integrity requirements set forth in the associated IPF Requirements Specification.</p>
<b>Verification</b>	<p>Demonstration for a particular life-cycle phase that all deliverables (documents, software, hardware) meet the objectives set for that phase.</p>



### 3.2 Acronyms

<b>BDV</b>	Blow-Down Valve
<b>BPCS</b>	Basic Process Control System
<b>C&amp;ED</b>	Cause and Effects Diagram
<b>DCS</b>	Distributed Control System
<b>ESD</b>	Emergency Shut Down
<b>ESDV</b>	Emergency Shut Down Valve
<b>F&amp;G</b>	Fire and Gas
<b>HAZOP</b>	Hazard and Operability study
<b>HFT</b>	Hardware Fault Tolerance
<b>IE</b>	Initiating Event
<b>IEC</b>	International Electrotechnical Commission
<b>IPL</b>	Independent Protection Layer
<b>IPF</b>	Instrumented Protective Function
<b>IPS</b>	Instrumented Protective System
<b>LOPA</b>	Level Of Protection Analysis
<b>MTTR</b>	Mean Time To Restoration
<b>P&amp;Id</b>	Piping and Instrumentation Diagram
<b>PE</b>	Programmable Electronics
<b>PES</b>	Programmable Electronic System
<b>PLC</b>	Programmable Logic Controller
<b>PF</b>	Probability of Failure on Demand
<b>PSV</b>	Pressure Safety Valve
<b>PVST</b>	Partial Valve Stroke Test
<b>SDV</b>	Shut Down Valve
<b>SFF</b>	Safe Failure Fraction
<b>SIF</b>	Safety Instrumented Function
<b>SIL</b>	Safety integrity Level
<b>SIS</b>	Safety Instrumented System
<b>TI</b>	Inspection Time

**4. CONTENTS**

**4.1 SIL methodology**


**4.1.1 Foreword**

A Safety Integrity Level (SIL) analysis is a key step in the Safety System Design Process. While the HAZOP process normally discovers potential hazards and provides general recommendations, the SIL is a specific analysis which defines the Safety Criteria and Mitigation of hazards which can lead to a significant safety, environmental and economic consequences.

SIL analysis is performed according to the IEC 61508<sup>1</sup> extensive standard, which is essentially a framework for implementing instrumented safety systems using the principle of Safety Life Cycle, and the IEC 61511<sup>2</sup>, developed as a Process Sector implementation of IEC 61508.

An important concept in the standard is that of the Safety Instrumented Function (SIF), which is a function to be implemented by a Safety Instrumented System (SIS) composed mainly by sensors (e.g. transmitters), logic solvers (E/E/PE) and final elements (e.g. solenoids), which is intended to achieve or maintain a safe state for the process, with respect to a specific hazardous event.

A SIS can be seen as a method to reduce the overall risk, acting as independent protection layer, as showed on the following figure.



**Figure 1 – Independent Protection Layers approach**

From this point of view, an independent protection layer is a “system” fully independent from the others capable to reduce the risk, by preventive or protective actions, e.g. an explosion proof design, a PSV, a SIS, a F&G system, an emergency procedure, etc.

Each key SIF must be evaluated for the severity of the protected risk and the performance of the SIF must be commensurate with the risk. The performance level for each SIF must address both the reliability and availability requirements of the SIF. Both of these factors are combined into a single index termed SIL, which

<sup>1</sup> Functional safety of electrical/electronic/programmable electronic safety-related systems.

<sup>2</sup> Functional safety – Safety instrumented systems for the process industry sector.

is defined as the likelihood of the system satisfactorily performing the required safety function under all the stated conditions within a stated period of time.

The SIL ratings can be equated to the Probability to Fail on Demand (PFD), in a defined interval of time, of the relevant SIF. Relationship between SIL and Process Failure on Demand is indicated in the following table, in case of Shut Down Systems (not continuously operating systems<sup>3</sup>).

Safety Integrity Level (SIL)	Probability of failure on demand (PFD)
4	$\geq 10^{-5} - < 10^{-4}$
3	$\geq 10^{-4} - < 10^{-3}$
2	$\geq 10^{-3} - < 10^{-2}$
1	$\geq 10^{-2} - < 10^{-1}$

**Table 1 - Relationship between SIL and Process Failure on Demand, low demand mode of operation**

Same criteria apply also for the identification of the Asset Integrity Level of the plant/station. The analysis is to be done separately due to fact that productive asset is mainly linked to economic aspects (loss of production, loss of materials, etc.) and not necessarily linked with safety. Combined but distinct analysis allows to have a more complete picture of the risk and mostly to select the most appropriate level of protection.

The development of SIL analysis sessions usually requires the participation of following multidisciplinary experts:

- SIL analysis Facilitator (and Secretary), an independent expert in safety and reliability, who has the duty to guide the SIL Team through the application of all necessary phases of the analysis;
- Process and Instrument engineers, with the task to provide necessary technical information and answers to the questions of the Facilitator;
- Project Engineer, with the task to support the SIL Team with specific considerations from project management point of view.

The proposed methodology shall be applied to all protective functions, as detailed on the cause & effect diagrams/matrixes.

#### 4.1.2 Logic scheme

The overall logic scheme of the so called SIL Assessment process is shown by the following flow chart:

<sup>3</sup> Low Demand Mode: where frequency of demands for operation made on a safety-related system is no greater than one per year and no greater than twice the proof-test frequency (IEC 61508-4).




Figure 2 – SIL Assessment process

### 4.1.3 Methodology

SIL analysis is performed in two phases:

- a) **Safety Requirements Allocation:** allocation of the most appropriate SIL to each SIF, by means of the evaluation of demand rate and magnitude of consequences, considering the SIF assessed not in place. The IEC 61508 does not provide a mandatory way to perform the safety requirement allocation phase; here are provided the following three suggested methods:
  - Risk Graph;
  - Risk Matrix.

Relevant details are provided below. In case, a different method can be followed, according to Client’s specifications.

- b) **Verification:** quantitative verification, according to the IEC-61508, that the proposed designing of the relevant SIS is conforming to the SIL required.

## 4.2 PHASE 1 – SAFETY REQUIREMENTS ALLOCATION

As a general point view, SIL analysis is the systematic assessment of key logic functions designed to manage the Emergency Shut Down of the process plant, as detailed in the Cause & Effects Diagram.

Logic steps to develop the SIL Allocation process are the following:

- a) brief introduction and description of the process;
- b) analysis of Cause & Effects diagrams;
- c) selection of first logic function (Safety Instrument Function, SIF) to analyse and analysis of design intent;
- d) selection of the safety requirement allocation method;
- e) evaluation of demand rate (frequency of occurrence) and magnitude of consequences in case of failure on demand;
- f) evaluation of additional parameter required by the method selected;
- g) evaluation of SIL requested to the SIF selected by application of the selected safety requirement allocation method;
- h) analysis of consequences of spurious trip, if necessary;
- i) selection of following logic function to analyse and actions from d) to h).

Procedure is applied in a systematic way up to final completion of all the logic functions to be analysed; when a SIF is analysed, it is assumed that all other SIFs function correctly.

Safety requirements allocation results are reported on the format provided on the **Attachment 1**.

### 4.2.1 The Risk Graph method

Risk is defined as a combination of the probability of occurrence of harm and the severity of that harm (see Clause 3 of IEC 61511-1). Typically, in the process sector, risk is a function of the following four parameters:

Parameter		Description
<b>Consequence of the hazardous situation</b>	<b>C</b>	Number of fatalities and/or serious injuries likely to result from the occurrence of the hazardous event. Determined by calculating the numbers in the exposed area when the area is occupied taking into account the vulnerability to the hazardous event.
<b>Occupancy</b> (probability that the exposed area is occupied)	<b>F</b>	Probability that the exposed area is occupied at the time of the hazardous event. Determined by calculating the fraction of time the area is occupied at the time of the hazardous event. This should take into account the possibility of an increased likelihood of persons being in the exposed area in order to investigate abnormal situations which may exist during the build-up to the hazardous event (consider also if this changes the C parameter).
<b>Probability of avoiding the hazardous situation</b>	<b>P</b>	The probability that exposed persons are able to avoid the hazardous situation which exists if the safety instrumented function fails on demand. This depends on there being independent methods of alerting the exposed persons to the hazard prior to the hazard occurring and there being methods of escape.
<b>Demand rate</b> (number of times per year that the hazardous situation would occur in the absence of the safety instrumented function being considered)	<b>W</b>	The number of times per year that the hazardous event would occur in the absence of the safety instrumented function under consideration. This can be determined by considering all failures which can lead to the hazardous event and estimating the overall rate of occurrence. Other protection layers should be included in the consideration.

**Table 2 - SIL Allocation Parameters**

### RISK GRAPH

The required SIL of the selected SIF is established according to a semi-quantitative way proposed by the IEC-61511. The Risk Graph procedure is shown by the following figure:




Figure 3 - Risk Graph for SIL Allocation

Calibration of the risk graph is the process of assigning numerical values to risk graph parameters in order to:

- describe all parameters in such a way as to enable the SIL assessment team to make objective judgements based on the characteristics of the application;
- ensure the SIL selected for an application is in accordance with corporate risk criteria and takes into account risks from other sources;
- enable the parameter selection process to be verified.
- The following calibration is proposed by the IEC-61511 as an example.

**CONSEQUENCES (TO PEOPLE)**

Risk parameter	Classification	Comments
Consequence (C) Number of fatalities  This can be calculated by determining the numbers of people present when the area exposed to the hazard is occupied and multiplying by the vulnerability to the identified hazard.  The vulnerability is determined by the nature of the hazard being protected against. The following factors can be used: V = 0,01 Small release of flammable or toxic material V = 0,1 Large release of flammable or toxic material V = 0,5 As above but also a high probability of catching fire or highly toxic material V = 1 Rupture or explosion	C <sub>A</sub> Minor injury  C <sub>B</sub> Range 0,01 to 0,1  C <sub>C</sub> Range >0,1 to 1,0  C <sub>D</sub> Range >1,0	1 The classification system has been developed to deal with injury and death to people.  2 For the interpretation of C <sub>A</sub> , C <sub>B</sub> , C <sub>C</sub> and C <sub>D</sub> , the consequences of the accident and normal healing should be taken into account.

Table 3 - Risk Graph – Consequences to People

**CONSEQUENCES (TO ENVIROMENT)**

Risk parameter		Classification	Comments
Consequence (C)	C <sub>A</sub>	A release with minor damage that is not very severe but is large enough to be reported to plant management	A moderate leak from a flange or valve Small scale liquid spill Small scale soil pollution without affecting ground water
	C <sub>B</sub>	Release within the fence with significant damage	A cloud of obnoxious vapour travelling beyond the unit following flange gasket blow-out or compressor seal failure
	C <sub>C</sub>	Release outside the fence with major damage which can be cleaned up quickly without significant lasting consequences	A vapour or aerosol release with or without liquid fallout that causes temporary damage to plants or fauna
	C <sub>D</sub>	Release outside the fence with major damage which cannot be cleaned up quickly or with lasting consequences	Liquid spill into a river or sea A vapour or aerosol release with or without liquid fallout that causes lasting damage to plants or fauna Solids fallout (dust, catalyst, soot, ash) Liquid release that could affect groundwater

Table 4 - Risk Graph – Consequences to Environment

## OCCUPANCY

Risk parameter	Classification	Comments
Occupancy (F) This is calculated by determining the proportional length of time the area exposed to the hazard is occupied during a normal working period. NOTE 1 If the time in the hazardous area is different depending on the shift being operated then the maximum should be selected. NOTE 2 It is only appropriate to use F <sub>A</sub> where it can be shown that the demand rate is random and not related to when occupancy could be higher than normal. The latter is usually the case with demands which occur at equipment start-up or during the investigation of abnormalities.	F <sub>A</sub> Rare to more frequent exposure in the hazardous zone. Occupancy less than 0,1  F <sub>B</sub> Frequent to permanent exposure in the hazardous zone	3 See comment 1 above.

Table 5 - Risk Graph – Occupancy

## PROBABILITY OF AVOIDING THE HAZARDOUS SITUATION

Probability of avoiding the hazardous event (P) if the protection system fails to operate.	P <sub>A</sub>	Adopted if all conditions in column 4 are satisfied	4 P <sub>A</sub> should only be selected if all the following are true: – facilities are provided to alert the operator that the SIS has failed; – independent facilities are provided to shut down such that the hazard can be avoided or which enable all persons to escape to a safe area; – the time between the operator being alerted and a hazardous event occurring exceeds 1 hour or is definitely sufficient for the necessary actions.
	P <sub>B</sub>	Adopted if all the conditions are not satisfied	

Table 6 - Risk Graph – Consequences

**DEMAND RATE**

<p>Demand rate (W) The number of times per year that the hazardous event would occur in absence of SIF under consideration.</p> <p>To determine the demand rate it is necessary to consider all sources of failure that can lead to one hazardous event. In determining the demand rate, limited credit can be allowed for control system performance and intervention. The performance which can be claimed if the control system is not to be designed and maintained according to IEC 61511, is limited to below the performance ranges associated with SIL1.</p>	W <sub>1</sub>	Demand rate less than 0,1 D per year	<p>5 The purpose of the W factor is to estimate the frequency of the hazard taking place without the addition of the SIS.</p> <p>If the demand rate is very high, the SIL has to be determined by another method or the risk graph recalibrated. It should be noted that risk graph methods may not be the best approach in the case of applications operating in continuous mode, see 3.2.43.2 of IEC 61511-1.</p> <p>6 D is a calibration factor, the value of which should be determined so that the risk graph results in a level of residual risk which is tolerable taking into consideration other risks to exposed persons and corporate criteria.</p>
	W <sub>2</sub>	Demand rate between 0,1 D and D per year	
	W <sub>3</sub>	Demand rate between D and 10 D per year	
		For demand rates higher than 10 D per year higher integrity shall be needed	

**Table 7 - Risk Graph – Demand rate**

**AVAILABILITY OF INDEPENDENT PROTECTION LAYERS (IPLS)**

In case of availability of an IPL, this acts reducing the level of SIL allocated, because participates to the overall integrity objective. The Risk Reduction Factor of an IPL is the reciprocal of relevant PFD.

An IPL meets the following criteria (from IEC 61511):

- Specificity: the protection layer is designed to prevent or mitigate the consequences of one potentially hazardous event. Multiple causes may lead to the same hazardous event, and therefore multiple event scenarios may initiate action by an IPL;
- Independence: the protection layer is independent of other protection layers if it can be demonstrated that there is no potential for common cause or common mode failure with any other claimed IPL;
- Dependability: the protection layer can be counted on to do what it was designed to do by addressing both random failures and systematic failures during its design;
- Auditability: the protection layer is designed to facilitate regular validation of the protective functions.

Examples of IPL and relevant RRF are provided on the following table.

Independent Protection Layer	RRF
Pressure Safety Valve (PSV) <sup>4</sup>	100
Rupture Diks	100
Basic Process Control Systems (independent)	10
SIF independent, allocated SIL 1 (PFDavg between 1*E-1 and 1*E-2)	10
SIF independent, allocated SIL 2 (PFDavg between 1*E-2 and 1*E-3)	100
SIF independent, allocated SIL 3 (PFDavg between 1*E-3 e 1*E-4)	1000
Operator intervention (in presence of unambiguous alarm and enough time to evaluate and counteract)	10

**Table 8 - IPL and relevant RRF**

**4.2.2 The Risk Matrix method**

<sup>4</sup> PSV shall be verified for the scenario under assessment ant relevant discharge shall be routed to a safe position.



One qualitative method that enables the SIL of a SIF to be determined is the Risk Matrix method. This method applies knowledge of the risk factors associated with the equipment under consideration and the equipment control system to make that determination.

Where a qualitative approach is adopted, a number of parameters are introduced that together describe the nature of the hazardous situation when safety systems fail or are not available. One parameter is chosen from each of four sets, and the selected parameters are then combined to derive the overall Safety Integrity Level allocated to the safety related systems. These parameters:

- allow a meaningful graduation of the risk to be made, and
- contain the key risk assessment factors.

The following simplified procedure is based on following relationship:

$$R = f \times C$$

**R (Risk)** is the combination (product) of occurrence of harm (frequency) and the severity of that harm (Consequence) and is considered, in this context, as having no safety-related systems in place.

**f (Frequency)** is the hazard rate of the hazardous event with no safety-related systems in place, i.e., the number of hazardous event per unit time.

**C (Consequence)** is the harm following an hazardous event (including ill health and injury, damage to property, products or the environment, production losses or increased liabilities).

### RISK MATRIX FOR SIL REQUIREMENT ALLOCATION

The Risk Matrix has the duty to combine the Demand Rate for each logic function and the relevant Consequences in case of failure on Demand. The proposed matrix is showed below.

Demand rate		SAFETY INTEGRITY LEVEL				
* ↓	<b>Frequent</b> (possibly every year)	1	SIL 1	SIL 2	SIL 3	SIL 4
	<b>Probable</b> (Several times during life cycle)	2	SIL 1	SIL 1	SIL 2	SIL 3
	<b>Rare</b> (possibly one time in the life cycle)	3	No action	SIL 1	SIL 2	SIL 3
	<b>Remote</b> (not expected during life cycle)	4	No action	No action	SIL 1	SIL 2
			1	2	3	4
			Minor damage	Serious damage	Extensive damage	Large Scale damage
			GRAVITY of CONSEQUENCES			

NOTE\*: If the hazard can be efficiently prevented by other measures, go one step below. Suitable prevention systems are the PSV. Alarms are considered as suitable system only if the alert is given with sufficient time interval to allow the operator taking the corrective actions. Otherwise derating is not allowed.

Table 9 - Risk Matrix for SIL Allocation

### DEMAND RATE

The classification of Demand Rate is made according to the table below, showing also the application of some sample cases for frequency identification.

Frequency (event/year)	Demand Rate		Example
> 1	1	Frequent	<ul style="list-style-type: none"> <li>▪ Control valve travels to fail safe position</li> <li>▪ Wrong action for a seldom practised operation</li> <li>▪ Untightness of a check valve</li> <li>▪ Failure of a pump / compressor</li> <li>▪ Critical failure of a non-fail safe control loop</li> </ul>
0.1 - 1	2	Probable	<ul style="list-style-type: none"> <li>▪ Control valve travels against fail safe position</li> <li>▪ Wrong action during frequent operation</li> <li>▪ Failure of electric motor</li> <li>▪ Failure of compressor's seal</li> <li>▪ Tube rupture within a heat exchanger</li> <li>▪ Critical failure of a fail-safe control loop</li> <li>▪ Failure of DCS</li> <li>▪ Total failure of a well maintained check valve</li> </ul>
0.01 – 0.1	3	Rare	<ul style="list-style-type: none"> <li>▪ Critical failure of a fail-safe PLC shut down</li> <li>▪ Total failure of a check valve with special safety demands</li> </ul>
< 0.01	4	Remote	<ul style="list-style-type: none"> <li>▪ Has never been recorded in similar plants of the company</li> </ul>

**Table 10 - Risk Matrix - Demand Rate**

For more detailed analysis, it is suggested to perform the evaluation of the Demand Rate by means of the Fault Tree techniques. The numerical results of Fault Tree Analysis are executed with specific software (e.g. the ASTRA - FTA, released by the European Joint Research Centre).

Reliability data for the analysis of the single events will be taken from industrial experience and from the internationally accepted sources, such as:

- Supplier's data;
- "The Cremer & Warner Report" – 1981;
- DNV Technica, "E&P Forum Report" – 1992;
- F.P. Lees, "Loss prevention in the chemical industry", IV Edition – 1992;
- CCPS/AIChE;
- R&M consultant;
- SINTF 2003 "Reliability Data Instrumented System";
- Exida "Safety Equipment Reliability Handbook".

## CONSEQUENCES

The classification of gravity of the consequences is made according a set of criteria which identify the risks in terms of human beings, the environment and the economic losses connected to the failure on demand of the logic function. The matrix for identification of gravity of consequences is indicated in the table below.

Selection of consequences gravity category is connected to the highest possible category for each analysed task (injuries, environment).

Gravity		Personnel	Environmental
1	Minor damage	Small/minor injuries	On unit release of non-toxic substance (low concentration at ground level)
2	Serious damage	Major injuries	On site release of toxic substances / Off Unit release of non-toxic substance
3	Extensive damage	At least one fatality and necessity for external treatment	Release of toxic substances on site and Off Unit.
4	Large Scale damage	Multiple fatalities	Large release of toxic substances on and Off Site

**Table 11 - Risk Matrix - Gravity of consequences**

If the hazard could be prevented by other technical measures (e.g. alarms on same or other process parameters), availability of other protection layers (e.g. presence of PSV), then the SIL Team has the possibility to reduce of one order the level of frequency of the expected event, reducing the SIL accordingly to the Matrix.

Regarding the Consequences for personnel, specific reference to the effective presence of the operator in the hazardous area is made in order to select the most appropriate level of consequences.

For this purpose, the following matrix is applicable. The matrix provides guidelines to establish the level of consequence to the personnel as function of the typology of incident and to differentiate the final consequence level in relation to the effective presence of personnel in the plant area.

The first step for this calculation is to use the table in the lower side of the matrix, which defines:

- by row the possible typology of scenario (fire/explosion, fragmentation, poisoning);
- by columns the possible dimension of the scenario (e.g. for the case of fire, three possible cases are suggested: flange leakage, pipe fitting rupture, release from process equipment, according to increasing level of consequences).

Once the typology of scenario is selected, it is necessary to select the Exposure time, in accordance to the indications provided by the table in the right side of the matrix. This table defines by rows two different level of exposure:

- rare exposure, which foresees that the permanence of personnel in the area of potential damage is limited in time (typical case is the area of a not permanently manned plant in which presence of personnel is foreseen only during maintenance and inspections)
- frequent exposure, which foresees that the area of potential damage is permanently manned (typical case is a control room or a manned control panel).

After selection of the two cases, it is necessary to pass through the main table and individuate the corresponding value of Consequence level.

For example, in the hypothesis that the scenario is a release from a flange in a not permanently manned area, the corresponding value of Consequence level is set equal to 1.

The philosophy at the base of such analysis is that in case the scenario is located in a not permanently manned area, the potential consequence for people are judged to be less critical than the same scenario where presence of people can be considered as permanent. The final consequence is therefore derated of one level, which at the end means also that required SIL for the protection loop is derated of one level.

CONSEQUENCES FOR PERSONNEL			Exposure Time Risk	
1	2	3	0.1	<b>Rare exposure</b> in the endangered zone (10% of the time): <ul style="list-style-type: none"> <li>only during inspections or maintenance</li> <li>if the remedial for accident does not require personnel in the endangered zone</li> </ul>
2	3	4	1	<b>Frequent or permanent exposure:</b> <ul style="list-style-type: none"> <li>manned control panel for machinery</li> <li>if the remedial for accident requires personnel in the endangered zone</li> <li>control room</li> <li>residential area if the extent of the accident is over the site fence</li> </ul>
CAUSES				
<b>Risk of fire / explosion</b>	Leakage at flange	Release from a pipe fitting	Major release from a process equipment	
<b>Risk of fragmentation</b>	No such risk	Damage of pressurised systems; fragmentation of minor equipment	Damage of pressurised systems; fragmentation of major equipment	
<b>Risk of poisoning</b>	Release of small amount of toxic substances	Minor release of toxic substances	Major release of toxic substances	

Table 12 - Definition of Gravity of consequences for personnel

### 4.3 PHASE 2 – VERIFICATION

After the identification of SIL levels that each single trip logic has to satisfy, the SIL analysis requires the operative numerical check on the basis of the proposed design

In this stage, SIL Verification of each Safety Instrumented Function (SIF) shall be performed through the following steps:

- Logical representation of the SIF architecture;
- Gathering of the reliability data of each SIF component;
- Calculation of total PFD of SIF and verification that calculated PFD and relevant calculated SIL level are consistent with the requirement arisen in SIL Allocation phase;
- Verification of the architectural requirements (Hardware fault tolerance / Safe Failure Fraction) for each component of the SIF, as per paragraph 7.4.3 of IEC 61508-2 and tables 2 and 3 (subsystem of type A or B).

#### 4.3.1 Representation of SIFs Architectures

In order to properly define the logical path that leads to a SIF unavailability (failure on demand), it is necessary to identify the architecture of each safety instrumented function.

For a correct and effective analysis, architectures of each SIF shall be sketched up showing:

- Sensors (e.g. pressure transmitters, etc.): in case of more than one sensor, the voting system shall be specified;
- Logic solver;
- Final Element/Elements (e.g. valves); in case of more than one sensor, the voting system shall be specified.

According to the voting system of the above mentioned elements, the logical diagram is drawn.

An example of SIF architecture sketch is shown in **Attachment 2**.

As far as final elements are concerned, it has to stressed that only the actions necessary to put in safe condition the system to be protected by the SIF have to be identified, neglecting all the complementary action which might be triggered by the same logic (shown in cause and effects matrixes).

All the actions not necessary to reach the safe condition of the system to be protected will not be taken into account in SIL Verification step, and thus they will be neglected in SIF Architecture definition.

### 4.3.2 Reliability Data collection

For every component of each Safety Instrumented Function reliability data shall be collected basing on the following sources:

- component’s certificates (to be preferred, if available) or other technical documents provided by vendor;
- reliability data from Exida “Safety Equipment Reliability Handbook”.

Main reliability data to be collected and used in PFD calculation are summarised in the following table.

Parameter	Description
$\lambda_{DD}$	Dangerous Failure Rate – Detected
$\lambda_{DU}$	Dangerous Failure Rate – Undetected
<b>MTTR</b>	Mean Time To Restoration
<b>SFF</b>	Safe failure fraction
$T_i$	Time interval between proof tests
$\beta$	Fraction of undetected failures that have a common cause
$\beta_D$	Fraction of detected failures that have a common cause

**Table 13 - Main reliability data required for SIL Verification**

If Common Cause Failure factors ( $\beta$  and  $\beta_D$ ) for redundant elements are not available, it will be generally assumed as 5% of dangerous undetected failure rate.

It is generally assumed that maintenance capability is 100%, which means that repairable components are “as good as new” once restored after failure detection during maintenance.

Following table summarizes the main aspects to be clarified in order to properly use the data from components certificates or to correctly choose the reliability figures in previously mentioned Exida data base.

SIF Element	Information
Sensor (e.g. level transmitter)	Displacement, radar, etc.
Logic Solver	To be considered as overall package unit/ to be analysed in single sub-components (input module, output module, main processor / s etc.)
Valve (solenoid)	2-ways, 3-ways, etc.
Valve (actuator)	Linear, quarter turn, etc.
	Single effect (spring return), double acting, etc.
	Pneumatic, hydraulic etc.
	Provided with PVST (Partial Valve Stroke Test) or not
Valve (body)	Ball, gate, etc.
	Clean/ severe service
	Close on trip/ open on trip

SIF Element	Information
	Fail open/ fail close
	Required TSO or not
	Provided with PVST (Partial Valve Stroke Test) or not

**Table 14 - Additional information required for SIL Verification**

#### 4.3.4 Reference for the selected reliability values

The reliability data shall be preferably taken from certificates / other technical documentation of the vendor. The use of information from databank shall be limited as much as possible since it would lead to the following consequences:

- incertitude that the selected figures are effectively representative of the actual components;
- usually higher values of PFDavg leading to excessively conservative calculation.

In case that vendor's data are not available, the reliability data can be taken from the following source:

- "Exida 2007: Safety Equipment Reliability Handbook, Exida – 3rd Edition, 2007".

#### 4.3.5 Application of availability models in order to establish the overall PFD of the complete loop

Average value of Probability of Failure on Demand (PFD) calculation of the whole safety function is performed in accordance with IEC 61508-6.

In order to evaluate the overall PFD of the loop, following formula applies:

$$PFD_{SYS} = PFD_S + PFD_{LS} + PFD_{FE}$$

being:

- $PFD_{SYS}$  Average Probability of Failure on Demand of Safety Function
- $PFD_S$  Average Probability of Failure on Demand of Sensor
- $PFD_{LS}$  Average Probability of Failure on Demand of Logic Solver
- $PFD_{FE}$  Average Probability of Failure on Demand of Final Element

The average PFD calculation will be performed by means of software such as FTA-Pro by IHS, basing on Fault Tree Analysis (FTA) technique for quantitative calculation of systems unavailability.

Fault trees are built basing on the logic architecture of each Safety Instrumented Function analysed and using as input data the specific reliability figures collected for every component.

The Unavailability (Q) of the Safety Instrumented Function calculated at the medium point of mission time is assumed as average value of probability of failure on demand for the SIF under examination.

An example of FTA graphic outline and relevant calculation results is showed in **Attachment 3**.

In the following paragraphs some example of mathematical simplified formula for PFD calculation, as provided by IEC 61508-6, are described.

#### SINGLE ELEMENT (1 OO 1 LOGIC)

$$t_{CE} = \frac{\lambda_{DU}}{\lambda_D} \cdot \left( \frac{T_1}{2} + MTTR \right) + \frac{\lambda_{DD}}{\lambda_D} \cdot MTTR$$

$$PFD_G = (\lambda_{DU} + \lambda_{DD}) \cdot t_{CE}$$

being:

- $\lambda_D$  Element dangerous failure rate

- $\lambda_{DD}$  Element dangerous failure rate – detected
- $\lambda_{DU}$  Element dangerous failure rate – undetected
- MTTR Element Mean Time To Restoration
- $T_1$  Time interval between proof tests
- $t_{CE}$  Channel Equivalent Mean Down Time
- $PFD_G$  Average Probability of Failure on Demand of the group

**REDUNDANT ELEMENTS (1 OO 2 LOGIC)**

$$t_{CE} = \frac{\lambda_{DU}}{\lambda_D} \cdot \left(\frac{T_1}{2} + MTTR\right) + \frac{\lambda_{DD}}{\lambda_D} \cdot MTTR \quad ; \quad t_{GE} = \frac{\lambda_{DU}}{\lambda_D} \cdot \left(\frac{T_1}{3} + MTTR\right) + \frac{\lambda_{DD}}{\lambda_D} \cdot MTTR$$

$$PFD_G = 2 \cdot ((1 - \beta_D) \cdot \lambda_{DD} + (1 - \beta) \cdot \lambda_{DU})^2 \cdot t_{CE} \cdot t_{GE} + \beta_D \cdot \lambda_{DD} \cdot MTTR + \beta \cdot \lambda_{DU} \left(\frac{T_1}{2} + MTTR\right)$$

being the parameters not defined in previous paragraph:

- $t_{GE}$  Voted Group Equivalent Mean Down Time
- $\beta$  Fraction of undetected failures that have a common cause
- $\beta_D$  Fraction of detected failures that have a common cause

**REDUNDANT ELEMENTS (2 OO 3 LOGIC)**

$$t_{CE} = \frac{\lambda_{DU}}{\lambda_D} \cdot \left(\frac{T_1}{2} + MTTR\right) + \frac{\lambda_{DD}}{\lambda_D} \cdot MTTR \quad ; \quad t_{GE} = \frac{\lambda_{DU}}{\lambda_D} \cdot \left(\frac{T_1}{3} + MTTR\right) + \frac{\lambda_{DD}}{\lambda_D} \cdot MTTR$$

$$PFD_G = 6 \cdot ((1 - \beta_D) \cdot \lambda_{DD} + (1 - \beta) \cdot \lambda_{DU})^2 \cdot t_{CE} \cdot t_{GE} + \beta_D \cdot \lambda_{DD} \cdot MTTR + \beta \cdot \lambda_{DU} \left(\frac{T_1}{2} + MTTR\right)$$

The parameters have been already defined in previous paragraphs.

**4.3.6 PFD average requirement for Verification**

The SIF designed is positively verified in case:

$$PFD_{SYS} \geq PFD_{Requested}$$

### 4.3.7 Architectural requirements for Verification

With reference to IEC 61511-1, apart from verification of calculated average PFD / calculated SIL level with the required PFD/ SIL level from SIL Allocation, there is a further requirement to be satisfied for every subcomponent of each safety instrumented function.

For all components, according to the Hardware Fault Tolerance available, the Safe Failure Fraction shall be inside the range correspondent to the SIL level required for the SIF.

The following tables show the SFF required for components of type A, elements with low complexity (sensors, final elements and non-PE logic solvers) or type B, elements with high complexity (PE logic solvers):

Safe Failure Fraction	Hardware fault tolerance		
	0	1	2
< 60 %	SIL 1	SIL 2	SIL 3
60% - < 90%	SIL 2	SIL 3	SIL 4
90% - < 99%	SIL 3	SIL 4	SIL 4
≥ 99%	SIL 3	SIL 4	SIL 4

**Table 15 - Hardware safety integrity: architectural constraints on type A safety-related subsystems (ref. Table 2 of IEC 61508-2)**

Safe Failure Fraction	Hardware fault tolerance		
	0	1	2
< 60 %	Not allowed	SIL 1	SIL 2
60% - < 90%	SIL 1	SIL 2	SIL 3
90% - < 99%	SIL 2	SIL 3	SIL 4
≥ 99%	SIL 3	SIL 4	SIL 4

**Table 16 - Hardware Safety Integrity: architectural constraints on type B safety-related subsystems (ref. Table 3 of IEC 61508-2)**




## ATTACHMENT 1 – SIL ALLOCATION WORKSHEET

Study		Unit	
Client		Equipment / Line from	
Plant			
Meeting		Line to	
Leader		Function	
Team		Presence of additional safety barrier	
		C&E Diagram n.	
		P&I Diagram n.	
Notes			
Description of logic function		SIL Assessment	
TAG initiator		Demand rate	0
TAG logic solver		Consequences of failure on demand (safety, environment)	0
TAG actuator		Calculated SIL	
Design intent		Selected SIL	
Demand scenario		Consequences of failure on demand	0
Consequences of failure on demand		Calculated AIL	
Consequences of spurious trip		Selected AIL	
Notes			
Demand rate			
Level of consequences			
Safety			
Environment			
Asset			

Note: the matrix allows the possibility for the SIL Team to select a different SIL from the calculated one. The calculated SIL represents the rigorous value obtained from the loop architecture. The selection of the SIL Team might revise the calculated SIL in order to take into account other available devices in the process circuit that might prevent the request for the automatic trip (e.g. presence of alarms on same or other process variable).

ATTACHMENT 2 – EXAMPLE OF SIF ARCHITECTURE



ATTACHMENT 3 – EXAMPLE OF PFD CALCULATION BY FTA

