



# Druck-Setzungs-Versuch

## U 5 Ost E

Bearbeiter: Boe

Datum: 21.09.18

Auftragsnummer: 022445

Entnahmestelle: B 24/17


Tiefe [m]: 16,25

Labornummer: 21

Geolog. Bez.: Geschiebemergel



Normalspannung [kN/m<sup>2</sup>] (logarithmisch)



Versuch-Nr.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Normalspannung [kN/m <sup>2</sup> ]	10.0	30.0	60.0	120.0	250.0	510.0	1030.0	250.0	30.0	60.0	120.0	250.0	510.0	1030.0	2030.0
Meßuhrablesung [mm]	0.135	0.310	0.415	0.525	0.672	0.849	1.046	0.969	0.798	0.828	0.880	0.948	1.002	1.080	1.262
Steifemodul [MN/m <sup>2</sup> ]		1.6	4.0	7.6	12.4	20.6	37.0	-	-	14.0	16.2	26.8	67.4	93.3	76.9

Einbauhöhe [mm] = 14.000	w (vorher) [%] = 11,0
Probendurchmesser [mm] = 70	w (nachher) [%] = 9,6