



Druck-Setzungs-Versuch

U 5 Ost E

Bearbeiter: Boe

Datum: 21.09.18

Auftragsnummer: 022445

Entnahmestelle: B 68/17


Tiefe [m]: 21,70

Labornummer: 20

Geolog. Bez.: Geschiebemergel



Normalspannung [kN/m²] (logarithmisch)



Versuch-Nr.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Normalspannung [kN/m ²]	10.0	30.0	60.0	120.0	250.0	510.0	1030.0	250.0	30.0	60.0	120.0	250.0	510.0	1030.0	2030.0
Meßuhrablesung [mm]	0.043	0.159	0.227	0.295	0.400	0.555	0.746	0.679	0.515	0.538	0.580	0.638	0.700	0.772	0.968
Steifemodul [MN/m ²]		2.4	6.2	12.4	17.3	23.5	38.1	-	-	18.3	20.0	31.4	58.7	101.1	71.4

Einbauhöhe [mm] = 14.000	w (vorher) [%] = 9,6
Probendurchmesser [mm] = 70	w (nachher) [%] = 10