



Druck-Setzungs-Versuch

U 5 Ost E

Bearbeiter: Ti

Datum: 10.02.17


Auftragsnummer: 021785

Entnahmestelle: B 50


Tiefe: 21,25

Labornummer: 18

Geolog. Bez.: Geschiebemergel



Normalspannung [kN/m²] (logarithmisch)



Versuch-Nr.	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Normalspannung [kN/m ²]	0.0	30.0	60.0	120.0	250.0	510.0	1030.0	250.0	60.0	120.0	250.0	510.0	1030.0	2030.0
Meßuhrablesung [mm]	0.000	0.431	0.539	0.678	0.851	1.029	1.239	1.184	1.123	1.141	1.180	1.207	1.272	1.481
Steifemodul [MN/m ²]		0.97	3.9	6.0	10.5	20.4	34.7	-	-	46.7	46.7	134.8	112.0	67.0

Einbauhöhe [mm] = 14.000	w (vorher) [%] = 11,3
Probendurchmesser [mm] = 70	w (nachher) [%] = 10,0