



Druck-Setzungs-Versuch

U 5 Ost E

Bearbeiter: Ti

Datum: 21.12.16


Auftragsnummer: 021785

Entnahmestelle: B 9


Tiefe: 5,45

Labornummer: 8

Geolog. Bez.: Geschiebelehm



Normalspannung [kN/m²] (logarithmisch)



Versuch-Nr.	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Normalspannung [kN/m ²]	0.0	30.0	60.0	120.0	250.0	510.0	1030.0	250.0	60.0	120.0	250.0	510.0	1030.0	2030.0
Meßuhrablesung [mm]	0.000	0.572	0.658	0.795	0.958	1.140	1.325	1.271	1.223	1.240	1.262	1.296	1.362	1.558
Steifemodul [MN/m ²]		0.73	4.9	6.1	11.2	20.0	39.4	-	-	49.4	82.7	107.1	110.3	71.4

Einbauhöhe [mm] = 14.000	w (vorher) [%] = 12,1
Probendurchmesser [mm] = 70	w (nachher) [%] = 11,0