



Druck-Setzungs-Versuch

U5 Ost E

Bearbeiter: Ti

Datum: 23.11.16


Auftragsnummer: 021785

Entnahmestelle: B 56

Tiefe: 17,25

Labornummer: 7

Geolog. Bez.: Beckenton



Versuch-Nr.	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Normalspannung [kN/m ²]	0.0	30.0	60.0	120.0	250.0	510.0	1030.0	250.0	60.0	120.0	250.0	510.0	1030.0	2030.0
Meßuhrablesung [mm]	0.000	0.091	0.176	0.296	0.472	0.661	0.940	0.832	0.717	0.732	0.788	0.868	0.986	1.297
Steifemodul [MN/m ²]		4.6	4.9	7.0	10.3	19.3	26.1	-	-	56.0	32.5	45.5	61.7	45.0

Einbauhöhe [mm] = 14.000	w (vorher) [%] = 25,0
Probendurchmesser [mm] = 70	w (nachher) [%] = 20,3