



Zustandsgrenzen nach DIN 18 122

U5 Ost E

Bearbeiter: Ti

Datum: 03.07.18

Auftragsnummer: 022445

Entnahmestelle: B 75a/17

Tiefe [m]: 13,50

Labornummer: 40

Geolog. Bez.: Geschiebemergel

Nr.	1	2	3	4	5	6
Art	wL	wL	wL	wp	wp	wp
Schläge	25	25	25	-	-	-
mf + mb [g]	72.61	76.57	77.25	37.18	38.14	40.91
mt + mb [g]	65.52	68.19	69.48	35.58	36.50	39.09
mb [g]	22.27	20.04	24.96	22.11	22.80	23.89
mw [g]	7.09	8.38	7.77	1.60	1.64	1.82
mt [g]	43.25	48.15	44.52	13.47	13.70	15.20
w [%]	16.39	17.40	17.45	11.88	11.97	11.97

Wassergehalt w =	12.8 %
Fließgrenze w_L =	17.1 %
Ausrollgrenze w_P =	11.9 %
Plastizitätszahl I_P =	5.2 %
Konsistenzzahl I_C =	0.83

