



Druck-Setzungs-Versuch

U 5 Ost E

Bearbeiter: Ti

Datum: 21.12.16

Auftragsnummer: 021785

Entnahmestelle: B 11


Tiefe: 30,75

Labornummer: 10

Geolog. Bez.: Geschiebemergel



Normalspannung [kN/m²] (logarithmisch)



Versuch-Nr.	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Normalspannung [kN/m ²]	0.0	30.0	60.0	120.0	250.0	510.0	1030.0	250.0	60.0	120.0	250.0	510.0	1030.0	2030.0
Meßuhrablesung [mm]	0.000	0.578	0.685	0.830	1.010	1.225	1.447	1.399	1.337	1.362	1.389	1.420	1.480	1.694
Steifemodul [MN/m ²]		0.73	3.9	5.8	10.1	16.9	32.8	-	-	33.6	67.4	117.4	121.3	65.4

Einbauhöhe [mm] = 14.000	w (vorher) [%] = 10,8
Probendurchmesser [mm] = 70	w (nachher) [%] = 9,3